DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



# CITY OF PORTLAND BUILDING PERMIT



This is to certify that AAA Fire, Inc.
of 328 Rodman Road, Auburn, Maine

For installation at 468 FORE ST Miyake Restaurant

Job ID: 2011-06-1361-FAFS

CBL: 038 - - F - 008 - 001 - - - -

has permission to install a hood suppression system

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in, 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be

Fire revention Officer

Code Enforcement Officer / Plan Reviewer

THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY PENALTY FOR REMOVING THIS CARD

DIL to due out

#### **BUILDING PERMIT INSPECTION PROCEDURES**

Please call 874-8703 or 874-8693 (ONLY)

or email: buildinginspections@portlandmaine.gov

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.
- Permits expire in 6 months. If the project is not started or ceases for 6 months.
- If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUOPIED.



## PORTLAND MAINE

Strengthening a Remarkable City, Building a Community for Life . www.portlandmaine.gov

Director of Planning and Urban Development Penny St. Louis

Job ID: 2011-06-1361-FAFS

Installation of a hood suppression system

For installation at: 468 FORE ST

CBL: <u>038 - - F - 008 - 001 - - - - -</u>

#### **Conditions of Approval:**

#### Fire

Hood suppression system shall comply with NFPA 17A, 96, and UL 300. Activation of the suppression system shall activate the fire alarm system if available. A letter of compliance will be required at the time of final inspection stating: the date the system was tested for operation, fuel gas shut off, and fire alarm connection if applicable. The Class K fire extinguisher and proper signage should be located at the suppression system pull station.

#### City of Portland, Maine - Building or Use Permit Application

389 Congress Street, 04101 Tel: (207) 874-8703, FAX: (207) 8716

Job No: 2011-06-1361-FAFS	Date Applied: 6/3/2011		CBL: 038 F - 008 - 001				
Location of Construction: 468 FORE ST	Owner Name: DICTAR ASSOCIATES		Owner Address: PO BOX 3572 PORTLAND, ME 04104			Phone:	
Business Name:	Contractor Name: AAA Fire Inc.		Contractor Address:			Phone: 207-784-8306	
Lessee/Buyer's Name:	Phone:		Permit Type: FIRE SUPPRESSION SYSTEM			Zone: B-3	
Past Use: Miyake Restaurant	Proposed Use:  Miyake Restaurant – non-water-based fire suppression system in kitchen		Cost of Work: 3000.00  Fire Dept:	Approved w/ conditions  Denied  N/A		CEO District  Inspection: Use Group: Type: Signature:	
Proposed Project Description Install Non-Water Fire Suppress Permit Taken By:			Pedestrian Activ	Zoning Appr			
<ol> <li>This permit application does not preclude the Applicant(s) from meeting applicable State and Federal Rules.</li> <li>Building Permits do not include plumbing, septic or electrial work.</li> <li>Building permits are void if work is not started within six (6) months of the date of issuance. False informatin may invalidate a building permit and stop all work.</li> </ol>		to conform to all applicable laws of		his jurisdiction. In add	Not in Di  Does not  Requires  Approved  Approved  Denied  Date:  Ard and that I have been a dition, if a permit for wo	Date: Afther did that I have been authorized by if a permit for work described in	



### Non-Water-Based Fire Suppression System Permit

If you or the property owner owes real estate or property taxes or user charges on any property within the city, payment arrangements must be made before permits of any kind are accepted.

	70 -0					
Installation address: 468 Fore Street	CBL: 38 -F-8					
Exact location: (within structure) Kitchen						
Type of occupancy(s) (NFPA & ICC): NFPA						
Building owner: Miyake Restaraunt						
Managing Supervisor: Will Garfield	License No:					
Supervisor phone: 207-272-3346						
Installing contractor: AAA Fire	_ License No:					
Contractor phone: 207-784-8306	E-mail: brian@aaafireinc.com					
The suppression work to be done will be: New: Renov	ation: Addition to existing system:					
This is an amendment to an existing permit: Yes: NO Permit no:						
System Type: UL 300 Amerex COST OF WORK: 2325.00						
NFPA Standard: 17A Edition: 2009	C.					
*Non-NFPA systems are not approved for use within the City of Portland.	PERMIT FEE:					
Download a new copy of this document from						
www.portlandmaine.gov/fire for every submittal. Attach all working						
documents as required on electronic PDF's in addition to	CC					
full sized plans.						
1328 Rodnu	WEL					
328 Rodnu	CE MI ONE					
Acerbaic	3 085,10					
Submit all information to the Building Inspections Department, 389 Congress Street, Room 315, Rortland, Maine 04101.						
Prior to acceptance of any fire protection system, a complete commissioning and acceptance test must be coordinated with						
all fire system contractors and the Fire Department, and proper documentation of such test (soprovided.						
All installation(s) must comply with NFPA and the Fire Department Technical Standard(s).						
Applicant signature: Bill Hyll Date: 6-3-11						