



CITY OF PORTLAND

DEPARTMENT OF PLANNING & URBAN DEVELOPMENT
INSPECTION SERVICES DIVISION

August 7, 1987

Baysice II Associates
148 Spring Street
Portland, ME 04101

Re: 459-465 Cumberland Avenue 36-F-18, 19

Dear Sir:

We recently received a complaint and an inspection was made by Code Enforcement Officer Burton MacIsaac of the property owned by you at 459-465 Cumberland Avenue, Portland, Maine. As a result of the inspection, you are hereby ordered to correct the following substandard housing conditions:

1. This building must be provided with two (2) separate and remote means of egress. 6-116


The above mentioned conditions are in violation of Article V of the Municipal Code of the City of Portland, Maine, and must be corrected on or before August 15, 1987

Failure to comply with this order -
prosecution in District Court.

Complaint being filed for

Sincerely yours,
Joseph E. Gray, Jr., Director of
Planning & Urban Development

By


P. Samuel Hoffges
Chief of Inspection Services

Burton MacIsaac, Code Enforcement Officer (6)

jmr