Travel Distance to Exit

Common Path of Travel to location where two means of egress are available

Occupant Load:

5th Floor:
gross floor area 8128 sf
Business Load Factor = 1 per 100
Busines Gross Area = 8128 sf = 81 Occupants

Total at 3rd floor = 81 Occupants

Widths by calculation are below minimum required by code
81 x .2 = 16.6
81 x .3 = 24.3

Exit Light Fixture, unswitched, with directional arrows

CL — Self contained emergency light with (2) 5 watt heads with 10 watt capacity for 90 minutes. CL indicates ceiling mount

EXIT — Access to protected stair. Stair discharges directly to grade. Stair is assumed to be rated 2 hours as required by code

Inspections Division

Date: 09/10/15

## 5th Floor Plan

3/16" = 1'-0"

1. contractor shall verify where solid blocking is required and provide blocking appropriate to items to be supported
2. All fire extinguishers shall be provided in ADA compliant cabinet mounts

d — DIRTT wall system, glazed

d — DIRTT wall system, opaque


facilitation

Lisa Whited
Chief Transformation Officer
207. 329. 2189 lisa@workplacetf.com

Michael Barton
Value and Constructability Analyst
207. 939. 5432 michael@workplacetf.com

Josef Chalat
Maine Licensed Architect
207. 318. 3234 AzimuthBlu@gmail.com

Mechanical and Electrical Engineering:
Bennet Engineering
contact: Cat Tranberg
ph (207) 865-9475
Cat@bennettengineering.net


Project:

MEMIC
Tenant Improvement to 3rd, 4th, and 5th floors
261 Commercial Street, Portland Maine
CBL 038 F019

Tenant: MEMIC
261 Commercial Street
Portland Maine, 04101

Tenant Contact
Catherine Lamson,
Senior Vice President
Chief Administrative Officer
(207) 791 3304

Building Owner:
Casco View Holdings II, LLC
PO Box 1137
Portland, ME 04104

General Contractor:
Zachau Construction
1185 U.S. Route One
Freeport, ME 04032
ph (207) 865-9925 (office)
contact: Jon
207.807.8980 (mobile)
Jon@zachauconstruction.com

| Date | Purpose |
|---|---|
| 08/13/2015 | Review by JD not for construction |

Sheet Title
5th Floor Life Safety Plan

Sheet Number
LS-3