
DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK





PERMIT ID: 2013-00593

Located at

19 CROSS ST (called 261 Commercial St.)

CASCO VIEW HOLDINGS II LLC /Simplex / Grinnell

ISSUE DATE: 04/18/2013 038 F019001 CBL:

has permission to install fire alarm on 1st & 6th floors & penthouse (MEMIC)

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

Fire Prevention Officer

Code Enforcement Officer / Plan Reviewer

THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY THERE IS A PENALTY FOR REMOVING THIS CARD

	•		ding or Use Permit 207) 874-8703, Fax: (20	Permit No: 2013-00593	Date Applied For: 03/27/2013	CBL: 038 F019001				
Location of Construction:			Owner Name:	Owner Address:			Phone:			
19 CROSS ST (called 261 Commerc			CASCO VIEW HOLDINGS II LLC		PO BOX 1137					
Business Name:			Contractor Name:		Contractor Address:		Phone			
	EMIC	4	Simplex / Grinnell		20 Thomas Drive Westbrook		(207) 842-6440			
Less	see/Buyer's Name		Phone:		Permit Type: Fire Alarm Systen	1				
	posed Use: fice					sed Project Description: Il fire alarm on 1st & 6th floors & penthouse (MEMIC)				
UI	lice			instal	Thre alarm on 1st &	our noors & pentro	ise (MEMIC)			
Dept: Zoning Status: Approved Reviewer: Ann Machado Approval Date: 03/28/2013 Note: Ok to Issue: Image: Comparison of the second secon										
	ept: Fire	Status: A	pproved w/Conditions	Reviewer	: Ben Wallace Jr	Approval Da				
	ote:			4.1114			Ok to Issue: 🗹			
) Notice: The first scheduled final inspection fee is at no charge. Additional inspections shall be billed at \$75 for each inspector.									
2)) A Knox Box is required.									
3)	3) Supervising Station monitoring for addressable fire alarm systems shall be by point.									
4)) Records cabinet, FACP, annunciator(s), and pull stations shall be keyed alike.									
5)	All fire alarm records required by NFPA 72 should be stored in an approved cabinet located at the FACP labeled "FIRE ALARM RECORDS".									
6)	Manual Pull Stations are required per NFPA 101:30.3.4.2.1 at all exit doorways and within 200 feet of travel.									
7)	In field installation shall be installed per code as conditions dictate.									
8)	The fire alarm system shall have a new fire alarm inspection sticker.									
9)	 The installation shall comply with the following: City of Portland Chapter 10, Fire Prevention and Protection; NFPA 1, Fire Code (2009 edition), as amended by City Code; NFPA 101, Life Safety Code (2009 edition), as amended by City Code; City of Portland Fire Department Rules and Regulations; NFPA 72, National Fire Alarm and Signaling Code (2010 edition), as amended by Fire Department Rules and Regulations; and NFPA 70, National Electrical Code (2011 edition) as amended by the State of Maine 									
10	0 All smoke detectors shall be photoelectric.									
11	Through-penetrations and membrane penetrations in fire walls, fire barrier walls, and fire resistance rated horizontal assemblies shall be protected by firestop systems or devices in conformance with NFPA 101:8.3.5 (ASTM E 814 or ANSI/UL 1479). Providing firestop labels at each firestop system or device and an onsite manual containing the detail for each firestop system or device used for the project will streamline final inspection approvals.									
12	The fire alarm technician shall be present for the fire inspection. System acceptance and commissioning must be coordinated with alarm and suppression system contractors and the Fire Department. Call 874-8703 to schedule.									
13	Fire protection systems shall be maintained. If system is to be off line over 4 hours a fire watch shall be in place. Dispatch notification required 874-8576.									

BUILDING PERMIT INSPECTION PROCEDURES Please call 874-8703 (ONLY) or email: buildinginspections@portlandmaine.gov

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.
- Permits expire in 6 months. If the project is not started or ceases for 6 months.
- If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.

REQUIRED INSPECTIONS:

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.



Fire Alarm Permit

If you or the property owner owes real estate or property taxes or user charges on any property within the city, payment arrangements must be made before permits of any kind are accepted.

		000	Faio
Installation address: 261 Commercia	al St (Memic)	_ CBL: 038	4014
Exact location: (within structure) 1st, 6	th, and Penthouse		
Type of occupancy(s) (NFPA & ICC): 0			
Building owner: Jerry Debransky			
Must be System Designer (point of contact): lan	Gregory		
Designer phone: (603) 886-1100		E-mail: igregory@s	implexgrinnell.com
Installing contractor: JT Hayman/Sir	nplexgrinnell	_ Certificate of Fitness N	o: 1019
Contractor phone: John Hale (207)2	39-5100	E-mail: johale@sim	plexgrinnell.com
This is a new application: YES		AES Master Box: YES lude Master Box approval	
Amendment to an existing permit: YES	NO O Perm	nit no:	
The following documents shall be provided a	with this application:		60
Floor plans	Scope of Work	COST OF WORK	0,000
Wiring diagram	1 ½ x 17s	PERMIT FEE: 4	00.00
Amunciator details	df copy (may be c-mailed)		D FOR THE FIRST \$1,000)
Input/ Output Matrix	Designer qualifications	Please cal	1 Wendy
Equipment data sheets	Sattery/ voltage drop calcs	Have @ 20	7-482-2350
Electrical Permit Pulled (check alarm	/com)	for credit	-card payment
Master box approval only: YES (If yes check New AES Master Bo	NO O ax above)		2
The <u>designer</u> shall be the responsible pa	rty for this application. D	ownload a new copy of this	application at
<u>www.portlandmainc.gov/fire</u> for every subm	ittal. Submit all plans in cl	lectronic PDF in <u>addition</u>	a to readable 11 ½ x 17s to
the Building Inspections Department, 38	9 Congress Street, Room	315, Portland, Maine 04	101.

Prior to acceptance of any fire alarm system, a complete commissioning and acceptance test must be coordinated with all fire system contractors and the Fire Department, and proper documentation of such test(s) provided.

All installation(s) must comply with the City of Portland Technical Standard for Signaling Systems for the Protection of Life and Property, available at www.portlandmaine.gov/fire.

Applicant signature:	Zam	Date:	3/22/13	
	LEVEL IV CERTIFIED IAN GREGORY JAN GREGORY			