



FLOOR PLAN
 SCALE: $1/4" = 1'-0"$
 NOTE: NO PROPOSED CHANGES TO EXISTING
 CODE COMPLIANT SPRINKLER SYSTEM

5 INTERIOR WALL
 SCALE - $1/2" = 1'-0"$
 NOTES:
 -ALL WET WALLS REQUIRE $1\frac{1}{2}"$ GAP BOTH SIDES BETWEEN PLUMBING AND FACE OF STRUCTURE
 -SUBSTITUTE WATER RESISTANT OR DURASHIELD WHERE APPROPRIATE
 -ALL POCKET DOOR WALLS TO BE 2X6
 -ALL GARAGE WALLS TO BE MIN. 1 HR. FIRE RATED

INTERIOR WALL CONSTRUCTION:
 ONE LAYER $1/2"$ SHEET ROCK EACH SIDE W/LEVEL 5 FINISH OVER 2X STEEL STUD WALL WITH FIBERGLASS SOUND INSULATION AT ALL CAVITIES

VARIABLES SEE PLANS

4 INTERIOR WALL - 1HR
 SCALE - $1/2" = 1'-0"$
 NOTES:
 -ALL WET WALLS REQUIRE $1\frac{1}{2}"$ GAP BOTH SIDES BETWEEN PLUMBING AND FACE OF STRUCTURE
 -SUBSTITUTE WATER RESISTANT OR DURASHIELD WHERE APPROPRIATE
 -ALL POCKET DOOR WALLS TO BE 2X6
 -ALL GARAGE WALLS TO BE MIN. 1 HR. FIRE RATED
 -FILL ALL PENETRATIONS WITH SPRAY FOAM

INTERIOR WALL CONSTRUCTION:
 ONE LAYER $5/8"$ SHEET ROCK INTERIOR SIDE OVER EXISTING STRUCTURE TO REMAIN WITH FIBERGLASS INSULATION AT ALL CAVITIES & FOAM AT ALL PENETRATIONS

VARIABLES SEE PLANS

