

Jeanie Bourke <jmb@portlandmaine.gov>

269 Commercial St. BP# 2016-02613

Tim Gilbert <timwgilbertinc@gmail.com>
To: Jeanie Bourke <jmb@portlandmaine.gov>

Wed, Nov 23, 2016 at 8:16 AM

Hi Jeanie.

On Fri, Nov 18, 2016 at 9:31 AM, Jeanie Bourke <jmb@portlandmaine.gov> wrote: Hi Tim.

My apologies for the delay in the permit review, I am looking at this now and have some questions:

- 1. I do not see any specifications on the windows in the submitted documents including dimensions, and insulating factors. The scope states that 3 of the windows will have newly constructed RO in the existing MO, are you just replacing damaged material?
- **Please see attached file for window details. I am replacing six windows. The ROs are being rebuilt as per engineered drawings attached to the original permit submission.**
 - 2. Are any of the windows in a hazard area that would require safety glazing, such as near stairs, tub/showers, doors, etc.
- **None of the windows are near any hazardous areas.**
 - 3. Are all of the sill heights above 24"? If not there will need to be hardware to restrict the amount of opening (barrier devices).
- **Yes. All of the sill heights are above 24".**

With this information I will be able to approve this permit in short order.

**Thank you for your email. Please let me know if you have any questions.

Sincerely, Tim Gilbert**

Thank you for your time,

Jeanie Bourke Code Enforcement Officer/Plan Reviewer

City of Portland
Permitting and Inspections Department
389 Congress St. Rm 315
Portland, ME 04101
jmb@portlandmaine.gov

(207)874-8715

Notice: Under Maine law, documents - including e-mails - in the possession of public officials or city employees about government business may be classified as public records. There are very few exceptions. As a result, please be advised that what is written in an e-mail could be released to the public and/or the media if requested.

Unit Summary, Windows for Harbor Landing.doc 126K