Portland Maine Yes. Google's good here.

Jeanie Bourke <jmb@portlandr

Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 11/28/16

269 Commercial St. BP# 2016-02613

Tim Gilbert <timwgilbertinc@gmail.com> Wed, Nov 23, 2016 at 8:16 AM
To: Jeanie Bourke <jmb@portlandmaine.gov>

Hi Jeanie,

On Fri, Nov 18, 2016 at 9:31 AM, Jeanie Bourke <jmb@portlandmaine.gov> wrote:

> Hi Tim,
>
> My apologies for the delay in the permit review, I am looking at this now and have some questions:
>
> 1. I do not see any specifications on the windows in the submitted documents including dimensions, and insulating factors. The scope states that 3 of the windows will have newly constructed RO in the existing MO, are you just replacing damaged material?

Please see attached file for window details. I am replacing six windows. The ROs are being rebuilt as per engineered drawings attached to the original permit submission.

> 2. Are any of the windows in a hazard area that would require safety glazing, such as near stairs, tub/showers, doors, etc.

None of the windows are near any hazardous areas.

> 3. Are all of the sill heights above 24"? If not there will need to be hardware to restrict the amount of opening (barrier devices).

Yes. All of the sill heights are above 24".

> With this information I will be able to approve this permit in short order.

**Thank you for your email. Please let me know if you have any questions.

Sincerely,
Tim Gilbert**

> Thank you for your time,
>
> Jeanie Bourke
> Code Enforcement Officer/Plan Reviewer
>
> City of Portland
> Permitting and Inspections Department
> 389 Congress St. Rm 315
> Portland, ME 04101
> jmb@portlandmaine.gov
> (207)874-8715
>
> Notice: Under Maine law, documents - including e-mails - in the possession of public officials or city employees about government business may be classified as public records. There are very few exceptions. As a result, please be advised that what is written in an e-mail could be released to the public and/or the media if requested.

Unit Summary, Windows for Harbor Landing.doc
126K

Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 11/28/16