#### DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



This is to certify that

Applicant: DAMON MECHANICAL SERVICES

Located at

269 Commercial St

**PERMIT ID:** 2018-00163

**ISSUE DATE:** 04/09/2018

CBL: 038 G002267

has permission to Install hood system over residential 4-burner gas range with oven.

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statutes of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 hour notice is required.

A final inspection must be completed before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Chris Pirone

/s/ Michael Russell, MS, Director

Fire Official

**Building Official** 

### THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY THERE IS A PENALTY FOR REMOVING THIS CARD

Approved Property Use - Zoning

**Building Inspections** 

Fire Department

**PERMIT ID:** 2018-00163 **Located at:** 269 Commercial St **CBL:** 038 G002267

## BUILDING PERMIT INSPECTION PROCEDURES Please call 874-8703

or email: buildinginspections@portlandmaine.gov

# Check the Status of Permit or Schedule an Inspection at http://www.portlandmaine.gov/planning/permitstatus.asp

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the City of Portland Inspections Division for the inspections listed below. Appointments must be requested 48 to 72 hours in advance. The inspection date will need to be confirmed by this office.

- Please read the conditions of approval that are attached to this permit.
- Permits expire in 6 months if the project is not started or ceases for 6 months.
- If the inspection requirements below are not followed, then additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.
- Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC), one set of printed approved stamped construction documents will be kept at the site of work and open to inspection by building officials.

### **REQUIRED INSPECTIONS:**

Final - Fire

The project cannot move to the next phase prior to the required inspection and approval to continue.

If the permit requires a certificate of occupancy, it must be paid and issued to the owner or designee before the space may be occupied.

**PERMIT ID:** 2018-00163 **Located at:** 269 Commercial St **CBL:** 038 G002267

City of Portland, Maine - Building or Use Permit 389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-						Permit No:	Date Applied For:	CBL:	
						2018-00163	02/05/2018	038 G002267	
Proposed Use:						Proposed Project Description:			
Same: Restaurant - Bam Bam Bakery					Install l	Install hood system over residential 4-burner gas range with oven.			
De	ept:	Historic	Status:	Approved	Reviewer:	Deborah Andrew	s Approval Da	ite: 04/06/2018	
No	ote:							Ok to Issue: 🔽	
Co	ondi	tions:							
De	ept:	Fire	Status:	Approved w/Conditions	Reviewer:	Chris Pirone	Approval Da	ite: 03/15/2018	
No	ote:	check w/installe	er reference	re-circulating hood.				Ok to Issue:	
Co	ondi	tions:							
1)		A separate Non-Water Based Suppression System permit is required. This review does not include approval of the suppression system design or installation.							
2)	Hood suppression system shall comply with NFPA 17A, 96, and UL 300. Activation of the suppression system shall activate the								
	fire alarm system if available. A letter of compliance will be required at the time of final inspection stating: the date the system was tested for operation, fuel gas shut off, and fire alarm connection if applicable. The Class K fire extinguisher and proper signage								
	should be located at the suppression system pull station.								
3)	A compliance letter stating that the installation meets NFPA codes from the installer shall submitted electronically prior to the inspection.								
4)	System acceptance and commissioning must be coordinated with a fire alarm technician and suppression system contractors and the Fire Department. Call 874-8400 to schedule.								
5)	The installation shall comply with the following: City of Portland Chapter 10, Fire Prevention and Protection; NFPA 1, Fire Code (2009 edition), as amended by City Code; NFPA 101, Life Safety Code (2009 edition), as amended by City Code; City of Portland Fire Department Rules and Regulations;								

**PERMIT ID:** 2018-00163 **Located at:** 269 Commercial St **CBL:** 038 G002267