

NOTES

Permit No. _____
Location 3-37 Center Street
Owner _____
Date of permit _____
Approved _____
Dwelling _____
Garage _____
Alteration _____

NOTES

Handwritten notes and a large 'X' mark on the lined paper.

9861

CITY OF PORTLAND, MAINE
DIVISION OF INSPECTION SERVICES

DEMOLITION CALL LIST

C. Lyons Building Co. 3-37 Court St
hereby requests permission to open
beginning on the following date April 14
for the following work as described: Demolition of premises

CITY OF PORTLAND

DEPARTMENT OF PARKS/PUBLIC WORKS

Sewer Division
Date: 3-24
775-463

DEPT. OF PARKS/PUBLIC WORKS

Traffic Division
Date: 3-24
775-5451, ext. 468, 469

DEPARTMENT OF PARKS/PUBLIC WORKS

Forestry Division
Date: 3-24
775-5451, ext. 333, 350, 351

DEPARTMENT OF PLANNING/URBAN DEVELOPMENT

Inspection Services Division
Date: 3-24
775-5451, ext. 374 (rodent/vermin/asbestos)

FIRE DEPARTMENT

Communications - Sam Allen
Date: 3-24
775-6361, ext. 21, 322

RECEIVED

MAR 24 1980

Maine Department of Environmental

Protection Bureau of Air Quality Control
State House Station 17
Augusta, ME 04333
Attn: Catharine Clayton-Richardson

United States Environmental Protection Agency

Region I, Air Management Division
Room 220
U.S.R. Federal Building
Boston, MA 02203

ASBESTOS NOTIFICATION:

PUBLIC CABLE CO. (7.7.)
George Grishy
Date: 3-24
775-2391

PORTLAND WATER DISTRICT
Joan Libby
Date: 3-24
774-5961, ext. 25

NORTHERN UTILITIES
Distribution Department
Date: 3-24
797-8002

NEW ENGLAND TELEPHONE CO.
Dig Safe Center
Date: 3-24
1-800-225-4977

CENTRAL MAINE POWER CO.
Meter Department
Date: 3-24
772-7411, ext. 290, 291, 292

UTILITY APPROVAL

I have contacted all of the above utility companies and/or necessary City departments.
DATE: 3-24
SIGNED: John G. Lund

1-39 Center St.
Sec 482-506 Front St.

SITUATION CORRECTED



CITY OF PORTLAND

DEPARTMENT OF PLANNING & URBAN DEVELOPMENT
INSPECTION SERVICES DIVISION

6/84
CMA

March 26, 1984

Mr. Fredrick Sullivan
c/o Shane's
3 Center Street
Portland, ME 04101

Dear Mr. Sullivan:


As is indicated on the attached letter dated January 6, 1984 noting several code deficiencies, most violations have been corrected, but three violations still exist.

- 1) The rear door must be properly hung and anti-panic hardware installed, eliminating the wooden closer.
- 2) The pinball machine must be licensed.
- 3) A hand rail must be installed on the rear stairs.

A reinspection will occur on April 23, 1984, and if violations are not corrected, this case will be forwarded to the City's Corporation Counsel for legal action.

If there are any questions, please contact this office at 775-5451, ext. 378.

Sincerely,


Mike Nugent
Code Enforcement Officer

MM/kat
Attachment