



**Notes:**

1. Provide 4" Minimum End Bearing
2. New Steel to be Galvanized, or Painted with an Exterior Paint System Coordinate with Owner.
3. All Means and Methods by Contractor.
4. Lintels Based on a Maximum Span = 7'-0"

**SECTION ——— Lintels at New Wall Openings**

Scale: 1" = 1'-0"

<b>SEI</b>	<b>Shelley Engineering, Inc.</b>		<b>48 Free Street</b>		
	Structural Consultants		Portland		ME
	P.O. Box 1030		Drawn By:	Date:	Sketch:
	Gray, Maine 04039		TGS	5/17/16	Sk1 of 1
Phone (207) 657-8031		Designed By:	Scale:	Job No.:	
www.ShelleyEngineering.com		TGS	AS NOTED	2016-084	