

**608/610 CONGRESS STREET
PORTLAND, MAINE**

ZONE	ADDRESS	DEVICE	FLOOR	DESCRIPTION	TEST RESULTS
1	1D001	SMOKE DETECTOR	GROUND	608 CONGRESS	PASS
2	1D002	SMOKE DETECTOR	GROUND	608 CONGRESS FRONT	PASS
3	1D003	HEAT DETECTOR	GROUND	608 CONGRESS BATH HALL	PASS
4	1D004	HEAT DETECTOR	GROUND	608 CONGRESS BATHROOM	PASS
5	1D005	HEAT DETECTOR	GROUND	608 CONGRESS BATHROOM	PASS
6	1D006	HEAT DETECTOR	GROUND	608 CONGRESS KITCHEN	PASS
7	1D007	HEAT DETECTOR	GROUND	610 CONGRESS REAR TATOO	PASS
8	1D008	HEAT DETECTOR	GROUND	610 CONGRESS CENTER TATOO	PASS
9	1D009	HEAT DETECTOR	GROUND	610 CONGRESS FRONT TATOO	PASS
10	1D010	SMOKE DETECTOR	1ST	610 CONGRESS FRONT HALL	PASS
11	1D011	HEAT DETECTOR	1ST	610A CONGRESS BEDROOM	PASS
12	1D012	HEAT DETECTOR	1ST	610A CONGRESS KITCHEN	PASS
13	1D013	HEAT DETECTOR	1ST	610 CONGRESS UNIT 1 KITCHEN	PASS
14	1D014	HEAT DETECTOR	1ST	610 CONGRESS UNIT 1 BEDROOM	PASS
15	1D015	SMOKE DETECTOR	1ST	610 CONGRESS REAR HALL	PASS
16	1D016	HEAT DETECTOR	BASEMENT	610 CONGRESS FRONT	PASS
18	1D018	HEAT DETECTOR	1ST	610 CONGRESS UNIT 2 KITCHEN	PASS
19	1D019	HEAT DETECTOR	1ST	610 CONGRESS UNIT 2 BEDROOM	PASS
20	1D020	SMOKE DETECTOR	2ND	610 CONGRESS REAR HALL	PASS
21	1D021	HEAT DETECTOR	2ND	610 CONGRESS UNIT 3 KITCHEN	PASS
22	1D022	HEAT DETECTOR	2ND	610 CONGRESS UNIT 3 BEDROOM	PASS
23	1D023	SMOKE DETECTOR	2ND	610 CONGRESS FRONT HALL	PASS
24	1D024	HEAT DETECTOR	2ND	610 CONGRESS UNIT 4 KITCHEN	PASS
25	1D025	HEAT DETECTOR	2ND	610 CONGRESS UNIT 4 BEDROOM	PASS
26	1D026	SMOKE DETECTOR	1ST	610 CONGRESS TOP OF BASEMENT STAIRS	PASS
27	1D027	HEAT DETECTOR	BASEMENT	608 CONGRESS	PASS
28	1D028	HEAT DETECTOR	3RD	610 CONGRESS UNIT 8 BEDROOM	PASS
29	1D029	HEAT DETECTOR	3RD	610 CONGRESS UNIT 8 KITCHEN	PASS
30	1D030	HEAT DETECTOR	3RD	610 CONGRESS UNIT 5 KITCHEN	PASS
31	1D031	HEAT DETECTOR	3RD	610 CONGRESS UNIT 5 BEDROOM	PASS
32	1D032	SMOKE DETECTOR	3RD	610 CONGRESS FRONT HALL BY UNIT 5	PASS
33	1D033	SMOKE DETECTOR	3RD	610 CONGRESS FRONT HALL BY UNIT 8	PASS
34	1D034	HEAT DETECTOR	3RD	610 CONGRESS UNIT 6 BEDROOM	PASS
35	1D035	HEAT DETECTOR	3RD	610 CONGRESS UNIT 6 KITCHEN	PASS
36	1D036	SMOKE DETECTOR	3RD	610 CONGRESS REAR HALL	PASS
37	1D037	HEAT DETECTOR	3RD	610 CONGRESS UNIT 7 KITCHEN	PASS
38	1D038	HEAT DETECTOR	3RD	610 CONGRESS UNIT 7 BEDROOM	PASS
39	1D039	HEAT DETECTOR	4TH	610 CONGRESS UNIT 11 KITCHEN	PASS
40	1D040	SMOKE DETECTOR	4TH	610 CONGRESS REAR HALL	PASS
41	1D041	HEAT DETECTOR	4TH	610 CONGRESS UNIT 10 KITCHEN	PASS
42	1D042	HEAT DETECTOR	4TH	610 CONGRESS UNIT 10 BEDROOM	PASS
43	1D043	SMOKE DETECTOR	4TH	610 CONGRESS FRONT HALL BY UNIT 9	PASS
44	1D044	SMOKE DETECTOR	4TH	610 CONGRESS FRONT HALL BY UNIT 12	PASS
45	1D045	HEAT DETECTOR	4TH	610 CONGRESS UNIT 9 BEDROOM	PASS
46	1D046	HEAT DETECTOR	4TH	610 CONGRESS UNIT 9 KITCHEN	PASS

**608/610 CONGRESS STREET
PORTLAND, MAINE**

ZONE	ADDRESS	DEVICE	FLOOR	DESCRIPTION	TEST RESULTS
47	1D047	HEAT DETECTOR	4TH	610 CONGRESS UNIT 12 KITCHEN	PASS
48	1D048	HEAT DETECTOR	4TH	610 CONGRESS UNIT 12 BEDROOM	PASS
49	1D049	HEAT DETECTOR	4TH	610 CONGRESS UNIT 11 BEDROOM	PASS
160	1M001	TROUBLE	BASEMENT	610 CONGRESS AES TROUBLE	PASS
161	1M002	PULL STATION	GROUND	608 CONGRESS FRONT	PASS
162	1M003	PULL STATION	GROUND	610 CONGRESS FRONT	PASS
163	1M004	PULL STATION	1ST	610 CONGRESS FRONT	PASS
165	1M006	PULL STATION	2ND	610 CONGRESS REAR	PASS
166	1M007	PULL STATION	3RD	610 CONGRESS FRONT	PASS
167	1M008	PULL STATION	3RD	610 CONGRESS REAR	PASS
168	1M009	PULL STATION	4TH	610 CONGRESS FRONT	PASS
169	1M010	PULL STATION	4TH	610 CONGRESS REAR	PASS
170	1M011	PULL STATION	BASEMENT	610 CONGRESS	PASS
171	1M012	PULL STATION	BASEMENT	608 CONGRESS	PASS
172	1M013	PULL STATION	GROUND	608 CONGRESS REAR	PASS
173	1M014	PULL STATION	GROUND	610 CONGRESS REAR	PASS
174	1M015	W-GATE	BASEMENT	W-GATE SUPERVISION(MESH 43)	PASS
175	1M016	W-DIS	BASEMENT	WIRELESS DEVICE TAMPER(MESH 43)	PASS
176	1M017	W-DIS	BASEMENT	WIRELESS DEVICE TROUBLE(MESH 43)	PASS
177	1M018	W-DIS	BASEMENT	WIRELESS DISPLAY DEVICE(MESH 43)	PASS
178	1M019	W-GATE	BASEMENT	W-GATE SUPERVISION(MESH 34)	PASS
179	1M020	W-DIS	BASEMENT	WIRELESS DEVICE TAMPER(MESH 34)	PASS
180	1M021	W-DIS	BASEMENT	WIRELESS DEVICE TROUBLE(MESH 34)	PASS
181	1M022	W-DIS	BASEMENT	WIRELESS DISPLAY DEVICE(MESH 34)	PASS

**608/610 CONGRESS STREET
PORTLAND, MAINE**

DEVICE	FLOOR	DESCRIPTION	TEST RESULTS
HORN/STROBE	BASEMENT	608 CONGRESS	PASS
HORN/STROBE	BASEMENT	610 CONGRESS	PASS
HORN/STROBE	GROUND	608 CONGRESS FRONT	PASS
HORN/STROBE	GROUND	608 CONGRESS BATH HALL	PASS
STROBE	GROUND	608 CONGRESS MEN'S BATHROOM	PASS
STROBE	GROUND	608 CONGRESS WOMEN'S BATHROOM	PASS
HORN/STROBE	GROUND	608 CONGRESS KITCHEN	PASS
HORN/STROBE	GROUND	610 CONGRESS FRONT	PASS
HORN/STROBE	GROUND	610 CONGRESS REAR	PASS
STROBE	GROUND	610 CONGRESS BATHROOM	PASS
HORN/STROBE	1ST	610 CONGRESS FRONT HALL	PASS
HORN/STROBE	1ST	610 CONGRESS REAR HALL	PASS
MINI SOUNDER	1ST	610A CONGRESS BEDROOM	PASS
MINI SOUNDER	1ST	610 CONGRESS UNIT 1 BEDROOM	PASS
MINI SOUNDER	1ST	610 CONGRESS UNIT 2 BEDROOM	PASS
HORN/STROBE	2ND	610 CONGRESS FRONT	PASS
HORN/STROBE	2ND	610 CONGRESS REAR	PASS
MINI SOUNDER	2ND	610 CONGRESS UNIT 3 BEDROOM	PASS
MINI SOUNDER	2ND	610 CONGRESS UNIT 4 BEDROOM	PASS
HORN/STROBE	3RD	610 CONGRESS FRONT HALL BY UNIT 5	PASS
HORN/STROBE	3RD	610 CONGRESS FRONT HALL BY UNIT 8	PASS
HORN/STROBE	3RD	610 CONGRESS REAR HALL	PASS
MINI SOUNDER	3RD	610 CONGRESS UNIT 5 BEDROOM	PASS
MINI SOUNDER	3RD	610 CONGRESS UNIT 6 BEDROOM	PASS
MINI SOUNDER	3RD	610 CONGRESS UNIT 7 BEDROOM	PASS
MINI SOUNDER	3RD	610 CONGRESS UNIT 8 BEDROOM	PASS
HORN/STROBE	4TH	610 CONGRESS FRONT HALL BY UNIT 9	PASS
HORN/STROBE	4TH	610 CONGRESS FRONT HALL BY UNIT 12	PASS
HORN/STROBE	4TH	610 CONGRESS REAR HALL	PASS
MINI SOUNDER	4TH	610 CONGRESS UNIT 9 BEDROOM	PASS
MINI SOUNDER	4TH	610 CONGRESS UNIT 10 BEDROOM	PASS
MINI SOUNDER	4TH	610 CONGRESS UNIT 11 BEDROOM	PASS
MINI SOUNDER	4TH	610 CONGRESS UNIT 12 BEDROOM	PASS