

SCANNED

Form # P 04

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK
CITY OF PORTLAND
BUILDING INSPECTION
PERMIT

Please Read
Application And
Notes, If Any,
Attached

Permit Number: 100974

PERMIT ISSUED

This is to certify that RICE GEOFFREY I / Freedom Fire Protection, Inc

has permission to install a Water-based fire suppression system

AT 600 CONGRESS ST

CBL 039 A013001

AUG 1 /

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statutes of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of buildings and structures, and of the application on file in this department.

Apply to Public Works for street line and grade if nature of work requires such information.

Notification of inspection must be given and written permission procured before this building or part thereof is lathed or otherwise closed-in. 24 HOUR NOTICE IS REQUIRED.

A certificate of occupancy must be procured by owner before this building or part thereof is occupied.

OTHER REQUIRED APPROVALS

Fire Dept. CAPT. R. [Signature]

Health Dept. _____

Appeal Board _____

Other _____

Department Name

Director - Building & Inspection Services

PENALTY FOR REMOVING THIS CARD

City of Portland, Maine - Building or Use Permit

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No: 10-0974	Date Applied For: 08/10/2010	CBL: 039 A013001
-----------------------	---------------------------------	---------------------

Location of Construction: 600 CONGRESS ST	Owner Name: RICE GEOFFREY I	Owner Address: 658 CONGRESS ST 1ST FLOOR	Phone:
Business Name:	Contractor Name: Freedom Fire Protection, Inc	Contractor Address: 209 Quaker Ridge Road Casco	Phone (207) 627-4109
Lessee/Buyer's Name	Phone:	Permit Type: Fire Suppression System	

Proposed Use: Commercial Mixed Use - install a Water-based fire suppression system	Proposed Project Description: install a Water-based fire suppression system
--	---

Dept: Zoning **Status:** Approved with Conditions **Reviewer:** Marge Schmuckal **Approval Date:** 08/12/2010
Note: **Ok to Issue:** ✓

- 1) ANY exterior work requires a separate review and approval thru Historic Preservation. This property is located within an Historic District.
- 2) This is NOT an approval for an additional dwelling unit. You SHALL NOT add any additional kitchen equipment including, but not limited to items such as stoves, microwaves, refrigerators, or kitchen sinks, etc. Without special approvals.
- 3) This property shall remain commercial use on first floor with 12 residential dwelling units above. Any change of use shall require a separate permit application for review and approval.
- 4) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.

Dept: Building **Status:** Approved with Conditions **Reviewer:** Tammy Munson **Approval Date:** 08/17/2010
Note: **Ok to Issue:** ✓

- 1) Sprinkler systems to be designed and installed per IBC 2003 standards Sec. 903.3.1

Dept: Fire **Status:** Approved with Conditions **Reviewer:** Capt Keith Gautreau **Approval Date:** 08/13/2010
Note: **Ok to Issue:** ✓

- 1) The Standpipe system shall be installed in accordance with NFPA 14. A signed compliance letter will be required.
- 2) Sprinkler protection shall be maintained. Where the system is to be shut down for maintenance or repair, the system shall be checked at the end of each day to insure the system has been placed back in service.
- 3) The Fire alarm and Sprinkler systems shall be reviewed by a licensed contractor[s] for code compliance. Compliance letters are required
- 4) The sprinkler system shall be installed in accordance with NFPA 13.
- 5) Application requires State Fire Marshal approval.
- 6) Fire department connection type and location shall be approved in writing by fire prevention bureau.
- 7) The Fire Department will require Knox locking caps on all Fire Department Connections on the exterior of the building.
- 8) System acceptance and commissioning must be co-ordinated with alarm and suppression system contractors and the Fire Department. Call 874-8703 to schedule.

PERMIT ISSUED

AUG 17 2010

City of Portland

BUILDING PERMIT INSPECTION PROCEDURES

Please call 874-8703 or 874-8693 (ONLY)

or email: buildinginspections@portlandmaine.gov

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the City of Portland Inspection Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.
- Permits expire in 6 months, if the project is not started or ceases for 6 months.
- If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue with construction.

 X Final inspection required at completion of work performed by the Fire Department.

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OR CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

PERMIT ISSUED

AUG 17 2010

City of Portland

mail

Freedom Fire Protection, Inc.

Over 30 Years of Fire Protection Experience
209 Quaker Ridge Rd. Casco, Maine 04015
Phone 207/627-4109 Fax 207/627-7340

August 9, 2010

Portland City Hall
Third Floor Room 315
Portland, Maine 04101

Attn: Captain Keith Gautreau

Ref: Rice Management Schwartz Building
602 Congress Street
Portland, Maine 04101

Subj: Fire Sprinkler Plan Review

Dear Captain Gautreau,

Enclosed please find for your review and comment the following sprinkler information.

- Fire Suppression System Permit.
- Permit Fee check.
- Freedom Fire Protections drawing FP1, FP2, FP3, FP4, Fp5 and FP6 dated 6/30/10.
- 1 set of 8-1/2 x 11 PDF sprinkler plans.
- Hydraulic Calculations Area Basement, 1st flr. & 4th flr.
- Copy of the State Marshall's sprinkler permit # 9163.

Please get in touch with me to discuss any question or if you need additional information.

Regards,



William Wales

(O) 207/627-4109

(F) 207/627-7340

(C) 207/671-8639

Email wwales@maine.rr.com



Water-Based Fire Suppression System Permit

If you or the property owner owes real estate or property taxes or user charges on any property within the city, payment arrangements must be made before permits of any kind are accepted.

Installation address: 602 Congress Street CBL: 39-A-13

Exact location: (within structure) Basement, First, Second, Third & Fourth levels.

Type of occupancy(s) (NFPA & ICC): Mixed - Mercantile & Apartment

Building owner: Geoffrey Rice (Rice Management)

Managing Supervisor (RMS): Timothy Vess License No: 348

Supervisor phone: 207/627-4109 E-mail: wwales@maine.rr.com

Installing contractor: Freedom Fire protection, Inc License No: 295

Contractor phone: 207/671-8639 E-mail: wwales@maine.rr.com

The suppression work to be done will be: New: Renovation: Addition to existing system:

This is an amendment to an existing permit: Yes: NO Permit no: _____

NFPA Standard this system is designed to: 13 & 13R Edition: 2007

*Non-NFPA systems are not approved for use within the City of Portland.

Download a new copy of this document from www.portlandmaine.gov/fire for every submittal. Attach all working documents and complete approved submittals as may be required by the State Fire Marshal's Office on electronic PDF's in addition to full sized plans.

Contractor shall verify location and type of all FDCs shall be approved in writing by the Fire Prevention Bureau.

COST OF WORK: 47,669.00
PERMIT FEE: 500.00
(\$10 PER \$1,000 + \$30 FOR THE FIRST \$1,000)

Submit all information to the Building Inspections Department, 389 Congress Street, Room 315, Portland, Maine 04101.

Prior to acceptance of any fire protection system, a complete commissioning and acceptance test must be coordinated with all fire system contractors and the Fire Department, and proper documentation of such test(s) provided.

All installation(s) must comply with NFPA and the Fire Department Technical Standard(s).

Applicant signature: William Wales Date: 8/4/10



State of Maine
Department of Public Safety



Fire Sprinkler System Permit

9163

Shwartz Building

Located at: 602 Congress Street
In the Town of: Portland
Occupancy/Use: Residential & Retail
Type of System: NFPA 13R

Permission is hereby given to:

Freedom Fire Protection, Inc.
209 Quaker Ridge Road
Casco, ME 04015
Contractor License # 295

according to plans submittal filed with the Licensing and Inspections Unit and are now approved. This application form/plans are filed under log # 2101260 , and no departure from application form/plans shall be made without prior approval in writing. This permit is issued under the provisions of Title 32, Chapter 20, Section 12004-I. Nothing herein shall excuse the holder of this permit for failure to comply with local ordinances, zoning laws, or other pertinent legal restrictions. Each permit issued shall be displayed/available at the site of construction.

This permit was issued on 7/28/2010 for a fee paid of \$180.00
This permit will expire at midnight on Monday, January 24, 2011

Anne H. Jordan
Commissioner

Fire Department Connection Location/Type per Local Fire Department




Within 30 days of the completion of a new fire sprinkler system or an addition to an existing fire sprinkler system, a fire sprinkler system contractor shall provide to the Licensing and Inspections Unit a copy of this permit signed and dated by the certified responsible managing supervisor representing that the fire sprinkler system has been installed according to specifications of the approved plan to the best of the supervisor's knowledge, information, and belief. This requirement is part of the sprinkler law, and neglect of this duty is grounds to not renew the contractor's license to do work in the State of Maine. All sprinkler licenses expire June 30th every year.

Job completed, tested and verified on date of _____

RMS for this job: Vess Timothy L.


RMS Signature: _____






SECOND FLOOR FIRE SPRINKLER PLAN

BOTTOM OF CONCRETE DECK = 10'-0" AFF
 (+)-0" DENOTES ELEVATION OF PIPING ABOVE FIN FLOOR
 (-)-0" DENOTES DISTANCE FROM BOTTOM OF DECK DOWN TO PIPING
 LINE HANGERS = TYPE #SBC (SEE DETAIL)
 MAIN HANGERS = TYPE #12 (SEE DETAIL)
 (H) DENOTES HYDRAULIC REFERENCE POINTS




Hanger No. 12
Concrete Insert

NO.	TYPE	SIZE	QTY
1	1/2"	1/2"	1
2	3/4"	3/4"	1
3	1"	1"	1
4	1 1/4"	1 1/4"	1
5	1 1/2"	1 1/2"	1
6	2"	2"	1
7	2 1/2"	2 1/2"	1
8	3"	3"	1
9	3 1/2"	3 1/2"	1
10	4"	4"	1
11	4 1/2"	4 1/2"	1
12	5"	5"	1
13	5 1/2"	5 1/2"	1
14	6"	6"	1
15	6 1/2"	6 1/2"	1
16	7"	7"	1
17	7 1/2"	7 1/2"	1
18	8"	8"	1
19	8 1/2"	8 1/2"	1
20	9"	9"	1
21	9 1/2"	9 1/2"	1
22	10"	10"	1
23	10 1/2"	10 1/2"	1
24	11"	11"	1
25	11 1/2"	11 1/2"	1
26	12"	12"	1
27	12 1/2"	12 1/2"	1
28	13"	13"	1
29	13 1/2"	13 1/2"	1
30	14"	14"	1
31	14 1/2"	14 1/2"	1
32	15"	15"	1
33	15 1/2"	15 1/2"	1
34	16"	16"	1
35	16 1/2"	16 1/2"	1
36	17"	17"	1
37	17 1/2"	17 1/2"	1
38	18"	18"	1
39	18 1/2"	18 1/2"	1
40	19"	19"	1
41	19 1/2"	19 1/2"	1
42	20"	20"	1
43	20 1/2"	20 1/2"	1
44	21"	21"	1
45	21 1/2"	21 1/2"	1
46	22"	22"	1
47	22 1/2"	22 1/2"	1
48	23"	23"	1
49	23 1/2"	23 1/2"	1
50	24"	24"	1
51	24 1/2"	24 1/2"	1
52	25"	25"	1
53	25 1/2"	25 1/2"	1
54	26"	26"	1
55	26 1/2"	26 1/2"	1
56	27"	27"	1
57	27 1/2"	27 1/2"	1
58	28"	28"	1
59	28 1/2"	28 1/2"	1
60	29"	29"	1
61	29 1/2"	29 1/2"	1
62	30"	30"	1
63	30 1/2"	30 1/2"	1
64	31"	31"	1
65	31 1/2"	31 1/2"	1
66	32"	32"	1
67	32 1/2"	32 1/2"	1
68	33"	33"	1
69	33 1/2"	33 1/2"	1
70	34"	34"	1
71	34 1/2"	34 1/2"	1
72	35"	35"	1
73	35 1/2"	35 1/2"	1
74	36"	36"	1
75	36 1/2"	36 1/2"	1
76	37"	37"	1
77	37 1/2"	37 1/2"	1
78	38"	38"	1
79	38 1/2"	38 1/2"	1
80	39"	39"	1
81	39 1/2"	39 1/2"	1
82	40"	40"	1
83	40 1/2"	40 1/2"	1
84	41"	41"	1
85	41 1/2"	41 1/2"	1
86	42"	42"	1
87	42 1/2"	42 1/2"	1
88	43"	43"	1
89	43 1/2"	43 1/2"	1
90	44"	44"	1
91	44 1/2"	44 1/2"	1
92	45"	45"	1
93	45 1/2"	45 1/2"	1
94	46"	46"	1
95	46 1/2"	46 1/2"	1
96	47"	47"	1
97	47 1/2"	47 1/2"	1
98	48"	48"	1
99	48 1/2"	48 1/2"	1
100	49"	49"	1
101	49 1/2"	49 1/2"	1
102	50"	50"	1
103	50 1/2"	50 1/2"	1
104	51"	51"	1
105	51 1/2"	51 1/2"	1
106	52"	52"	1
107	52 1/2"	52 1/2"	1
108	53"	53"	1
109	53 1/2"	53 1/2"	1
110	54"	54"	1
111	54 1/2"	54 1/2"	1
112	55"	55"	1
113	55 1/2"	55 1/2"	1
114	56"	56"	1
115	56 1/2"	56 1/2"	1
116	57"	57"	1
117	57 1/2"	57 1/2"	1
118	58"	58"	1
119	58 1/2"	58 1/2"	1
120	59"	59"	1
121	59 1/2"	59 1/2"	1
122	60"	60"	1
123	60 1/2"	60 1/2"	1
124	61"	61"	1
125	61 1/2"	61 1/2"	1
126	62"	62"	1
127	62 1/2"	62 1/2"	1
128	63"	63"	1
129	63 1/2"	63 1/2"	1
130	64"	64"	1
131	64 1/2"	64 1/2"	1
132	65"	65"	1
133	65 1/2"	65 1/2"	1
134	66"	66"	1
135	66 1/2"	66 1/2"	1
136	67"	67"	1
137	67 1/2"	67 1/2"	1
138	68"	68"	1
139	68 1/2"	68 1/2"	1
140	69"	69"	1
141	69 1/2"	69 1/2"	1
142	70"	70"	1
143	70 1/2"	70 1/2"	1
144	71"	71"	1
145	71 1/2"	71 1/2"	1
146	72"	72"	1
147	72 1/2"	72 1/2"	1
148	73"	73"	1
149	73 1/2"	73 1/2"	1
150	74"	74"	1
151	74 1/2"	74 1/2"	1
152	75"	75"	1
153	75 1/2"	75 1/2"	1
154	76"	76"	1
155	76 1/2"	76 1/2"	1
156	77"	77"	1
157	77 1/2"	77 1/2"	1
158	78"	78"	1
159	78 1/2"	78 1/2"	1
160	79"	79"	1
161	79 1/2"	79 1/2"	1
162	80"	80"	1
163	80 1/2"	80 1/2"	1
164	81"	81"	1
165	81 1/2"	81 1/2"	1
166	82"	82"	1
167	82 1/2"	82 1/2"	1
168	83"	83"	1
169	83 1/2"	83 1/2"	1
170	84"	84"	1
171	84 1/2"	84 1/2"	1
172	85"	85"	1
173	85 1/2"	85 1/2"	1
174	86"	86"	1
175	86 1/2"	86 1/2"	1
176	87"	87"	1
177	87 1/2"	87 1/2"	1
178	88"	88"	1
179	88 1/2"	88 1/2"	1
180	89"	89"	1
181	89 1/2"	89 1/2"	1
182	90"	90"	1
183	90 1/2"	90 1/2"	1
184	91"	91"	1
185	91 1/2"	91 1/2"	1
186	92"	92"	1
187	92 1/2"	92 1/2"	1
188	93"	93"	1
189	93 1/2"	93 1/2"	1
190	94"	94"	1
191	94 1/2"	94 1/2"	1
192	95"	95"	1
193	95 1/2"	95 1/2"	1
194	96"	96"	1
195	96 1/2"	96 1/2"	1
196	97"	97"	1
197	97 1/2"	97 1/2"	1
198	98"	98"	1
199	98 1/2"	98 1/2"	1
200	99"	99"	1
201	99 1/2"	99 1/2"	1
202	100"	100"	1
203	100 1/2"	100 1/2"	1
204	101"	101"	1
205	101 1/2"	101 1/2"	1
206	102"	102"	1
207	102 1/2"	102 1/2"	1
208	103"	103"	1
209	103 1/2"	103 1/2"	1
210	104"	104"	1
211	104 1/2"	104 1/2"	1
212	105"	105"	1
213	105 1/2"	105 1/2"	1
214	106"	106"	1
215	106 1/2"	106 1/2"	1
216	107"	107"	1
217	107 1/2"	107 1/2"	1
218	108"	108"	1
219	108 1/2"	108 1/2"	1
220	109"	109"	1
221	109 1/2"	109 1/2"	1
222	110"	110"	1
223	110 1/2"	110 1/2"	1
224	111"	111"	1
225	111 1/2"	111 1/2"	1
226	112"	112"	1
227	112 1/2"	112 1/2"	1
228	113"	113"	1
229	113 1/2"	113 1/2"	1
230	114"	114"	1
231	114 1/2"	114 1/2"	1
232	115"	115"	1
233	115 1/2"	115 1/2"	1
234	116"	116"	1
235	116 1/2"	116 1/2"	1
236	117"	117"	1
237	117 1/2"	117 1/2"	1
238	118"	118"	1
239	118 1/2"	118 1/2"	1
240	119"	119"	1
241	119 1/2"	119 1/2"	1
242	120"	120"	1
243	120 1/2"	120 1/2"	1
244	121"	121"	1
245	121 1/2"	121 1/2"	1
246	122"	122"	1
247	122 1/2"	122 1/2"	1
248	123"	123"	1
249	123 1/2"	123 1/2"	1
250	124"	124"	1
251	124 1/2"	124 1/2"	1
252	125"	125"	1
253	125 1/2"	125 1/2"	1
254	126"	126"	1
255	126 1/2"	126 1/2"	1
256	127"	127"	1
257	127 1/2"	127 1/2"	1
258	128"	128"	1
259	128 1/2"	128 1/2"	1
260	129"	129"	1
261	129 1/2"	129 1/2"	1
262	130"	130"	1
263	130 1/2"	130 1/2"	1
264	131"	131"	1
265	131 1/2"	131 1/2"	1
266	132"	132"	1
267	132 1/2"	132 1/2"	1
268	133"	133"	1
269	133 1/2"	133 1/2"	1
270	134"	134"	1
271	134 1/2"	134 1/2"	1
272	135"	13	



TYPICAL SIDEWALL EXPOSED





TYPICAL SIDEWALL SEMI RECESSED




THIRD FLOOR FIRE SPRINKLER PLAN

BOTTOM OF CONCRETE DECK = 9'-5" AFF
 C-W-O DENOTES ELEVATION OF PIPING ABOVE FIN FLOOR
 C-0'-0" DENOTES DISTANCE FROM BOTTOM OF DECK DOWN TO PIPING
 LINE HANGERS= TYPE #SBC (SEE DETAIL)
 MAIN HANGERS= TYPE #12 (SEE DETAIL)
 (9) DENOTES HYDRAULIC REFERENCE POINTS



THIRD FLOOR ZONE CONTROL DETAIL
SCALE 1/2" = 1'-0"




NOTE ON PLAN: 1" DIMENSION
 PIPE SIZE 1" THROUGH 4" - ROD SIZE 3/16"
 PIPE SIZE 1" THROUGH 4" - ROD SIZE 1/8"



REVISIONS	NOTES	MAX HEAD SPACING	HEAD COUNT				STANDARD SYMBOLS		STANDARD SYMBOLS		INSPECTIONS								
NO.			SPRINKLER TYPE	K	WPL	SEC.	WALL	FINISH	OFFICE	TEMP.	SYMBOL	QUANT.							
1	7-22-18		RES. DEF.	0.5	TRSD	NON-RES.	1/2"	DRINKS	7/2"	18F	4E	21							
TOTAL SPRINKLER THIS TIER/FLOOR																			


SHWARTZ BUILDING
 602 CONGRESS STREET
 PORTLAND MAINE
3RD FLOOR FIRE SPRINKLER PLAN
FREEDOM FIRE PROTECTION, INC.
 209 QUAKER RIDGE ROAD
 CASCO, MAINE 04015
 (207)627-4109

JOB NO. 00008
 DATE 8-28-18
 DRAWN BY TEP
 SCALE 3/4" = 1'-0"
 SHEET NO. FP-5




Congress Street Elevation

NFPA 13R		
HYDRAULIC DESIGN		
SYSTEM	WET	AREA 4TH FLOOR
SPRINKLER CALCULATOR		4 HEADS
DESIGN PRESSURE		35 GPM
DESIGN FLOW		4 HDS
HOSE ALLOWANCE		100 GPM
DESIGN PRESSURE		71.2 GPM
DESIGN PRESSURE		65.6 PSI
SAFETY FACTOR		5.05 PSI




FOURTH FLOOR FIRE SPRINKLER PLAN


BOTTOM OF WOOD CEILING TRUSSES= 9'-0" AFF
 C-10-0 DENOTES ELEVATION OF PIPING ABOVE FIN FLOOR
 (-0'-0") DENOTES DISTANCE FROM BOTTOM OF DECK DOWN TO PIPING
 LINE HANGERS= TYPE #SBW (SEE DETAIL)
 MAIN HANGERS= TYPE #SBW (SEE DETAIL)
 (C) DENOTES HYDRAULIC REFERENCE POINTS




TYPICAL SIDEWALL EXPOSED



TYPICAL "SBW" HANGER



TYPICAL SIDEWALL SEMI RECESSED



FOURTH FLOOR ZONE CONTROL DETAIL SCALE 1/8"

REVISIONS	NOTES	MAX HEAD SPACING	SPRINKLER TYPE	K	WPL	ESC.	W/CSL	FRNH	ORANGE	TEMP	SPRINKL	SHUNT
1			SBW	100	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5

SHWARTZ BUILDING
 802 CONGRESS STREET
 PORTLAND MAINE
4TH FLOOR FIRE SPRINKLER PLAN
FREEDOM FIRE PROTECTION, INC.
 208 QUAKER RIDGE ROAD
 CASCO, MAINE 04015
 (207) 687-4109

JOB NO.	DATE	SCALE
DRAWN BY	DATE	SCALE
CHECKED BY	DATE	SCALE
SHEET NO.	FP-6	



CITY OF PORTLAND, MAINE
Department of Building Inspections

Original Receipt

8-10 20 10

Received from Freedom Fire Protection

Location of Work 600 Congress

Cost of Construction \$ _____ Building Fee: _____

Permit Fee \$ _____ Site Fee: _____

Certificate of Occupancy Fee: _____

Total: 500

Building (I1) Plumbing (I5) Electrical (I2) Site Plan (U2)

Other Fire Water Based

CBL: 39-A-13

Check #: 14967 Total Collected \$ 500

**No work is to be started until permit issued.
Please keep original receipt for your records.**

Taken by: [Signature]

WHITE - Applicant's Copy
YELLOW - Office Copy
PINK - Permit Copy

Hydraulics Summary Sheet

**FREEDOM FIRE PROTECTION
209 QUAKER RIDGE ROAD
CASCO, MAINE**

Designer: DON UESS
Calc By: DON UESS
Date: 7-27-10

Project Information

**SHWARTZ BUILDING
602 CONGRESS STREET
PORTLAND, MAINE**

Contract No:
Building: EXIST
System ID: BASEMENT HYD REMOTE AREA
Ref. Drawing No: FP-2
Construction: CONC
Occupancy: BASEMENT
Authority: NFPA 13

System Information

Hydraulics Design Criteria
System Type: WET
Density: .15 GPM/SqFt
Remote Area: 1000 SqFt
Sprinkler Coverage: 110 SqFt
Design Standard: NFPA 13
Hazard: ORDINARY GP 1
Figure: 11.2.3.1.1 Curve:
Sprinklers / Nozzles
Manufacturer: TYCO
Model: TYFRB
Size: 1/2
K-Factor: 5.6
Temp. Rating: 155

Hydraulics Information

Demand...

Spr Req'd Pres: 56.78 PSI
Spr Req'd Flow: 238.48 GPM
Add'l Flows: 250.00 GPM
Hose at Srce: 0.00 GPM
Total Flow: 488.48 GPM
Total Pres: 57.61 PSI
Static Elev: 0.00 Ft

Supply...

Water Flow Test
Static: 71.00 PSI
Residual: 62.00 PSI
Qty Flowing: 992.00 GPM
Elevation: 0.00 Ft

Date: Time:
By:

Pump Data
Rated: 0.0 PSIE 0.0 GPM
Boost Pres: (NA) PSI
Discharge Pres: (NA) PSI
Discharge Flow: (NA) GPM

Combined
Static: (NA) PSI
Residual: (NA) PSI
Qty Flowing: (NA) GPM

Available...


P) 68.57 PSIE 488.48 GPM
F) 57.61 PSIE 1229.47 GPM

Margin...

Pressure: 10.97 PSI
Flow: 740.99 GPM

BASEMENT HYD REMOTE AREA

Sigma Dynamics Corporation
7700 Supply / Demand Graph



N 1.85

SUBMITTAL SERIAL NO:2933HY2
 BASEMENT HYD REMOTE AREA
 SHWARTZ BUILDING
 .15 GPM OVER 1000 SQ FT
 REDUCED AREA FOR QR HDS

07-27-2010 PAGE 3

Location From To	Flow in GPM	Pipe Size IN	Fittings & Devices	Equiv Length Ft	Friction Loss PSI/Ft	Pressure Summary PSI	
111 112		1.104		L 11.00	C=120	PT 10.43	(112)
Q	18.09		F=2E	F 4.00		PE 0.00	
		BN		T 15.00	0.0842	PF 1.26	
110 111DQ	19.15	1.452		L 8.50	C=120	PT 11.69	(111)
Q	37.24		F=0	F 0.00		PE 0.00	
		BN		T 8.50	0.0844	PF 0.72	
101 110DQ	19.73	1.452		L 4.00	C=120	PT 12.41	(110)
Q	56.96		F=T	F 6.00		PE 0.00	
		BN		T 10.00	0.1852	PF 1.85	
						PT 14.26	(101)
102 103		2.157		L 8.00	C=120	PT 11.79	(103)
Q	87.73		F=0	F 0.00		PE 0.00	
		FM		T 8.00	0.0599	PF 0.48	
101 102DQ	73.65	2.157		L 9.00	C=120	PT 12.27	(102)
Q	161.38		F=EE	F 1.80		PE 0.00	
		FM		T 10.80	0.1851	PF 2.00	
100 101DQ	77.10	2.157		L 2.50	C=120	PT 14.27	(101)
Q	238.48		F=T	F 8.50		PE 0.00	
		FM		T 11.00	0.3811	PF 4.19	
99 100		2.157		L 36.00	C=120	PT 18.46	(100)
Q	238.48		F=T	F 8.50		PE 0.00	
		FM		T 44.50	0.3811	PF 16.96	
7 99		2.154		L 9.00	C=120	PT 35.42	(99)
Q	238.48		F=T, BV, 2E	F 26.00		PE 0.43	
		FM		T 35.00	0.3837	PF 13.43	
6 7		4.260		L 2.00	C=120	PT 49.28	(7)
Q	238.48		F=T	F 16.00		PE -0.87	
		FR		T 18.00	0.0139	PF 0.25	
5 6		4.260		L 28.00	C=120	PT 48.66	(6)
Q	238.48		F=2E, BV	F 25.60		PE 0.00	
		FM		T 53.60	0.0139	PF 0.75	
4 5		4.260		L 7.00	C=120	PT 49.41	(5)
Q	238.48		F=CV	F 22.00		PE 2.60	
		FR		T 29.00	0.0139	PF 0.40	

Hydraulics Summary Sheet

FREEDOM FIRE PROTECTION
209 QUAKER RIDGE ROAD
CASCO, MAINE

Designer: DON UESS
Calc By: DON UESS
Date: 7-27-10

Project Information

SHWARTZ BUILDING
802 CONGRESS STREET
PORTLAND, MAINE

Contract No:
Building: EXIST
System ID: 1ST FLOOR RETAIL REMOTE AREA
Ref. Drawing No: FP=3

Construction: CONC
Occupancy: RETAIL

Authority: NFPA 13

System Information

Hydraulics Design Criteria

System Type: WET
Density: .20 GPM/SqFt
Remote Area: 1000 SqFt
Sprinkler Coverage: 100 SqFt
Design Standard: NFPA 13
Hazard: ORDINARY GP 2
Figure: 11.2.3.1.1 Curve:

Sprinklers / Nozzles

Manufacturer: TYCO
Model: TYFRB
Size: 1/2
K-Factor: 5.6
Temp. Rating: 155

Hydraulics Information

Demand...

Spr Req'd Pres: 63.76 PSI
Spr Req'd Flow: 256.82 GPM
Add'l Flows: 250.00 GPM
Hose at Srce: 0.00 GPM
Total Flow: 506.82 GPM
Total Pres: 64.62 PSI
Static Elev: 0.00 Ft

Supply...

Water Flow Test

Static: 71.00 PSI
Residual: 62.00 PSI
Qty Flowing: 992.00 GPM
Elevation: 0.00 Ft

Date: Time:

By:

Pump Data

Rated: 0.0 PSIE @ 0.0 GPM
Boost Pres: (NA) PSI
Discharge Pres: (NA) PSI
Discharge Flow: (NA) GPM

Combined

Static: (NA) PSI
Residual: (NA) PSI
Qty Flowing: (NA) GPM

Available...


P) 68.40 PSIE @ 506.82 GPM
F) 64.62 PSIE @ 823.72 GPM

Margin...

Pressure: 3.78 PSI
Flow: 316.91 GPM

1ST FLOOR RETAIL REMOTE AREA

Sigma Dynamics Corporation
7700 Supply / Demand Graph



System Demand..

Sprinkler Demand 63.76 PSI @ 256.82 GPM
 Additional Flows 250.00 GPM
 Hose at Source 0.00 GPM
 Total Demand 64.62 PSI @ 506.92 GPM

Water Supply..

Static 71.00 PSI
 Residual 62.00 PSI @ 992.00 GPM
 Elevation 0.00 PSI

SUBMITTAL SERIAL NO:2933HY2
 1ST FLOOR RETAIL REMOTE AREA
 SHWARTZ BUILDING
 .20 GPM OVER 1000 SQ FT
 REDUCED AREA FOR QR HDS

FLOW TEST RESULTS

Water Supply

STATIC 71.00 PSI
 RESIDUAL 62.00 PSI @ 992.00 GPM

CITY PRESSURE AVAILABLE AT 506.8 GPM 68.40 PSI

SUMMARY OF SPRINKLER OUTFLOWS

SPR	ACTUAL FLOW	MINIMUM FLOW	K-FACTOR	PRESSURE
210	23.39	20.00	5.60	17.44
211	23.39	20.00	5.60	17.44
212	22.40	20.00	5.60	16.00
213	21.35	20.00	5.60	14.53
214	20.12	20.00	5.60	12.90
215	20.00	20.00	5.60	12.76
216	20.12	20.00	5.60	12.90
217	20.00	20.00	5.60	12.76
218	21.20	20.00	5.60	14.33
219	21.31	20.00	5.60	14.48
220	21.56	20.00	5.60	14.83
221	21.99	20.00	5.60	15.42

TOTAL WATER REQUIRED FOR SYSTEM 256.82 GPM
 OUTFLOWS AT 1 250.00 GPM
 TOTAL WATER REQUIREMENT 506.82 GPM
 PRESSURE REQUIRED AT 0 64.62 PSI

MAXIMUM PRESSURE UNBALANCE IN LOOPS 0.00 PSI
 MAXIMUM VELOCITY FROM 8 TO 200 15.11 FPS

SUBMITTAL SERIAL NO:2933HY2
 1ST FLOOR RETAIL REMOTE AREA
 SHWARTZ BUILDING
 .20 GPM OVER 1000 SQ FT
 REDUCED AREA FOR QR HDS

07-27-2010 PAGE 2

Location From To	Flow in GPM	Pipe Size IN	Fittings & Devices	Equiv Length Ft	Friction Loss PSI/Ft	Pressure Summary PSI	
207 217 Q 20.00	20.00	1.104 BN	F=T	L 1.00	C=120	PT 12.76 (217)	
				F 5.00		PE 0.00	
				T 6.00	0.1015	PF 0.61	PT 13.37 (207)

206 216 Q 20.12	20.12	1.104 BN	F=T	L 1.00	C=120	PT 12.90 (216)	
				F 5.00		PE 0.00	
				T 6.00	0.1025	PF 0.61	PT 13.51 (206)

207 215 Q 20.00	20.00	1.104 BN	F=T	L 1.00	C=120	PT 12.76 (215)	
				F 5.00		PE 0.00	
				T 6.00	0.1015	PF 0.61	PT 13.37 (207)

206 214 Q 20.12	20.12	1.104 BN	F=T	L 1.00	C=120	PT 12.90 (214)	
				F 5.00		PE 0.00	
				T 6.00	0.1025	PF 0.61	PT 13.51 (206)

204 211 Q 23.39	23.39	1.104 BN	F=T	L 1.00	C=120	PT 17.44 (211)	
				F 5.00		PE 0.00	
				T 6.00	0.1355	PF 0.81	PT 18.25 (204)

203 210 Q 23.39	23.39	1.104 BN	F=T	L 1.00	C=120	PT 17.44 (210)	
				F 5.00		PE 0.00	
				T 6.00	0.1355	PF 0.81	PT 18.25 (203)

208 204 Q 23.03	23.03	2.157 CM	F=0	L 8.00	C=120	PT 18.26 (204)	
				F 0.00		PE 0.00	
				T 8.00	0.0050	PF 0.04	

201 208DQ Q 104.92 127.95	104.92 127.95	2.157 CM	F=T, 3E	L 23.00	C=120	PT 18.30 (208)	
				F 19.00		PE 0.00	
				T 42.00	0.1205	PF 5.06	PT 23.36 (201)

213 205 Q 61.17	61.17	2.157 CM	F=0	L 9.00	C=120	PT 14.25 (205)	
				F 0.00		PE 0.00	
				T 9.00	0.0308	PF 0.28	

212 213DQ Q 21.35 82.51	21.35 82.51	2.157 CM	F=3E	L 17.00	C=120	PT 14.53 (213)	
				F 10.50		PE 0.00	
				T 27.50	0.0535	PF 1.47	

SUBMITTAL SERIAL NO:2933HY2
 1ST FLOOR RETAIL REMOTE AREA
 SHWARTZ BUILDING
 .20 GPM OVER 1000 SQ FT
 REDUCED AREA FOR QR HDS

07-27-2010 PAGE 3

Location From To	Flow in GPM	Pipe Size IN	Fittings & Devices	Equiv Length Ft	Friction Loss PSI/Ft	Pressure Summary PSI
208 212DQ Q	22.40 104.92	2.157 CM	F=T, 2E	L 12.00 F 15.50 T 27.50	C=120 0.0834	PT 16.00 (212) PE 0.00 PF 2.29 PT 18.29 (208)
218 205 Q	19.06	2.157 CM	F=E	L 17.00 F 3.50 T 20.50	C=120 0.0036	PT 14.25 (205) PE 0.00 PF 0.07
219 218DQ Q	21.20 40.26	2.157 CM	F=0	L 11.00 F 0.00 T 11.00	C=120 0.0142	PT 14.32 (218) PE 0.00 PF 0.16
220 219DQ Q	21.31 61.57	2.157 CM	F=0	L 11.00 F 0.00 T 11.00	C=120 0.0311	PT 14.48 (219) PE 0.00 PF 0.34
221 220DQ Q	21.56 83.13	2.157 CM	F=0	L 11.00 F 0.00 T 11.00	C=120 0.0542	PT 14.82 (220) PE 0.00 PF 0.60
202 221DQ Q	21.99 105.13	2.157 CM	F=T, E	L 24.00 F 12.00 T 36.00	C=120 0.0837	PT 15.42 (221) PE 0.00 PF 3.01 PT 18.43 (202)
203 204 Q	0.35	2.157 CM	F=0	L 10.00 F 0.00 T 10.00	C=120 0.0000	PT 18.26 (204) PE 0.00 PF 0.00
202 203DQ Q	23.39 23.74	2.157 CM	F=T, EE, E	L 20.00 F 13.80 T 33.80	C=120 0.0053	PT 18.26 (203) PE 0.00 PF 0.18
201 202DQ Q	105.13 128.87	2.157 CM	F=T, EE	L 30.00 F 10.30 T 40.30	C=120 0.1221	PT 18.44 (202) PE 0.00 PF 4.92
200 201DQ Q	127.95 256.82	2.635 FM	F=2T, 4E	L 56.00 F 38.80 T 94.80	C=120 0.1649	PT 23.36 (201) PE 0.00 PF 15.63
8 200 Q	256.82	2.635 FM	F=2T, BV, 2E	L 30.00 F 37.20 T 67.20	C=120 0.1649	PT 38.99 (200) PE 0.43 PF 11.08

Hydraulics Summary Sheet

**FREEDOM FIRE PROTECTION
209 QUAKER RIDGE ROAD
CASCO, MAINE**

Designer: DON UESS
Calc By: DON UESS
Date: 7-27-10

Project Information

**SHWARTZ BUILDING
602 CONGRESS STREET
PORTLAND, MAINE**

Contract No:
Building: EXIST
System ID: 4TH FLOOR HYD REMOTE AREA
Ref. Drawing No: FP-6

Construction: WOOD TRUSS
Occupancy: RESIDENTIAL

Authority: NFPA 13R

Hydraulics Information

Demand...

Spr Req'd Pres: 65.47 PSI
Spr Req'd Flow: 71.23 GPM
Add'l Flows: 100.00 GPM
Hose at Srce: 0.00 GPM
Total Flow: 171.23 GPM
Total Pres: 65.60 PSI
Static Elev: 0.00 Ft

Supply...

Water Flow Test

Static: 71.00 PSI
Residual: 62.00 PSI
Qty Flowing: 992.00 GPM
Elevation: 0.00 Ft
Date: Time:
By:

Pump Data

Rated: 0.0 PSI @ 0.0 GPM
Boost Pres: (NA) PSI
Discharge Pres: (NA) PSI
Discharge Flow: (NA) GPM

Combined

Static: (NA) PSI
Residual: (NA) PSI
Qty Flowing: (NA) GPM

Available...

P) 70.65 PSI @ 171.23 GPM
F) 65.60 PSI @ 752.53 GPM

Margin...

Pressure: 5.05 PSI
Flow: 581.30 GPM

System Information

Hydraulics Design Criteria


System Type: WET
Density: .05 GPM/SqFt
Remote Area: 4HDS SqFt
Sprinkler Coverage: 256 SqFt
Design Standard: NFPA 13R
Hazard: RESIDENTIAL
Figure: Curve:

Sprinklers / Nozzles

Manufacturer: TYCO
Model: RES HSW LF-11
Size: 7/16
K-Factor: 4.2
Temp. Rating: 155

4TH FLOOR HYD REMOTE AREA

Signa Dynamics Corporation
7700 Supply / Demand Graph



System Demand..

Sprinkler Demand 65.47 PSI @ 71.23 GPM
 Additional Flows 100.00 GPM
 Hose at Source 0.00 GPM
 Total Demand 65.60 PSI @ 171.23 GPM

Water Supply..

Static 71.00 PSI
 Residual 62.00 PSI @ 992.00 GPM
 Elevation 0.00 PSI

SUBMITTAL SERIAL NO:2933HY2
4TH FLOOR HYD REMOTE AREA
SHWARTZ BUILDING
NFPA 13R 4 HDS FLOWING
4 HDS FLOWING 16 GPM

07-27-2010 PAGE 1

FLOW TEST RESULTS

Water Supply

STATIC 71.00 PSI
RESIDUAL 62.00 PSI @ 992.00 GPM

CITY PRESSURE AVAILABLE AT 171.2 GPM 70.65 PSI

SUMMARY OF SPRINKLER OUTFLOWS

SPR	ACTUAL FLOW	MINIMUM FLOW	K-FACTOR	PRESSURE
---	----	----	-----	-----
502	20.25	16.00	4.20	23.24
503	18.43	16.00	4.20	19.27
504	16.55	16.00	4.20	15.52
505	16.00	16.00	4.20	14.51

TOTAL WATER REQUIRED FOR SYSTEM 71.23 GPM
OUTFLOWS AT 1 100.00 GPM
TOTAL WATER REQUIREMENT 171.23 GPM
PRESSURE REQUIRED AT 0 65.60 PSI

MAXIMUM PRESSURE UNBALANCE IN LOOPS 0.00 PSI
MAXIMUM VELOCITY FROM 500 TO 501 13.80 FPS

SUBMITTAL SERIAL NO:2933HY2
 4TH FLOOR HYD REMOTE AREA
 SHWARTZ BUILDING
 NFPA 13R 4 HDS FLOWING
 4 HDS FLOWING 16 GPM

07-27-2010 PAGE 2




Location From To	Flow in GPM	Pipe Size IN	Fittings & Devices	Equip Length Ft	Friction Loss PSI/Ft	Pressure Summary PSI
504 505 Q	16.00	1.104 BN	F=0	L 15.00 F 0.00 T 15.00	C=120 0.0671	PT 14.51 (505) PE 0.00 PF 1.01
503 504DQ Q	16.55 32.55	1.104 BN	F=0	L 15.00 F 0.00 T 15.00	C=120 0.2498	PT 15.52 (504) PE 0.00 PF 3.75
501 503DQ Q	18.43 50.98	1.452 BN	F=T, E	L 19.00 F 9.00 T 28.00	C=120 0.1509	PT 19.27 (503) PE 0.00 PF 4.23 PT 23.50 (501)

501 502 Q	20.25	1.452 BN	F=T	L 3.00 F 6.00 T 9.00	C=120 0.0273	PT 23.24 (502) PE 0.00 PF 0.25
500 501DQ Q	50.98 71.23	1.452 FM	F=T, 3EE	L 42.00 F 9.00 T 51.00	C=120 0.2801	PT 23.49 (501) PE 0.00 PF 14.29
13 500 Q	71.23	1.687 FM	F=T	L 9.00 F 8.00 T 17.00	C=120 0.1349	PT 37.78 (500) PE 0.00 PF 2.29
12 13 Q	71.23	1.687 FM	F=T	L 17.00 F 8.00 T 25.00	C=120 0.1349	PT 40.07 (13) PE 0.00 PF 3.37
11 12 Q	71.23	1.687 FM	F=T, BV, 2E	L 6.00 F 16.00 T 22.00	C=120 0.1349	PT 43.44 (12) PE 0.43 PF 2.97
10 11 Q	71.23	4.260 FR	F=0	L 8.00 F 0.00 T 8.00	C=120 0.0015	PT 46.84 (11) PE 3.03 PF 0.01
9 10 Q	71.23	4.260 FR	F=0	L 9.00 F 0.00 T 9.00	C=120 0.0015	PT 49.88 (10) PE 3.47 PF 0.01
8 9 Q	71.23	4.260 FR	F=0	L 10.00 F 0.00 T 10.00	C=120 0.0015	PT 53.36 (9) PE 0.00 PF 0.02

SUBMITTAL SERIAL NO:2933HY2
 4TH FLOOR HYD REMOTE AREA
 SHWARTZ BUILDING
 NFPA 13R 4 HDS FLOWING
 4 HDS FLOWING 16 GPM

07-27-2010 PAGE 3



Location From To	Flow in GPM	Pipe Size IN	Fittings & Devices	Equip Length Ft	Friction Loss PSI/Ft	Pressure Summary PSI		
6 8	71.23	4.260	F=T	L 12.00 F 16.00 T 28.00	C=120	PT 53.38 PE 4.33 PF 0.04	(8)	
5 6	71.23	4.260	F=2E,BV	L 28.00 F 25.60 T 53.60	C=120	PT 57.75 PE 0.00 PF 0.08	(6)	
4 5	71.23	4.260	F=CV	L 7.00 F 22.00 T 29.00	C=120	PT 57.83 PE 2.60 PF 0.04	(5)	
3 4	71.23	4.026	F=2E,DCA	L 8.00 F 20.00 T 28.00	C=120	PT 60.47 PE -1.30 PF 0.06	(4)	
		4" Ames Mod. 2000ss - Double Check Valve Assembly					2.95	
2 3	71.23	6.340	F=T,GV	L 15.00 F 44.00 T 59.00	C=140	PT 62.18 PE 0.00 PF 0.01	(3)	
1 2	71.23	14.580	F=T,EE	L 100.00 F 117.00 T 217.00	C=140	PT 62.19 PE 0.43 PF 0.00	(2)	
0 1DQ	100.00	8.450	F=T,EE	L 750.00 F 58.60 T 808.60	C=140	PT 62.62 PE 2.82 PF 0.16	(1)	
0 Q	171.23	UN				PT 65.60 PF 0.16	(0)	




1/2" STAMPED RISER
1/2" FLOW SV. VA
1/2" TEST & DRAIN VA
1/2" 2 1/2" FLOW @ 5'-0" AFF

SECOND FLOOR FIRE SPRINKLER PLAN

BOTTOM OF CONCRETE DECK = 10'-0" AFF
E=+0 DENOTES ELEVATION OF PIPING ABOVE FIN FLOOR
(-0'-0") DENOTES DISTANCE FROM BOTTOM OF DECK DOWN TO PIPING
LINE HANGERS= TYPE #SBC (SEE DETAIL)
MAIN HANGERS= TYPE #12 (SEE DETAIL)
⊙ DENOTES HYDRAULIC REFERENCE POINTS




SECOND FLOOR ZONE CONTROL DETAIL
SCALE: 1/4" = 1'-0"




REVISIONS	NOTES	MAX HEAD BRANCH	SPRINKLER PIPING (S.P.)	PIPE	CONNECTION	VALVE	DRIVER	TEST	STAMP	GRADE
NO.	DATE	BY	TYPE	SIZE	TYPE	TYPE	TYPE	TYPE	TYPE	TYPE

STANDARD SYMBOLS	STANDARD SYMBOLS
<ul style="list-style-type: none"> Flow direction valve Flow valve Flow stop Flow stop connection Flow stop valve Flow stop valve Flow stop valve Flow stop valve Flow stop valve Flow stop valve 	<ul style="list-style-type: none"> Flow stop valve Flow stop valve Flow stop valve Flow stop valve Flow stop valve Flow stop valve Flow stop valve Flow stop valve Flow stop valve Flow stop valve




SHWARTZ BUILDING
602 CONGRESS STREET
PORTLAND MAINE
SECOND FLOOR FIRE SPRINKLER PLAN
FREEDOM FIRE PROTECTION, INC.
208 QUAKER RIDGE ROAD
CASCO, MAINE 04015
(807) 827-4100

DATE: 11-11-11
DRAWN BY: J.P.
CHECKED BY: J.P.
SCALE: 1/4" = 1'-0"
SHEET NO. FP-4




Congress Street Elevation

NFPA 13A		
HYDRAULIC DESIGN		
SYSTEM	WET	4TH FLOOR
HEADS		4 HEADS
DESIGN DENSITY		25 GPM
DESIGN PRESSURE		4 KPS
HEAD ALLOWANCE		180 GPM
DESIGN FLOW		7.2 GPM
DESIGN PRESSURE		48.6 PSI
DESIGN TEST PRESSURE		300 PSI
SAFETY FACTOR		300 PSI




FOURTH FLOOR FIRE SPRINKLER PLAN


BOTTOM OF WOOD CEILING TRUSSES= 9'-0" AFF
 (+0'-0") DENOTES ELEVATION OF PIPING ABOVE FIN FLOOR
 (-0'-0") DENOTES DISTANCE FROM BOTTOM OF DECK DOWN TO PIPING
 LINE HANGERS= TYPE #SBW (SEE DETAIL)
 MAIN HANGERS= TYPE #SBW (SEE DETAIL)
 (⊙) DENOTES HYDRAULIC REFERENCE POINTS




TYPICAL SIDEWALL EXPOSED



TYPICAL SIDEWALL SEMI RECESSED




TYPICAL SIDEWALL SEMI RECESSED



FOURTH FLOOR ZONE CONTROL DETAIL SCALE: N.T.S.

REVISIONS	NOTES	DATE	BY	CHKD

SYMBOLS	DESCRIPTION



SCHWARTZ BUILDING
 602 CONGRESS STREET
 PORTLAND MAINE
4TH FLOOR FIRE SPRINKLER PLAN
FREEDOM FIRE PROTECTION, INC
 5005 SQUARERIDGE ROAD
 CASCO, MAINE 04013
 (207) 687-4100

DATE: 8-20-08
 DRAWN BY: JF
 CHECKED BY: JF
 SHEET NO: 1/1
FP-6