

EXISTING SUB-FLOOR

 $| \lor |$

| /\ |

|/ \|

| | |

1 / 1

| | | |

SHEATHING (V.I.F.) (TYP.)

EXISTING 2"x8" @ 16" O.C. FLOOR JOISTS (V.I.F.). VERIFY ORIENTATION

OF JOISTS IN FIELD (TYP.) —

T/EXIST. FLOOR

(SUB-FLOOR) ELEV. (V.I.F.)

PRELIMINARY NOT FOR CONSTRUCTION

SCREWS (TYP.)

PROVIDE BOOT AT PIPE PENETRATION AND SEAL PENETRATION WEATHER-TIGHT

(DESIGNED BY OTHERS, TYP.)

 $-3-\frac{1}{2}$ "ø A307 HDG THRU BOLTS IN %6" # HOLES AS SHOWN (TYP.)

1/4"x2"ø PLATE. SEAL

WELD ALL AROUND (TYP.)

WIDE BENEATH EACH JOIST (TYP.)

PROVIDE 2x SOLID P.T.

BLOCKING ALL AROUND PIPE

SOLID IN ROOF SYSTEM (TYP.) —

- %" ROOF SHEATHING (TYP.)

- STAIR ENCLOSURE ROOF BELOW - SEE L&L DRAWING UNDER PROJECT NUMBER 2016-211A FOR INFORMATION

SECTION / 4

1 1/2" = 1'-0"

BUILDING
602 CONG
PORTLAND
EXTERIOR [
SFCTIONS

THESE DRAWINGS HAVE BEEN DEVELOPED BY L&L STRUCTURAL ENGINEERING SERVICES, INC. FOR THE TITLED SET ONLY. THE DRAWINGS ARE THE SOLE PROPERTY OF L&L ENGINEERING SERVICES, INC. AND THEY SHALL NOT BE USED, LENT, COPIED OR ALTERED WITHOUT THE WRITTEN CONSENT OF L&L STRUCTURAL ENGINEERING SERVICES, INC.