

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT

This is to certify that

PACIFIC & SOUTHERN COMPANY INC

Located at

128 HIGH ST (United Way)

PERMIT ID: 2015-01970

ISSUE DATE: 09/17/2015

CBL: 039 A017001

has permission to **For the installation of an 8' x 12' (96 SF), temporary, wall banner - Give, Advocate, Live United (United Way of Greater Portland).**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise cloed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

N/A

/s/ Tammy Munson

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

Building Inspections

Fire Department

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

**Check the Status or Schedule an Inspection On-Line at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

REQUIRED INSPECTIONS:

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No: 2015-01970	Date Applied For: 08/13/2015	CBL: 039 A017001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Same: WCSH 6		Proposed Project Description: For the installation of an 8' x 12' (96 SF), temporary, wall banner - Give, Advocate, Live United (United Way of Greater Portland).		
Dept: Historic	Status: Approved	Reviewer: Robert Wiener	Approval Date: 09/16/2015	
Note:				Ok to Issue: <input checked="" type="checkbox"/>
Conditions:				
Dept: Zoning	Status: Approved w/Conditions	Reviewer: Ann Machado	Approval Date: 09/03/2015	
Note:				Ok to Issue: <input checked="" type="checkbox"/>
Conditions:				
<ol style="list-style-type: none"> 1) This permit is being issued with the condition that the banner is temporary. It will be installed for the fall campaign for the United Way and must be removed as soon as the campaign ends. 2) This is the seventh year that the United Way Campaign has installed temporary banners. Since the proposed banner exceeds the allowable square footage of a temporary banner an exception has been granted by the Planning Division under section 14-368.5(g) to allow the banner "to advertise a community wide campaign supporting a significant number of nonprofits within the region" 3) ANY exterior work requires a separate review and approval thru Historic Preservation. This property is located within an Historic District. 				