Inspections Division

Date: 09/15/16

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with, the Report of Materials and Equipment Acceptance (MEA) Division.

Richard C. Visconti, R.A., Acting Commissioner
MEA109-00-M

Report of Material and Equipment Acceptance Division Manufacturer-
Britten Inc., 2322 Cass Road, Traverse City, Michigan 49684.
Trade Name – Admesh Vinyl-Coated Scrim
Product - PVC coated fabric for flex sign.
Pertinent Code Section(s) -27-499, 27-501, 27-506, 27-507, and TPPN #11/99.
Prescribed Test(s) - RS 7-3 [NFPA 701(Test Method 2)].
Laboratory - Govmark Organization Inc.
Test Report(s) - Test Report #2-278410-0, dated March 3, 2000
Description –Admesh Vinyl-Coated Scrim material for use as flex sign, is a polyester fabric coated with PVC Vinyl. It is used for large hanging banners and signs. It can be printed on

Recommendation - That the above material be accepted as meeting the flame resistance requirements of Section 27-506 and 27-507 of the Building Code, for use on flex signs. The acceptance of this material is limited to flame resistance only. Structural and other requirements shall be in accordance with pertinent Building Code provisions and Technical Policy and Procedure Notice #11/99. All installations, uses and locations shall be in accordance with the New York City Building Code, specifically with Section 27-499 and 27-501, and the Zoning Resolution. All shipments and deliveries of such materials shall, in addition, be accompanied by a tag, certifying that the materials shipped or delivered is equivalent to those tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance *ftp*

Examined By_