

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that

BLUE BAY LLC

Located at

612 CONGRESS ST

PERMIT ID: 2016-01162

ISSUE DATE: 06/24/2016

CBL: 039 A038001

has permission to **Fire Alarm system for coverage of restaurant only.**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise cloed-in. 48 HOUR NOTICE IS REQUIRED.	A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.
--	--

/s/ Michael White

/s/ Tammy Munson

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

Building Inspections

Fire Department

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

**Check the Status or Schedule an Inspection On-Line at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

REQUIRED INSPECTIONS:

Electrical Close-in

Final Inspection

Final - Fire

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No: 2016-01162	Date Applied For: 05/06/2016	CBL: 039 A038001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Restaurant	Proposed Project Description: Fire Alarm system for coverage of restaurant only.			
Dept: Historic Status: Approved w/Conditions Reviewer: Robert Wiener Approval Date: 06/23/2016 Note: Ok to Issue: <input checked="" type="checkbox"/>				
Conditions:				
1) Knox box on exterior must be recessed. Installer is to coordinate with the carpentry contractor who is working on the storefront renovation. HP staff is to be notified at 756-8023 when a location for the knox box is identified.				
Dept: Zoning Status: Approved Reviewer: Tammy Munson Approval Date: 05/17/2016 Note: Ok to Issue: <input checked="" type="checkbox"/>				
Conditions:				
Dept: Fire Status: Approved w/Conditions Reviewer: Michael White Approval Date: 06/09/2016 Note: Ok to Issue: <input checked="" type="checkbox"/>				
Conditions:				
1) All construction shall comply with 2009 NFPA 1, Fire Code. Review and approval by the AHJ shall not relieve the applicant of the responsibility of compliance with this Code (Chapter 1.14.4).				
2) The fire alarm system shall have a new fire alarm inspection sticker.				
3) The fire alarm technician shall be present for the fire inspection. System acceptance and commissioning must be coordinated with alarm and suppression system contractors and the Fire Department. Call 874-8400 to schedule.				
4) All smoke alarms shall be photoelectric.				
5) The installation shall comply with the following: City of Portland Chapter 10, Fire Prevention and Protection; NFPA 1, Fire Code (2009 edition), as amended by City Code; NFPA 101, Life Safety Code (2009 edition), as amended by City Code; City of Portland Fire Department Rules and Regulations; NFPA 72, National Fire Alarm and Signaling Code (2010 edition), as amended by Fire Department Rules and Regulations; and NFPA 70, National Electrical Code (2011 edition) as amended by the State of Maine.				
6) A Knox Box is required.				