DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



This is to certify that

BLUE BAY LLC

Located at

612 CONGRESS ST

PERMIT ID: 2016-00418

ISSUE DATE: 03/28/2016

CBL: 039 A038001

has permission to Kitchen Hood (Type I) for new restaurant

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ David Petruccelli

/s/ Tammy Munson

Fire Official

Building Official

THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY THERE IS A PENALTY FOR REMOVING THIS CARD

Approved Property Use - Zoning

Building Inspections

Fire Department

restaurant

BUILDING PERMIT INSPECTION PROCEDURES Please call 874-8703 (ONLY)

or email: buildinginspections@portlandmaine.gov

Check the Status or Schedule an Inspection On-Line at http://www.portlandmaine.gov/planning/permitstatus.asp

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.
- Permits expire in 6 months. If the project is not started or ceases for 6 months.
- If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.
- Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.

REQUIRED INSPECTIONS:

Final Inspection

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

					•	
City of Portland, Maine - Building or Use Permit				Permit No:	Date Applied For:	CBL:
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 87				2016-00418	02/23/2016	039 A038001
Proposed Use:			Proposed	Project Description:		
Restaurant			Kitchen	i Hood (Type I) fo	r new restaurant	
Dept: Historic Note:	Status:	Approved w/Conditions	Reviewer:	Robert Wiener	Approval Da	ate: 03/24/2016 Ok to Issue: ✓
Conditions:						
	on roof is to be kep	t as low as possible.				
Dept: Zoning	Status:	Approved w/Conditions	Reviewer:	Ann Machado	Approval Da	ate: 03/02/2016
Note:						Ok to Issue:
Conditions:						
1) ANY exterio District.	or work requires a so	eparate review and approval	thru Historic F	Preservation. This	property is located w	rithin an Historic
Dept: Fire	Status:	Approved w/Conditions	Reviewer:	David Petruccelli	Approval Da	ate: 03/26/2016
Note:						Ok to Issue: 🔽
Conditions:						
	ovide documentatio	n re: cleaning schedule, emp	oloyee training	and cleaning contr	ract information	
2) Hood suppre fire alarm sys tested for ope	ssion system shall of stem if available. A eration, fuel gas shu	comply with NFPA 17A, 96 A letter of compliance will but off, and fire alarm connection system pull station.	, and UL 300. e required at th	Activation of the setime of final insp	suppression system s pection stating: the d	ate the system was

- 3) Any cutting and welding done will require a Hot Work Permit from Fire Department.
- 4) Installation shall comply with City Code Chapter 10 and NFPA 96, Standard for ventilation Control and Fire Protection of Commercial Cooking Operations, 2008 edition. A signed letter of certification is required.