CERTIFICATE OF FLAME RETARDANCE

Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 06/15/15

ISSUED TO: MAINE BAY CANVAS INC.
53 INDUSTIRAL WAY
PORTLAND, ME 04103

NUMBER: 85935

DATE: 4-28-2015

THIS CERTIFICATE OF COMPLIANCE IS ISSUED TO VERIFY THAT THE ITEMS OR AREAS DESCRIBED BELOW ON THIS CERTIFICATE HAVE BEEN TREATED WITH FLAME COAT™.

FLAME COAT™ IS A CLASS A FIRE RETARDANT.

Description of Material, Structure, etc.

45	YARDS SUNBRELLA #4955 FERN CLASSIC, TREATED W/FLAMECOAT
	N.F.P.A. 701 SMALL SCALE, CLASS A. A.S.T.M.E-84,FLAME SPREAD:10 SMOKE DENSITY:25,
	AFTER FLAME AVG:0.0 sec,CALIFORNIA TITLE 19 SECTION 1237,CALIFORNIA TB 117E
	FOR INTERIOR & EXTERIOR USE
42815	4-28-2015

REGISTERED STATE OF CALIFORNIA STATE FIRE MARSHAL FLAME RETARDANT GA - 1201.01

ISSUED BY:

American Flamecoat Inc.

521-F Eagleton Downs Drive
Pineville, NC 28134
(704) 543-0903

Director GA-1201.01 (General)

Note: Fabrics and/or materials described on this certificate are intended for interior use unless otherwise stated. Due to the number of external forces that can diminish flame retardancy, this fabric should be periodically retested to insure it retains its effectiveness. We do not warrant the length of time that the fabric remains fire retardant. We do state that when it leaves our facility, it meets the stated code. Certificate void if material is exposed to open flame or extremely hot lights or electrical wiring.

©2008 #137048