

Beverly Stone

From: Mike Keon
Sent: Wednesday, June 29, 2016 02:53 PM
To: Beverly Stone
Subject: Fwd: Nema Statement

Sent from my iPad

Begin forwarded message:

From: Asa Gorman <asa.gorman@gmail.com>
Date: June 29, 2016 at 2:07:15 PM EDT
To: Mike Keon <mike@ottoportland.com>
Subject: Fwd: Nema Statement
Reply-To: asa.gorman@gmail.com

----- Forwarded message -----
From: "Mary Jo Reed" <mjrelectric@me.com>
Date: Jun 29, 2016 2:06 PM
Subject: Nema Statement
To: "Asa Gorman" <asa.gorman@gmail.com>
Cc:


To whom it may concern:

44 Oak St, Condo 4-5 floor sustained water damage due to an activated sprinkler head. NEMA standards require all switches, receptacles, light fixtures, wire and outlet boxes affected be replaced. I have inspected all accessible devices in these areas and found them to be functional and free of any sign of water damage. Mike Keon, owner of the property, has been advised of these two facts.

Sincerely,
MJ

MJ Reed
MJR Electric
[207-831-9387](tel:207-831-9387)
mjrelectric@me.com
Sent from my iPhone

I HAVE ACKNOWLEDGED THE
NEMA STANDARDS AND AM
AWARE OF THE ELECTRICIANS
ASSESSMENT AND I AM
COMFORTABLE WITH THEIR DECISION.



Before Me, I, Pamela Hennings
MICHAEL KEON
6/29/16