



State of Maine
Department of Public Safety
Fire Sprinkler System Permit



9228

Maine Health 110 Free Street

Located at:
 In the Town of: Portland
 Occupancy/Use: Medical Offices
 Type of System: NFPA 13


Permission is hereby given to:

High Tech Fire Protection Co., Inc.
 PO Box 156
 Minot, ME 042580156
 Contractor License # **102**

according to plans submittal filed with the Licensing and Inspections Unit and are now approved. This application form/plans are filed under log # **2101235**, and no departure from application form/plans shall be made without prior approval in writing. This permit is issued under the provisions of Title 32, Chapter 20, Section 12004-I. Nothing herein shall excuse the holder of this permit for failure to comply with local ordinances, zoning laws, or other pertinent legal restrictions. Each permit issued shall be displayed/available at the site of construction.

This permit was issued on **9/16/2010** for a fee paid of **\$1,344.00**

This permit will expire at midnight on Tuesday, March 15, 2011



Anne H. Jordan
 Commissioner

Fire Department Connection Location/Type per Local Fire Department

Within 30 days of the completion of a new fire sprinkler system or an addition to an existing fire sprinkler system, a fire sprinkler system contractor shall provide to the Licensing and Inspections Unit a copy of this permit signed and dated by the certified responsible managing supervisor representing that the fire sprinkler system has been installed according to specifications of the approved plan to the best of the supervisor's knowledge, information, and belief. This requirement is part of the sprinkler law, and neglect of this duty is grounds to not renew the contractor's license to do work in the State of Maine. All sprinkler licenses expire June 30th every year.

Job completed, tested and verified on date of _____

RMS for this job: Poulin Edward M.

RMS Signature: _____



Fire Suppression System Permit

If you or the property owner owes real estate or property taxes or user charges on any property within the city, payment arrangements must be made before permits of any kind are accepted.

Installation address: 110 Free Street CBL: _____

Exact location: (within structure) Complete Building

Type of occupancy(s) (NFPA & ICC): Medical office ^{NFPA 13} Light hazard + Ordinary hazard group 1

Building owner: Maine Health

Managing Supervisor: Ed Poulin License No: Nicet # 108534 / ME RMS # 515

Supervisor phone: 207-998-2551 E-mail: epoulin@fairpoint.net

Installing contractor: High Tech Fire Protection License No: 102

Contractor phone: 207-998-2551 E-mail: HTFP@fairpoint.net

The suppression work to be done will be: New: Renovation: Addition to existing system:

This is an amendment to an existing permit: Yes: NO Permit no: 9228

NFPA Standard will this system is designed to: 13 Edition: 2007

*Non-NFPA systems are not approved for use within the City of Portland.

Download a new copy of this document from Inspection Division on-line at www.portlandmaine.gov for every submittal. Attach all design information and complete approved submittals as may be required by the State Fire Marshal's Office on 11X17 copies or electronic PDF's in **addition** to full sized plans.

Contractor shall verify location and type of all FDCs shall be approved in writing by the Fire Prevention Bureau.

Submit all information to the Building Inspections Department, 389 Congress Street, Room 315, Portland, Maine 04101.

Prior to acceptance of any fire protection system, a complete commissioning and acceptance test must be coordinated with all fire system contractors and the Fire Department, and proper documentation of such test(s) provided.

All installation(s) must comply with NFPA and the Fire Department Technical Standard(s).

COST OF WORK: \$90,000.00

PERMIT FEE: \$920

(\$10 PER \$1,000 + \$30 FOR THE FIRST \$1,000)

Applicant signature: Edward M Poulin Date: 9-16-10