



Mark	Date	Description
	11/25/09	ISSUED FOR BID

Issue Dates
Drawing Status

LEGEND

- POWER** -----
- LP-1,3 ← ← ← BRANCH CIRCUIT HOMERUNS - ARROWS INDICATE NUMBER OF CIRCUITS, CIRCUIT NUMBER(S) PANEL DESIGNATION
 - ⊖ DUPLEX CONVENIENCE RECEPTACLE - MOUNTED C/L UP 22" UNLESS NOTED OTHERWISE - R-RED RECEPTACLE ON EMERGENCY CIRCUIT
 - ⊖ SINGLE CONVENIENCE RECEPTACLE - MOUNTED C/L UP 22" UNLESS NOTED OTHERWISE
 - ⊖ DOUBLE DUPLEX CONVENIENCE RECEPTACLE IN TWO GANG WALL BOX - MOUNTED C/L UP 22" UNLESS NOTED OTHERWISE
 - TR = TAMPER RESISTANT
GFI = GROUND FAULT CIRCUIT INTERRUPTER
AFI = ARC FAULT CIRCUIT INTERRUPTER
 - Ⓜ ELECTRICAL MOTOR
 - ⊠ DISCONNECT SWITCH - FUSED WHEN NOTED - SIZE AS REQUIRED OR AS INDICATED FUSED
 - Ⓜ JUNCTION BOX - SIZE AS REQUIRED OR AS INDICATED
 - Ⓜ LIGHTING/POWER PANELBOARD (SURFACE)
 - Ⓜ LIGHTING/POWER PANELBOARD (RECESSED)
- MISCELLANEOUS** -----
- GFI GROUND FAULT CIRCUIT INTERRUPTER
 - Ⓜ CARD SWIPE (CARD READER)/KEYPUNCH - PROVIDE 4" BACKBOX, SINGLE GANG MUDRING AND 3/4" CONDUIT TO ACCESSIBLE CEILING SPACE
 - Ⓜ TEL/DATA OUTLET

- EMERGENCY LIGHTING DEVICES** -----
- EXIT SIGN WITH ARROWS AS INDICATED OR FLAT LINE INDICATES SIGN FACE - WALL, END AND CEILING (W/E OR C) MOUNT AS NOTED.
 - Ⓜ EMERGENCY LIGHTING BATTERY UNIT - WALL MOUNTED UP 7'-6". NUMERAL INDICATES BATTERY ID NUMBER. SEE SPEC FOR DC AS NOTED. HEADS AS SHOWN.
 - Ⓜ EMERGENCY LIGHTING REMOTE HEAD WITH NUMBER OF HEADS AS INDICATED - MOUNTED UP 7'-6". NUMERAL INDICATES BATTERY UNIT CONNECTED TO. WP INDICATES EXTERIOR WEATHERPROOF TYPE.

- LIGHTING** -----
- Ⓜ 2' x 4' FLUORESCENT FIXTURE
 - △ SCANCE FLUORESCENT FIXTURE - SEE LIGHTING FIXTURE SCHEDULE
 - CEILING MOUNTED FIXTURE - SEE LIGHTING FIXTURE SCHEDULE
 - S SINGLE POLE SWITCH - MOUNTED C/L UP 46" UNLESS NOTED OTHERWISE
 - Sos OCCUPANCY SENSOR SWITCH - MOUNTED C/L UP 46" UNLESS NOTED OTHERWISE
 - Swp SWITCH - HORSE POWER RATED - SIZE AS REQUIRED.
 - Ss SWITCH - SUBLETTER INDICATES SWITCH CONTROL

- FIRE ALARM DEVICES** -----
- Ⓜ FIRE ALARM STROBE
 - Ⓜ FIRE ALARM HORN/STROBE
 - Ⓜ SMOKE DETECTOR - CEILING MOUNTED
 - Ⓜ DUCT DETECTOR WITH SAMPLING TUBE - SEE MECHANICAL DRAWING FOR LOCATIONS - COORDINATE WITH DW. 23.
 - Ⓜ HEAT DETECTOR - MOUNTED ON CEILING
 - Ⓜ FIRE ALARM MANUAL PULL STATION - MOUNTED C/L UP 46"