



- DEMOLITION KEY NOTES**
- ① REMOVE EXISTING JUNCTION BOXES, RECEPTACLES, TEL/DATA JACKS, CONDUIT AND CONDUCTORS BACK TO SOURCE.
  - ② REMOVE EXISTING JUNCTION BOXES, RECEPTACLES, CONDUIT AND CONDUCTORS FROM OLD FIRE ALARM SYSTEMS. NOT ALL LOCATIONS SHOWN ON DRAWING.
  - ③ REMOVE EXISTING JUNCTION BOXES, CONDUIT AND CONDUCTORS FOR OLD CLOCK SYSTEM BACK TO SOURCE.
  - ④ REMOVE EXISTING ABANDONED JUNCTION BOXES, CONDUIT AND CONDUCTORS MOUNTED ON CEILING/SLAB.
  - ⑤ REMOVE EXISTING LIGHTING FIXTURES, SWITCHES, CONDUIT AND CONDUCTORS BACK TO SOURCE.
  - ⑥ REMOVE EXISTING FIRE ALARM DEVICES, CONDUIT AND CONDUCTORS BACK TO SOURCE.
  - ⑦ REMOVE EXISTING EXIT SIGN, CONDUIT AND CONDUCTORS BACK TO SOURCE.
  - ⑧ REMOVE EXISTING ELECTRICAL PANEL, CONDUIT AND CONDUCTORS BACK TO SOURCE.
  - ⑨ REMOVE EXISTING CAMERAS, SECURITY DEVICES, CONDUIT, CONDUCTORS AND CABLING BACK TO SOURCE.
  - ⑩ EXISTING HEATED GUTTER/DRAIN SYSTEM TO REMAIN. LOCATE, ISOLATE AND SAVE ALL JUNCTION BOXES, CONDUIT AND CONDUCTORS FOR RECONNECTION IN NEW WORK.
  - ⑪ EXISTING FIREMAN'S KNOX BOX TO REMAIN.
  - ⑫ EXISTING FRONT ENTRANCE FIXTURES TO REMAIN. LOCATE, ISOLATE AND SAVE JUNCTION BOXES, CONDUIT AND CONDUCTORS FOR RECONNECTION IN NEW WORK.
  - ⑬ REMOVE EXISTING PHOTOCELLS AND JUNCTION BOXES. IDENTIFY USE AND SAVE CONDUCTORS IF BEING USED IN NEW WORK.
  - ⑭ DEVICE BOX AND RACEWAY REMAINS.
  - ⑮ EXISTING PANEL TO BE RELOCATED FOR TEMPORARY CONSTRUCTION POWER. SEE SHEET ED04.1.
  - ⑯ EXISTING STAIRWELL FIXTURES SHALL BE MADE OPERABLE. REPLACE BALLASTS AND PROVIDE NEW FLOURESCENT LAMPS AND LENSES WHERE NEEDED.
  - ⑰ REMOVE EXISTING BACKBOARD, PUNCHDOWN BLOCKS AND COMMUNICATIONS CABLING BACK TO SOURCE.

- DEMOLITION GENERAL NOTES**
1. REMOVE ALL EXISTING NON METALLIC CABLE AND RELATED JUNCTION BOXES BACK TO SOURCE.
  2. LOCATIONS AND QUANTITIES OF LIGHTING FIXTURES AND OTHER ELECTRICAL DEVICES ARE DERIVED FROM EXISTING DRAWINGS AND SITE OBSERVATIONS. NOT ALL LIGHT FIXTURES AND/OR ELECTRICAL DEVICES MAY BE SHOWN.
  3. DEVICE/EQUIPMENT SHOWN WITH "E" IS EXISTING TO REMAIN.


11/25/09	ISSUED FOR BID
Mark	Date
	Description

Issue Dates

Drawing Status

Drawing Title  
**ELECTRICAL DEMOLITION FIRST FLOOR PLAN**  
PA / PE: WRH | Drawn By: RJB

Drawing Number  
**ED06.1**