DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK





This is to certify that

Located at

HELLENIC ORTHODOX COMMUNITY OF PORTLAND

133 PLEASANT ST

& WESTBROO

PERMIT ID: 2014-00755

ISSUE DATE: 05/14/2014

CBL: 039 D009001

has permission to Set up tent for Greek Festival 6/24/2014 - 6/30/2014

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Craig Messinger

/s/ Tammy Munson

Fire Official

Building Official

THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY THERE IS A PENALTY FOR REMOVING THIS CARD

Approved Property Use - Zoning

Building Inspections

Fire Department

Church

BUILDING PERMIT INSPECTION PROCEDURES Please call 874-8703 (ONLY)

or email: buildinginspections@portlandmaine.gov

Check the Status or Schedule an Inspection On-Line at http://www.portlandmaine.gov/planning/permitstatus.asp

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.
- Permits expire in 6 months. If the project is not started or ceases for 6 months.
- If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.
- Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.

REQUIRED INSPECTIONS:

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

289 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-871					2014.00755	Date Applied For.	CBL.		
					2014-00755	04/16/2014	039	D0090)01
Proposed Use:					Proposed Project Description:				
Same: Holy Trinity Church				Set up	Set up tent for Greek Festival 6/24/2014 - 6/30/2014				
Dept:	Historic	Status:	Approved	Reviewer:	Deb Andrews	Approval Da	ite: (05/07/2	2014
Note:							Ok to Is	ssue:	✓
Condi	tions:								
_	Zoning	Status:	Approved	Reviewer:	Marge Schmucka			04/16/2	_
Note:							Ok to Is	ssue:	✓
Condi	tions:								
Dept:	Building	Status:	Approved	Reviewer:	Tammy Munson	Approval Da	ite: (04/28/2	2014
Note:							Ok to I	ssue:	✓
Condi	tions:								
Dept:	Fire	Status:	Approved w/Conditions	Reviewer:	Craig Messinger	Approval Da	ite: (04/29/2	2014
Note:							Ok to I	ssue:	~
	. •								

Conditions:

- 1) EXITs
 - a. The main entrance shall have minimum clear width of 10 feet.
 - B.The divider in the main tent shall maintain an exit opening of 6 feet.
 - C.A main corridor for the main tent shall be maintained a minimum of 50 inches. Where a chair is placed between a table and the corridor the measurement shall be made from the table and add 19 inches for each chair (ie. Chair at both sides 38" + 50"= 88"). D.An exit from the main tent to the outside directly across from the main entrance shall be provided. Minimum clear width shall be

6 feet.

- E.The auction tent shall have 2 exits perpendicular from the main tent. Minimum clear width shall be 36".
- F.The catering tent shall have one additional exit across from the main tent. Minimum clear width shall be 36".
- 2) Emergency lighting and approved illuminated EXIT signs are required for events held outside of day light hours. A back up generator with transfer switch shall meet this requirement if the following is met:
 - a.All lighting is powered from the generator circuit.
 - B.The lighting illuminates the face of the EXIT signs.
 - C.An auto transfer and start shall be provided or dedicated staff shall be provided for that purpose.
- 3) Cooking within the tents has not been reviewed and approved.
- 4) All tents shall meet the flame propagation performance criteria contained in NFPA 701. A certificate or other evidence of acceptance by an organization acceptable to the AHJ shall serve as evidence that the tent fabric materials have the required flame propagation performance.
- 5) Tents shall have an approved fire resistant rating and maintain 10' between stake lines. No smoking or open flame allowed within 10'. Provide at least one 2A:10 BC fire extinguisher.

PERMIT ID: 2014-00755 **Located at:** 133 PLEASANT ST **CBL:** 039 D009001