Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 05/17/16

See historic preservation conditions for design details

minimum guard height is 42"

All beams to bear directly on posts or knotched and bolted.