

· LOADS ON NORTH AND SOUTH PENTHOUSE ELEVATIONS PENTHOUSE 221'-10" SEE NORTH ELEVATION FOR WIND LOADS ON STAIR TOWER MACHINE ROOM 213'-2" ROOF 203'-10" ELEVENTH FLOOR 195'-0" TENTH FLOOR 186'-2" NINTH FLOOR 177'-4" EIGHTH FLOOR 168'-6" SEVENTH FLOOR 159'-8" SIXTH FLOOR 150'-10" FIFTH FLOOR 142'-0" FOURTH FLOOR 133'-2" THIRD FLOOR 124'-4" SECOND FLOOR 114'-6" BUILDING PEDESTAL (N.I.C.) FIRST FLOOR 99'-6"

NORTH ELEVATION WIND LOADS

<u>DESIGN WIND LOAD</u> 37 PSF 66 PSF

67 PSF


3

SOUTH ELEVATION WIND LOADS

N.T.S.

Holiday Inn

MATTHEW J. MILLER



WEST ELEVATION WIND LOADS

N.T.S.

<u>DESIGN WIND LOAD</u>

37 PSF


67 PSF

66 PSF

Holiday Inn

DESIGN WIND LOADS WEST ELEVATION

Scale: NONE



# EXISTING PENTHOUSE ROOF PLAN

1/4" = 1'-0"

### <u>PLAN NOTES</u>

- DIMENSIONS PROVIDED ARE BASED ON LIMITED FIELD MEASUREMENTS. CONTRACTOR SHALL FIELD VERIFY DIMENSIONS PRIOR TO CONSTRUCTION
- 2. BP-x INDICATES BASE PLATE MARK. SEE 2/S2.1 FOR DETAILS

# **GENERAL NOTES**

- 1. DETAILS SHOWN ON THESE DRAWINGS ARE TYPICAL; SIMILAR DETAILS APPLY TO SIMILAR CONDITIONS
- UNLESS NOTED OTHERWISE. 2. BRACE BUILDING UNTIL STRUCTURAL ELEMENTS NECESSARY FOR STABILITY HAVE BEEN INSTALLED. THESE ELEMENTS INCLUDE: ROOF DECK, FLOOR DECK, BRACING MEMBERS, MOMENT CONNECTIONS, SHEAR WALLS, ETC. IT IS THE CONTRACTOR'S RESPONSIBILITY TO DETERMINE ERECTION PROCEDURES AND SEQUENCING TO ENSURE THE SAFETY OF THE BUILDING AND IT'S COMPONENTS DURING ERECTION.
- 3. CONTRACTOR SHALL NOTIFY THE ENGINEER IN WRITING OF ANY PROPOSED CHANGES, DEVIATIONS OR SUBSTITUTIONS FROM DIMENSIONS, MATERIALS OR EQUIPMENT SHOWN ON THESE DRAWINGS AND MAKE ONLY THOSE CHANGES ACCEPTED BY THE ENGINEER.
- 4. THE CONTRACTOR SHALL BE RESPONSIBLE FOR THE COORDINATION BETWEEN THE STRUCTURAL DRAWINGS AND THE DRAWINGS OF OTHER DISCIPLINES TO INCLUDE THE LOCATIONS AND DIMENSIONS OF OPENINGS, CHASES, INSERTS, SLEEVES, DEPRESSIONS AND OTHER DETAILS NOT SHOWN ON THE STRUCTURAL DRAWINGS.
- 5. THESE DRAWINGS DO NOT INCLUDE NECESSARY COMPONENTS FOR CONSTRUCTION SAFETY. THE CONTRACTOR SHALL BE SOLELY RESPONSIBLE FOR CONSTRUCTION SAFETY.

## STRUCTURAL STEEL NOTES

# SUBMITTALS FOR REVIEW

1. SHOP DRAWINGS: INDICATE PROFILES, SIZES, SPACING, LOCATIONS OF STRUCTURAL MEMBERS, DECKING, OPENINGS, ATTACHMENTS, AND FASTENERS. SHOW ALL CONNECTION DETAILS. PROVIDE DESIGN OF CONNECTIONS NOT DETAILED ON DRAWINGS. INDICATE WELDED CONNECTIONS WITH AWS A2.4 WELDING SYMBOLS. INDICATE NET WELD LENGTHS.

### SUBMITTALS FOR INFORMATION

- 1. MANUFACTURER'S MILL CERTIFICATE: CERTIFY THAT PRODUCTS MEET OR EXCEED SPECIFIED
- 2. MILL TEST REPORTS: SUBMIT INDICATING STRUCTURAL STRENGTH, DESTRUCTIVE AND NON-DESTRUCTIVE TEST ANALYSIS.
- 3. WELDERS CERTIFICATES: CERTIFY WELDERS EMPLOYED ON THE WORK, VERIFYING AWS QUALIFICATION WITHIN THE PREVIOUS 12 MONTHS.

# **QUALITY ASSURANCE**


1. FABRICATE STRUCTURAL STEEL MEMBERS IN ACCORDANCE WITH AISC CODE OF STANDARD PRACTICE. 2. FABRICATOR AND ERECTOR: COMPANY SPECIALIZING IN PERFORMING THE WORK OF THIS SECTION WITH

#### MINIMUM FIVE YEARS EXPERIENCE. <u>MATERIALS</u>

- 1. STRUCTURAL STEEL WIDE FLANGE MEMBERS: ASTM A992
- 2. ANGLES, CHANNELS, PLATE AND OTHER HOT ROLLED SHAPES: ASTM A36 3. STRUCTURAL TUBING: ASTM A500, GRADE B.
- 4. BOLTS, NUTS, AND WASHERS: MINIMUM 3/4" DIAMETER ASTM A325 BOLTS, ASTM A563 NUTS WITH HARDENED WASHERS, GALVANIZED TO ASTM A153 FOR GALVANIZED STRUCTURAL MEMBERS. ASTM A490 BOLTS REQUIRED WHERE NOTED ON DRAWINGS.
- 5. ANCHOR BOLTS: ASTM A-307 FOR HEADED BOLT ASTM A-36 FOR THREADED ROD

#### 6. WELDING MATERIALS: AWS D1.1; TYPE REQUIRED FOR MATERIALS BEING WELDED.

- 1. ALLOW FOR ERECTION LOADS, AND FOR SUFFICIENT TEMPORARY BRACING TO MAINTAIN STRUCTURE SAFE, PLUMB, AND IN TRUE ALIGNMENT UNTIL COMPLETION OF ERECTION AND INSTALLATION OF PERMANENT
- 2. FIELD WELD COMPONENTS INDICATED ON DRAWINGS AND SHOP DRAWINGS.
- 3. DO NOT FIELD CUT OR ALTER STRUCTURAL MEMBERS WITHOUT APPROVAL OF ARCHITECT/ENGINEER. 4. AFTER ERECTION, PRIME WELDS, ABRASIONS, AND SURFACES NOT SHOP PRIMED, EXCEPT SURFACES TO BE IN CONTACT WITH CONCRETE.



# PENTHOUSE ROOF FRAMING PLAN

<u>PLAN NOTES</u>

- 1. SEE PLAN FOR TOP OF STEEL (UNDERSIDE OF DECK) ELEVATION. TOP OF STEEL ELEVATIONS ARE
- BASED ON REFERENCE ELEVATION 100'-0" AT TOP OF EXISTING CONCRETE ROOF SLAB. 2. METAL ROOF DECK SHALL BE  $1\frac{1}{2}$ ", 20 GAGE, TYPE B, G90 GALV.

# METAL DECK

#### <u>GENERAL</u>

<u>INSTALLATION</u>

1. SHEET STEEL FOR DECK AND ACCESSORIES SHALL CONFORM TO ASTM A1008 WITH A MINIMUM YIELD STRENGTH OF 33 KSI. 2. ROOF DECK TYPES SHALL BE AS NOTED ON THE DRAWINGS.

#### SUBMITTALS FOR REVIEW

1. SUBMIT SHOP DRAWINGS FOR REVIEW. INCLUDE LAYOUT AND TYPES OF DECK PANELS, ANCHORAGE DETAILS, REINFORCING CHANNELS, PANS, CUT DECK OPENINGS, SPECIAL JOINING, ACCESSORIES, AND ATTACHMENTS TO OTHER CONSTRUCTION.

#### 1. INSTALL DECK PANELS AND ACCESSORIES ACCORDING TO APPLICABLE SPECIFICATIONS AND COMMENTARY IN SDI PUBLICATION

- NO. 31, MANUFACTURER'S WRITTEN INSTRUCTION AND REQUIREMENTS IN THIS SECTION. 2. PLACE DECK PANELS ON SUPPORTING FRAME AND ADJUST TO FINAL POSITION WITH ENDS ACCURATELY ALIGNED AND BEARING ON SUPPORTING FRAME BEFORE BEING PERMANENTLY FASTENED. DO NOT STRETCH OR CONTRACT SIDE LAP INTERLOCKS. 3. PLACE DECK PANELS FLAT AND SQUARE AND FASTEN TO SUPPORTING FRAME WITHOUT WARP OF DEFLECTION.
- 4. CUT AND NEATLY FIT DECK PANELS AND ACCESSORIES AROUND OPENINGS AND OTHER WORK PROJECTING THROUGH OR ADJACENT TO THE DECK. 5. PROVIDE ADDITIONAL REINFORCING AND CLOSURE PIECES AT OPENINGS AS REQUIRED FOR STRENGTH, CONTINUITY OF DECK,
- AND SUPPORT OF OTHER WORK. 6. COMPLY WITH AWS REQUIREMENTS AND PROCEDURES FOR MANUAL SHIELDED METAL ARC WELDING, APPEARANCE AND QUALITY OF WELDS, AND METHODS USED FOR CORRECTING WELDING WORK.
- 7. MECHANICAL FASTENING MAY BE USED IN LIEU OF WELDING TO FASTEN DECK WITH PRIOR APPROVAL OF THE ENGINEER. LOCATE MECHANICAL FASTENERS AND INSTALL ACCORDING TO DECK MANUFACTURER'S WRITTEN INSTRUCTIONS. 8. INSTALL FINISH STRIPS, END CLOSURES AND REINFORCING CHANNELS ACCORDING TO DECK MANUFACTURER'S WRITTEN
- INSTRUCTIONS. WELD OR MECHANICALLY FASTEN TO SUBSTRATE TO PROVIDE A COMPLETE DECK INSTALLATION. 9. DECK SHALL BE CONTINUOUS OVER 3 SPANS, MINIMUM.
- 10. FASTEN DECK WITH A MINIMUM OF 5/8" PUDDLE WELDS SPACED IN A 36/4 PATTERN AND 2-#10 TEK SCREWS PER DECK SPAN. DECK WELDS AT PERIMETER SUPPORTS SHALL BE A 6" ON CENTER.

BUILDING	G CODE: · ·		 	· 2009	9 INTERNATIONAL BUILDING CODE
<u>DESIGN</u>					
					PSF W LOAD GOVERNS
				0.10	. 20.0
GROUI	<u>NOW LOAD</u> ND SNOW LOA	D, Pg · · · ·	 	· 50 F	PSF
SNOW	EXPOSURE F	ACTOR, Ce TANCE FACTOR,	 	· 1.0	
		AL FACTOR, Ct			

(NOTE: NOT ALL ABBREVIATIONS ARE USED)
LLV LONG LEG VERTICAL LVL LAMINATED VENEER LUMBER MAX MAXIMUM MIN MINIMUM NS NEAR SIDE NTS NOT TO SCALE OC ON CENTER P# PIER MARK PL or P PLATE PSF POUNDS PER SQUARE FOOT PSI POUNDS PER SQUARE INCH PT PRESSURE TREATED REINF: REINFORCED / REINFORCING SIM: SIMILAR STD. STANDARD T/CONC TOP OF CONCRETE T/PIER TOP OF PIER ELEVATION T/SLAB TOP OF STEEL ELEVATION T/STL TOP OF STEEL ELEVATION TOSH TOP OF WALL ELEVATION TOW TOP OF WALL ELEVATION TYP: TYPICAL UNO UNLESS NOTED OTHERWISE VIF VERIFY IN FIELD
W.P. · · · · · WORKING POINT

STORY FRAMINCS AND GENERAL NOTES

JUNE 30, OVERS PLANS