



Department of Permitting and Inspections

Air Velocity within the duct system 3800 cfm

Grease accumulation prevention system: _____

Cleanouts: 3

Grease Duct enclosure: NO

Exhaust Termination: Roof Wall _____

Fire Suppression System: NOT US

Exhaust fan mounting and clearance from the roof / wall or Combustibles:

48" Above Roof line

Exhaust fan distance from property lines: _____

Exhaust fan distance from other vents or openings: _____

Exhaust fan distance from adjacent buildings: _____

Exhaust fan height above adjoining grade: _____

3. Hood Specs

Style of Hood: low profile

Type of Filter: STAINLESS BAFLED

Height of filter above nearest cooking surface: _____

Capacity of hood CFM: 4000 cfm

Make up Air system description and capacity:
Factory ~~was~~ matched to Hood
CAPTIVE AIR Engineered