

City of Portland, Maine - Building or Use Permit Application

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

No:	06-0498	Issue Date:	PERMIT ISSUED: MAY 15 2006	039	G002952
Owner Name:	MEAGHER MICHAEL VN TD VE	Owner Address:	93 PARK ST # 952	Phone:	
Contractor Name:	Down East Energy	Contractor Address:	172 Main Street South	Phone:	95585
Permit Type:	Tanks - Dwellings		CITY OF PORTLAND		

Location of Construction:	93 PARK ST
Business Name:	
Lessee/Buyer's Name	

Past Use:	Condo
Proposed Use:	Condo/ install one 120 gallon propane tank to replace existing 4 tanks from another company <i>excl use - 1 dwelling units</i>

Permit Fee:	\$30.00	Cost of Work:	\$30.00	CEO District:	1
-------------	---------	---------------	---------	---------------	---

<input checked="" type="checkbox"/> Ap	Type: <i>Tanks</i>
<i>TO NHPA 58</i>	<i>State Gas Regs</i>
Signature: <i>Greg Cass</i>	Signature: <i>[Signature]</i>

Proposed Project Description:
install one 120 gallon propane tank to replace existing 4 tanks from another company

PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.)

Action: Approved Approved w/Conditions Denied

Signature: _____ Date: _____

Permit Taken By:	Date Applied For:	Zoning Approval	
Idobson	04/12/2006		

<p>1. This permit application does not preclude the Applicant(s) from meeting applicable State and Federal Rules.</p> <p>2. Building permits do not include plumbing, septic or electrical work.</p> <p>3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..</p>	<p>Special Zone or Reviews</p> <p><input type="checkbox"/> Shoreland</p> <p><input type="checkbox"/> Wetland</p> <p><input type="checkbox"/> Flood Zone</p> <p><input type="checkbox"/> Subdivision</p> <p><input type="checkbox"/> Site Plan</p> <p>Maj <input type="checkbox"/> Minor <input type="checkbox"/> MM <input type="checkbox"/></p> <p>late: _____</p>	<p>Zoning Appeal</p> <p><input type="checkbox"/> Variance</p> <p><input type="checkbox"/> Miscellaneous</p> <p><input type="checkbox"/> Conditional Use</p> <p><input type="checkbox"/> Interpretation</p> <p><input type="checkbox"/> Approved</p> <p><input type="checkbox"/> Denied</p> <p>late: _____</p>	<p>Historic Preservation</p> <p><input type="checkbox"/> Not in District or Landmark</p> <p><input type="checkbox"/> Does Not Require Review</p> <p><input type="checkbox"/> Requires Review</p> <p><input type="checkbox"/> Approved</p> <p><input type="checkbox"/> Approved w/Conditions</p> <p><input type="checkbox"/> Denied</p> <p>Date: _____</p>
---	--	--	--

CERTIFICATION


I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provision of the code(s) applicable to such permit.

SIGNATURE OF APPLICANT	ADDRESS	DATE	PHONE
RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE		DATE	PHONE



FILL IN AND SIGN WITH INK

APPLICATION FOR PERMIT HEATING OR POWER EQUIPMENT



To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location / CBL 39 G 002952 Use of Building Private Date _____
 Name and address of owner of appliance Alice Meager 95 Park St
Portland
 Installer's name and address Down East Energy 172 Main St
South Portland Telephone 789-5585

Location of appliance:

- Basement
- Floor
- Attic
- Roof

Type of Fuel:

- Gas
- Oil
- Solid

Appliance Name:

U.L. Approved Yes No

Will appliance be installed in accordance with the manufacture's installation instructions? Yes No

IF **NO** Explain: _____

The Type of License of Installer:

- Master Plumber # _____
- Solid Fuel # _____
- Oil # _____
- Gas # PVT 1445
- Other _____

Type of Chimney:

- Masonry Lined
Factory built _____
- Metal
Factory Built U.L. Listing # _____
- Direct Vent
Type _____ uL# _____

Type of Fuel Tank

- Oil
- Gas

Replacing existing tank w/ 1 Downeast tank

Size of Tank 120

Number of Tanks 1

Distance from Tank to Center of Flame _____ feet.

Cost of Work: \$ _____

Permit Fee: \$ 30

Approved

Approved with Conditions

Fire: _____

Ele.: _____

Bldg.: _____

See attached letter or requirement

Inspector's Signature _____

Date Approved _____

Signature of Installer *Alice Meager*

White - Inspection

Yellow - File

Pink - Applicant's

Gold - Assessor's Copy

City of Portland, Maine - Building or Use Permit

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No: 06-0498	Date Applied For: 04/12/2006	CBL: 039 G002952
------------------------------	--	----------------------------

Location of Construction: 93 PARK ST	Owner Name: MEAGHER MICHAEL VN TD VE	Owner Address: 93 PARK ST # 952	Phone:
Business Name:	Contractor Name: Down East Energy	Contractor Address: 172 Main Street South Portland	Phone (207) 799-5585
Lessee/Buyer's Name	Phone:	Permit Type: Tanks - Dwellings	

Proposed Use: Condo/ install one 120 gallon propane tank to replace existing 4 tanks from another company	Proposed Project Description: install one 120 gallon propane tank to replace existing 4 tanks from another company
---	--

Dept: Zoning **Status:** Approved **Reviewer:** Ann Machado **Approval Date:** 0510212006

Note: Converted to four family dwelling in June 1971. Condo docs. recorded at Registry of Deeds on 411983. No record of condo conversion permit. Ordinance went into effect 11/16/81. Will contact Park Street Row House Association to determine when they became condos. We might need to issue an after the fact permit. **Ok to Issue:**

Dept: Building **Status:** Approved with Conditions **Reviewer:** Tammy Munson **Approval Date:** 05/12/2006

Note: **Ok to Issue:**

1) The tank must NOT be subject to vehicular traffic.

Dept: Fire **Status:** Approved with Conditions **Reviewer:** Cptn Greg Cass **Approval Date:** 04/12/2006

Note: **Ok to Issue:**

1) Install shall comply with NFPA 58

DIAGRAM / SPECIAL NOTES:

Driveway

set
- 120 bar
in place
of cycles

0000

Fence

Park 3
Town Houses

PKG
lot

Park 4 - L

