
72 High St., BP# 2016-02727 replacement windows plan review comments

4 messages

Jeanie Bourke <jmb@portlandmaine.gov>
To: dthibeau@marvinportland.com

Wed, Nov 30, 2016 at 2:38 PM

Hi Dave,

I am reviewing this permit and have a few questions for you regarding some code details. Once these are provided the permit will be issued in short order

1. The insulating factor of the glazing.
2. Are any of the windows in a hazard area that would require safety glazing, such as near stairs, tub/showers, doors, etc.
3. Are all of the sill heights above 24"? If not there will need to be hardware to restrict the amount of opening (barrier devices).
4. If windows are located in a bedroom, confirm that 1 window will have an opening size that complies with emergency escape and rescue per the SFM policy, see attached.

Let me know if you have any questions,

Thanks,

Jeanie Bourke
Code Enforcement Officer/Plan Reviewer

City of Portland
Permitting and Inspections Department
389 Congress St. Rm 315
Portland, ME 04101
jmb@portlandmaine.gov
(207)874-8715

 **Egress Window Replacement per SFM 11-1-13.pdf**
66K

Dave Thibeau <dthibeau@marvinportland.com>
To: Jeanie Bourke <jmb@portlandmaine.gov>

Wed, Nov 30, 2016 at 2:58 PM

Hi Jeanie,

See below for reply

Dave Thibeau

Millwork Specialist

Installation Specialist

Marvin Design Gallery by Eldredge

317 Marginal Way

Portland, ME 04101

Phone: (207) 772-2003

Fax: (207) 772-0418

Cell: (207) 337-5334

dthibeau@marvinportland.com

www.MarvinbyEldredge.com

like us on Facebook: [facebook.com/marvindesigngallerybyeldredge](https://www.facebook.com/marvindesigngallerybyeldredge)

follow us on Houzz: [Houzz.com/pro/marvin-design-gallery](https://www.houzz.com/pro/marvin-design-gallery)

The information in this electronic mail message is the sender's confidential business and may be legally privileged. It is intended solely for the addressee(s). Access to this internet electronic mail message by anyone else is unauthorized. If you are not the intended recipient, any disclosure, copying, distribution or any action taken or omitted to be taken in reliance on it is prohibited and may be unlawful.

From: Jeanie Bourke [mailto:jmb@portlandmaine.gov]

Sent: Wednesday, November 30, 2016 2:38 PM

To: dthibeau@marvinportland.com

Subject: 72 High St., BP# 2016-02727 replacement windows plan review comments

Hi Dave,

I am reviewing this permit and have a few questions for you regarding some code details. Once these are provided the permit will be issued in short order

1. The insulating factor of the glazing. Whereas this is in the historic district, we are using the Low E1, which gives a visible transmittance of about 72%

2. Are any of the windows in a hazard area that would require safety glazing, such as near stairs, tub/showers, doors, etc. These are not near any stairs, tub or shower and they are about 26" off the finished floor

3. Are all of the sill heights above 24"? If not there will need to be hardware to restrict the amount of opening (barrier devices). **Yes, they are above 24"**

4. If windows are located in a bedroom, confirm that 1 window will have an opening size that complies with emergency escape and rescue per the SFM policy, see attached. **These are sash kits that we're using. The clear opening measures about 33 ¼" x 30 ¼", giving us a net clear opening of 6.98 square feet.**

I believe that takes care of everything. Let me know if there is anything else you need. Thanks

Let me know if you have any questions,

Thanks,

Jeanie Bourke
Code Enforcement Officer/Plan Reviewer

City of Portland
Permitting and Inspections Department
389 Congress St. Rm 315
Portland, ME 04101
jmb@portlandmaine.gov
(207)874-8715

Notice: Under Maine law, documents - including e-mails - in the possession of public officials or city employees about government business may be classified as public records. There are very few exceptions. As a result, please be advised that what is written in an e-mail could be released to the public and/or the media if requested.

Jeanie Bourke <jmb@portlandmaine.gov>
To: Dave Thibeau <dthibeau@marvinportland.com>

Wed, Nov 30, 2016 at 3:09 PM

Thanks Dave,

By chance, what does this translate to for a U-factor?

Jeanie Bourke
Code Enforcement Officer/Plan Reviewer

City of Portland
Permitting and Inspections Department
389 Congress St. Rm 315
Portland, ME 04101
jmb@portlandmaine.gov
(207)874-8715

[Quoted text hidden]

Dave Thibeau <dthibeau@marvinportland.com>
To: Jeanie Bourke <jmb@portlandmaine.gov>

Wed, Nov 30, 2016 at 3:26 PM

The U-factor is at .30

Dave Thibeau

Millwork Specialist

Installation Specialist

Marvin Design Gallery by Eldredge

317 Marginal Way

Portland, ME 04101

Phone: (207) 772-2003

Fax: (207) 772-0418

Cell: (207) 337-5334

dthibeau@marvinportland.com

www.MarvinbyEldredge.com

like us on Facebook: [facebook.com/marvindesigngallerybyeldredge](https://www.facebook.com/marvindesigngallerybyeldredge)

follow us on Houzz: [Houzz.com/pro/marvin-design-gallery](https://www.houzz.com/pro/marvin-design-gallery)

The information in this electronic mail message is the sender's confidential business and may be legally privileged. It is intended solely for the addressee(s). Access to this internet electronic mail message by anyone else is unauthorized. If you are not the intended recipient, any disclosure, copying, distribution or any action taken or omitted to be taken in reliance on it is prohibited and may be unlawful.

From: Jeanie Bourke [mailto:jmb@portlandmaine.gov]

Sent: Wednesday, November 30, 2016 3:09 PM

To: Dave Thibeau <dthibeau@marvinportland.com>

Subject: Re: 72 High St., BP# 2016-02727 replacement windows plan review comments

[Quoted text hidden]