



© 2016 RYAN SENATORE ARCHITECTURE

OFFICE FIT-UP
622 CONGRESS STREET
PORTLAND, MAINE



RYAN SENATORE
ARCHITECTURE
565 CONGRESS STREET
PORTLAND, MAINE 04101
207-650-6414
senatorearchitecture.com

CONSULTANTS:

REVISIONS:

DATE: OCTOBER 31, 2016

PROJECT No. 1625

DRAWN BY: JPF, RJS

CHECKED BY: RJS

SCALE: AS NOTED

SHEET TITLE:

WALL ASSEMBLIES

A0-1

GRAPHIC DEPICTION		DESCRIPTION			
		- LAYER OF 5/8" GWB - 6" LIGHT GAUGE METAL STUDS AT 16" O.C. - 5 1/2" SOUND BATT INSULATION - LAYER OF 5/8" GWB			
		TYPE	FIRE RATING	UL NUMBER	STC RATING
NC		N/A	N/A		N/A

GRAPHIC DEPICTION		DESCRIPTION			
		- LAYER OF 5/8" GWB - 3 5/8" LIGHT GAUGE METAL STUDS AT 16" O.C. - 3 1/2" SOUND BATT INSULATION - 1/2" RESILIENT SOUND CHANNEL @ 24" O.C. - LAYER OF 5/8" GWB			
		TYPE	FIRE RATING	UL NUMBER	STC RATING
NF		N/A	N/A		N/A

GRAPHIC DEPICTION		DESCRIPTION			
		- LAYER OF 5/8" GWB - 3 5/8" LIGHT GAUGE METAL STUDS AT 16" O.C. - 3 1/2" SOUND BATT INSULATION - LAYER OF 5/8" GWB			
		TYPE	FIRE RATING	UL NUMBER	STC RATING
NB		N/A	N/A		N/A

GRAPHIC DEPICTION		DESCRIPTION			
		- LAYER OF 5/8" GWB - 6" LIGHT GAUGE METAL STUDS AT 24" O.C. - 5 1/2" SOUND BATT INSULATION - FUR OUT TO MATCH EXISTING WALL THICKNESS - LAYER OF 5/8" GWB			
		TYPE	FIRE RATING	UL NUMBER	STC RATING
NE		N/A	N/A		N/A

GRAPHIC DEPICTION		DESCRIPTION			
		- LAYER OF 5/8" GWB - 3 5/8" LIGHT GAUGE METAL STUDS AT 16" O.C. - LAYER OF 5/8" GWB			
		TYPE	FIRE RATING	UL NUMBER	STC RATING
NA		N/A	N/A		N/A

GRAPHIC DEPICTION		DESCRIPTION			
		- LAYER OF TYPE 'X' 5/8" GWB - 3 5/8" LIGHT GAUGE METAL STUDS AT 24" O.C. - 3 1/2" SOUND BATT INSULATION - LAYER OF TYPE 'X' 5/8" GWB			
		TYPE	FIRE RATING	UL NUMBER	STC RATING
1A		1 HR	V450	50-54	N/A

GRAPHIC DEPICTION		DESCRIPTION			
		- LAYER OF 5/8" GWB - 3 5/8" LIGHT GAUGE METAL STUDS AT 24" O.C. - 3 1/2" SOUND BATT INSULATION - FUR OUT TO MATCH EXISTING WALL THICKNESS - LAYER OF 5/8" GWB			
		TYPE	FIRE RATING	UL NUMBER	STC RATING
ND		N/A	N/A		N/A

WALL TYPE NOTES	
1.) REFER TO STRUCTURAL DRAWINGS FOR STUD SIZE AND SPACING 2.) INSTALL WATER RESISTANT GYPSUM WALLBOARD IN ALL RESTROOMS AND TOILET ROOM WALLS AND CEILINGS, AND AT ANY WALL WITH PLUMBING FIXTURES 3.) PROVIDE 3/4" GWB BEHIND ALL TUBS AND SHOWERS AT EXTERIOR WALLS AND FIRE RATED ASSEMBLIES. PROVIDE ADDITIONAL LAYER OF GWB TO COVER TUB AND SHOWER FLANGE. EXTEND ADDED LAYER ALONG ADJACENT WALLS AND ADJUST DOOR JAMB WIDTHS AS REQUIRED. 4.) WHEN TWO ADJACENT WALL TYPES HAVE DIFFERING NUMBERS OF LAYERS OF GWB, THE FINISHED FACE OF GWB MUST FORM ONE CONTINUOUS PLANE, ADJUST STUD PLANE LOCATION AS REQUIRED TO ACHIEVE THE CONTINUOUS PLANE 5.) HOLD BOTTOM OF GWB UP 1/2" FROM CONCRETE, PROVIDE SEALANT AT JOINT. 6.) ALL WALL TYPES WITH AN INSULATION COMPONENT TO BE ACOUSTICALLY SEALED	