

EASTERN FIRE



PROTECTION

FIRE SPRINKLER CONTRACTORS AND DESIGNERS

MEMO

DATE: 06/13/2017

TO: Gerry Leach

FROM: James Lemay

SUBJECT: 622 Congress St, Portland Maine

Gerry,

This memo is to inform you that no hydraulic calculations were performed on the 622 Congress St. project due to the scope of the project which was re-working the existing sprinkler system to accommodate the new floor plan. Pipe sizing is per existing pipe schedule.

If you have any questions concerning this correspondence feel free to contact me.

Sincerely,

**James Lemay
System Designer, Eastern Fire Protection**

TOTAL PAGES: 1

207-784-1507 Fax: 207.782.0566
P.O. Box 1390 Auburn, Maine 04211-1390

TOTAL PAGES: 1

207-784-1507 Fax: 207.782.0566
P.O. Box 1390 Auburn, Maine 04211-1390