Reviewed for Code Compliance
Inspections Division
City of Portland, Maine
Date: 07/12/17



THIRD FLOOR

Sprinkler Head Schedule					
Symbol	Count	Thread	K-Factor	Description	Note
⊙	20	1/2"	5.6	NEW RELIABLE F1FR56 SEMI-RECESSED PENDENT	on Drop
○	19	1/2"	5.6	NEW RELIABLE F1FR56 BRASS UPRIGHT 200°	ON LINE
⊙	10	1/2"	5.6	EXISTING SR	
⊗	15	1/2"	5.6	EXISTING QR	
64 = Total Number of Heads This Floor					



SECOND FLOOR

Sprinkler Head Schedule					
Symbol	Count	Thread	K-Factor	Description	Note
⊙	7	1/2"	5.6	NEW RELIABLE F1FR56 SEMI-RECESSED PENDENT	on Drop
○	36	1/2"	5.6	NEW RELIABLE F1FR56 BRASS UPRIGHT 200°	ON LINE
⊙	1	1/2"	5.6	EXISTING SR	
⊗	1	1/2"	5.6	EXISTING QR	
45 = Total Number of Heads This Floor					

DATE	REVISIONS	REQUIRED APPROVALS	622 CONGRESS ST.	FIRE SPRINKLER PLANS & DETAILS
			622 CONGRESS STREET, PORTLAND MAINE	DWG. NO. 1 OF 1
		DRAWN BY JML	CONTRACT WITH: NORTHLAND MANAGMENT CORP.	JOB NUMBER 5615
		NICET LEVEL CERT.#	EASTERN FIRE PROTECTION	
		CHECKED BY		SCALE AS NOTED
		NICET LEVEL CERT.#		
		CONTRACTOR LICENSE # 101	AUBURN/LEWISTON INDUSTRIAL AIRPARK, AUBURN, MAINE 04210	DATE 06/22/2017
		CONTRACTOR RMS # 368		