

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that

614 CONGRESS STREET LLC

Located at

616 CONGRESS ST (618 Congress)

PERMIT ID: 2016-02643

ISSUE DATE: 12/20/2016

CBL: 039 A005001

has permission to **For the installation of a commercial kitchen hood system.**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

| | |
|---|--|
| Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 HOUR NOTICE IS REQUIRED. | A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy. |
|---|--|

/s/ Michael White

Fire Official

/s/ Michael Russell, MS, Director

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

Building Inspections

Fire Department

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

**Check the Status or Schedule an Inspection On-Line at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the City of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that are attached to this permit! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases 6 months.**
- **If the inspection requirements are not followed as stated below, additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**

REQUIRED INSPECTIONS:

Final - Commercial

Final - Fire

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

| | | | | |
|--|--|---|--|----------------------------|
| City of Portland, Maine - Building or Use Permit | | Permit No: 2016-02643 | Date Applied For: 10/07/2016 | CBL: 039 A005001 |
| 389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716 | | | | |
| Proposed Use: Restaurant | | Proposed Project Description: For the installation of a commercial kitchen hood system. | | |
| Dept: Historic Status: Approved w/Conditions Reviewer: Robert Wiener Approval Date: 12/05/2016 Note: Ok to Issue: <input checked="" type="checkbox"/> Conditions: 1) This permit is for the hood only; no other exterior alterations are approved, and items such as windows, doors, exterior lighting, etc. must be reviewed and reviewed separately under other application(s). 2) HP staff understands the exterior duct work and associated equipment is to be painted a color to match the color of the masonry wall, in a dull, matte finish. | | | | |
| Dept: Zoning Status: Approved Reviewer: Jennifer Thompson Approval Date: 12/20/2016 Note: Ok to Issue: <input checked="" type="checkbox"/> Conditions: | | | | |
| Dept: Fire Status: Approved w/Conditions Reviewer: Michael White Approval Date: 10/14/2016 Note: Ok to Issue: <input checked="" type="checkbox"/> Conditions: 1) All construction shall comply with 2009 NFPA 1, Fire Code. Review and approval by the AHJ shall not relieve the applicant of the responsibility of compliance with this Code (Chapter 1.14.4). 2) All construction shall comply with City Code, Chapter 10. 3) All installations shall comply with 2009 NFPA 101, Chapter 9, Building Service and Fire Protection Equipment, NFPA 17A, NFPA 96, UL 300, as well as in accordance with the terms of appliance listings and manufacture instructions. Activation of the suppression system shall activate the fire alarm system if available. A letter of compliance will be required at the time of final inspection stating: the date the system was tested for operation, fuel gas shut off, and fire alarm connection if applicable. The Class K fire extinguisher and proper signage should be located at the suppression system pull station. | | | | |