

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that

614 CONGRESS STREET LLC

Located at

616 CONGRESS ST (#618)

PERMIT ID: 2017-00146

ISSUE DATE: 05/31/2017

CBL: 039 A005001

has permission to **2017 New Outdoor Seating- 6 Tables 12 Chairs**
(approved for 102SF)

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 hour notice is required.

A final inspection must be completed before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

N/A

/s/ Tom Williams

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

Building Inspections

Fire Department

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703
or email: buildinginspections@portlandmaine.gov

**Check the Status of Permit or Schedule an Inspection at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the City of Portland Inspections Division for the inspections listed below. Appointments must be requested 48 to 72 hours in advance. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that are attached to this permit.**
- **Permits expire in 6 months if the project is not started or ceases for 6 months.**
- **If the inspection requirements below are not followed, then additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC), one set of printed approved stamped construction documents will be kept at the site of work and open to inspection by building officials.**

REQUIRED INSPECTIONS:

Outside Dining - New

The project cannot move to the next phase prior to the required inspection and approval to continue.

If the permit requires a certificate of occupancy, it must be paid and issued to the owner or designee before the space may be occupied.

City of Portland, Maine - Building or Use Permit		Permit No: 2017-00146	Date Applied For: 02/01/2017	CBL: 039 A005001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Same: Restaurant "Lazzari"		Proposed Project Description: 2017 New Outdoor Seating- 6 Tables 12 Chairs (approved for 102SF)		
Dept: Historic		Status: Not Applicable	Reviewer: Deborah Andrews	Approval Date: 04/19/2017
Note:		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:				
Dept: Zoning		Status: Approved w/Conditions	Reviewer: Jennifer Thompson	Approval Date: 02/10/2017
Note: Per application: Sidewalk width = 11'. Tables and chairs to occupy 6'6", leaving 4'6" for passing.		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:				
1) ANY exterior work requires a separate review and approval thru Historic Preservation. This property is located within an Historic District.				
2) All outdoor seating is subject to adjustment at any time from the City's traffic engineer who ensures that the City sidewalk is open and cleared for pedestrian use.				
Dept: Building Inspecti		Status: Approved w/Conditions	Reviewer: Tom Williams	Approval Date: 05/31/2017
Note:		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:				
1) This permit approves outdoor seating only. Any alcohol or entertainment in this space requires licensing approvals from Business Licensing.				
2) The outdoor seating permit is approved for the area delineated at the inspection and stated on the permit, and must be kept on site. This permit must be renewed annually.				
3) The tables and chairs must not block any means of egress of any building, even during storage.				