

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



# CITY OF PORTLAND

# BUILDING PERMIT

This is to certify that  
FREEDOM FIRE PROTECTION  
209 QUAKER RIDGE RD  
CASCO, ME 04015

For installation at  
606 CONGRESS ST

Job ID: 2011-11-2699-FAFS


CBL: 039- A-010-001

has permission to install an automatic sprinkler system

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be

  
Fire Prevention Officer

58

Code Enforcement Officer / Plan Reviewer

THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY  
PENALTY FOR REMOVING THIS CARD

## BUILDING PERMIT INSPECTION PROCEDURES

Please call 874-8703 or 874-8693 (ONLY)

or email: [buildinginspections@portlandmaine.gov](mailto:buildinginspections@portlandmaine.gov)

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**

### **Final Fire**

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.



# PORTLAND MAINE

*Strengthening a Remarkable City, Building a Community for Life* • [www.portlandmaine.gov](http://www.portlandmaine.gov)

Director of Planning and Urban Development  
Penny St. Louis

Job ID: 2011-11-2699-FAFS  
install an automatic sprinkler system

For installation at:  
.606 CONGRESS ST

CBL: 039- A-010-001

## **Conditions of Approval:**

### **Fire**

The sprinkler system shall be installed in accordance with NFPA 13. A signed compliance letter will be required.

A separate sprinkler permit is required from the State Fire Marshal's Office.

Sprinkler protection shall be maintained. Where the system is to be shut down for maintenance or repair, the system shall be checked at the end of each day to insure the system has been placed back in service.

Fire department connection shall be single 2 ½ inch. The Fire Department will require a Knox locking cap on the Fire Department Connection.

System acceptance and commissioning must be coordinated with alarm and suppression system contractors and the Fire Department. Call 874-8703 to schedule.

A 4100 series Knox Box is required.

**City of Portland, Maine - Building or Use Permit Application**

389 Congress Street, 04101 Tel: (207) 874-8703, FAX: (207) 8716

Job No: 2011-11-2699-FAFS	Date Applied: 10/28/2011	CBL: 039- A-010-001	
Location of Construction: 606 CONGRESS ST	Owner Name: GEOFFREY I RICE	Owner Address: 658 CONGRESS ST 1ST FLOOR PORTLAND, ME 04101	Phone:
Business Name:	Contractor Name: William Wales @ Freedom Fire Protection, Inc.	Contractor Address: 209 Quaker Ridge, Casco, ME 04015	Phone: (207) 671 -8639
Lessee/Buyer's Name:	Phone:	Permit Type: FIRE ALARM - Fire Alarm	Zone: B-3
Past Use: 1 <sup>st</sup> floor restaurant with 2 dwelling units above	Proposed Use: Same: 1 <sup>st</sup> floor restaurant with 2 dwelling units above – to install fire suppression system	Cost of Work: \$19,000.00	CEO District:
		Fire Dept: <input checked="" type="checkbox"/> Approved w/ conditions <input type="checkbox"/> Denied <input type="checkbox"/> N/A	Inspection: Use Group: Type:
Proposed Project Description: Mixed Commercial Use		Signature: <i>[Signature]</i> (58)	
		Pedestrian Activities District (P.A.D.)	

Permit Taken By: Lannie

**Zoning Approval**

1. This permit application does not preclude the Applicant(s) from meeting applicable State and Federal Rules.
2. Building Permits do not include plumbing, septic or electrical work.
3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work.

**Special Zone or Reviews**

- Shoreland
- Wetlands
- Flood Zone
- Subdivision
- Site Plan

\_\_\_ Maj \_\_\_ Min \_\_\_ MM  
Date: *OK [Signature]*  
*11/14/11*

**CERTIFICATION**

**Zoning Appeal**

- Variance
- Miscellaneous
- Conditional Use
- Interpretation
- Approved
- Denied

Date:

**Historic Preservation**

- within*
- Not in Dist or Landmark
  - Does not Require Review
  - Requires Review
  - Approved
  - Approved w/Conditions
  - Denied

Date: *any exterior work requires a separate review & approval*

SIGNATURE OF APPLICANT

ADDRESS

DATE

PHONE

RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE

DATE

PHONE

2011-11-2699



# Water-Based Fire Suppression System Permit

If you or the property owner owes real estate or property taxes or user charges on any property within the city, payment arrangements must be made before permits of any kind are accepted.

1st floor Rest.

Installation address: 606 Congress Street CBL: 039 A 010

Exact location: (within structure) Basement, First, Second, and Third levels

Type of occupancy(s) (NFPA & ICC): Mixed - Mercantile & Apartment

Building owner: Geoffrey Rice (Rice Management)

Managing Supervisor (RMS): Timothy Vess License No: 348

Supervisor phone: 207/627-4109 E-mail: wwales@maine.rr.com

Installing contractor: Freedom Fire Protection, Inc. License No: 295

Contractor phone: 207/671-8639 E-mail: wwales@maine.rr.com

The suppression work to be done will be: New:  Renovation:  Addition to existing system:

This is an amendment to an existing permit: Yes:  NO:  Permit no: \_\_\_\_\_

NFPA Standard this system is designed to: 13 & 13R Edition: 2007

\*Non-NFPA systems are not approved for use within the City of Portland.

Download a new copy of this document from [www.portlandmaine.gov/fire](http://www.portlandmaine.gov/fire) for every submittal. Attach all working documents and complete approved submittals as may be required by the State Fire Marshal's Office on electronic PDF's in addition to full sized plans.

Contractor shall verify location and type of all FDCs shall be approved in writing by the Fire Prevention Bureau.

<b>COST OF WORK:</b> \$18,669.00
<b>PERMIT FEE:</b> \$210
(\$10 PER \$1,000 + \$30 FOR THE FIRST \$1,000)
<b>RECEIVED</b>
OCT 28 2011
Dept. of Building Inspections City of Portland Maine

Submit all information to the Building Inspections Department, 389 Congress Street, Room 315, Portland, Maine 04101.

Prior to acceptance of any fire protection system, a complete commissioning and acceptance test must be coordinated with all fire system contractors and the Fire Department, and proper documentation of such test(s) provided.

All installation(s) must comply with NFPA and the Fire Department Technical Standard(s).

Applicant signature: William W. Wales Date: July 6, 2011

Freedom Fire Prot.  
209 Quaker Ridge Rd Casco ME 04015

11-17-11  
Wales

# Freedom Fire Protection, Inc.

*30 Years of Fire Protection Experience*

209 Quaker Ridge Road

Casco, Maine 04015

Phone (207) 627-4109 Fax (207) 627-7340

July 6, 2011

Portland City Hall  
Third Floor Room #315  
Portland, Maine 04101

Attention: Captain Keith Gautreau

Ref: 606 Congress Street  
Portland, Maine 04101

Subject: Fire Sprinkler Plan Review

Enclosed please find for your review and comment the following sprinkler information.

- Fire Suppression System Permit
- Permit Fee check
- Freedom Fire Protections drawings FP1, FP2
- 1 set of 8-1/2 x 11 PDF sprinkler plans.
- Hydraulic Calculations Area #1 and Area #2.
- Copy of the State Fire Marshall's sprinkler permit (to follow).

Please get in touch with me to discuss any questions or if you need additional information.

Regards,



William Wales

(O) 207-627-4109

(F) 207-627-7340

(C) 207-671-8639

E-mail [wwales@maine.rr.com](mailto:wwales@maine.rr.com)



**State of Maine**  
**Department of Public Safety**  
**Fire Sprinkler System Permit**



# 9571

**606 CONGRESS STREET**

Located at: 606 CONGRESS STREET  
 In the Town of: Portland  
 Occupancy/Use: TAVERN  
 Type of System: NFPA 13

Permission is hereby given to:

**Freedom Fire Protection, Inc.**  
 209 Quaker Ridge Road  
 Casco, ME 04015  
 Contractor License # 295

to begin installation according to plans submittal approved by the Office of State Fire Marshal. The submittal is filed under log # 2111229 , and no departure from the application submittal shall be made without prior approval in writing. This permit is issued under the provisions of Title 32, Chapter 20, Section 12004-I. Nothing herein shall excuse the holder of this permit from failure to comply with local ordinances, zoning laws, or other pertinent legal restrictions. This permit shall be displayed at the construction site or be made readily available.

This permit was issued on 7/13/2011 for a fee paid of \$100.00

*This permit will expire at midnight on Monday, January 09, 2012*

The expiration date applies only if the installation has not begun by that date and no permission has been granted to extend the date. Once installation begins, then the permit is valid for however long it takes to complete the installation, assuming that the work is fairly continuous.

John E. Morris  
 Commissioner

***The type of Fire Department Connection and its location is to be according to the Local Fire Department***

Within 30 days of the completion of a new fire sprinkler system or an addition to an existing fire sprinkler system, a fire sprinkler system contractor shall provide to the Office of State Fire Marshal a copy of this permit signed and dated by the certified Responsible Managing Supervisor representing that the fire sprinkler system has been installed according to specifications of the approved plan to the best of the supervisor's knowledge, information, and belief. This requirement is part of the sprinkler law, and neglect of this duty is grounds to not renew the contractor's license to do work in the State of Maine. All renewed sprinkler licenses are good for two years and expire on a June 30th.

Job completed, tested and verified by date of \_\_\_\_\_

RMS for this job: Vess Timothy L.

RMS Signature: \_\_\_\_\_



... Fire Protection by Computer Design

FREEDOM FIRE PROTECTION INC.  
209 QUAKER RIDGE ROAD  
CASCO, MAINE 04015  
207-627-4109

Job Name : 606 CONGRESS STREET HC1  
Building : 606 CONGRESS STREET  
Location : PORTLAND, MAINE 04101  
System : #1 AREA #1  
Contract :  
Data File :




# Water Supply Curve (C)

FREEDOM FIRE PROTECTION INC.  
606 CONGRESS STREET HC1

Page 2  
Date 3/2/12

City Water Supply:  
C1 - Static Pressure : 71  
C2 - Residual Pressure: 62  
C2 - Residual Flow : 992

Demand:  
D1 - Elevation : 17.610  
D2 - System Flow : 111.678  
D2 - System Pressure : 62.307  
Hose (Adj City) :  
Hose (Demand) : 100  
D3 - System Demand : 211.678  
Safety Margin : 8.177



Pressure / Flow Summary - STANDARD

FREEDOM FIRE PROTECTION INC.  
606 CONGRESS STREET HC1

Page 4  
Date 3/2/12

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
102	40.66	4.2	12.53	na	14.87	0.1	0.001	11.1
101	40.66	4.2	13.34	na	15.34	0.1	0.001	11.1
30	40.66		19.61	na				
103	40.66	4.2	21.4	na	19.43	0.1	0.001	11.1
104	40.66	4.2	18.82	na	18.22	0.1	0.001	11.1
105	40.66	4.2	13.61	na	15.49	0.1	0.001	11.1
106	40.66	4.2	11.65	na	14.34	0.1	0.001	11.1
107	40.66	4.2	11.1	na	13.99	0.1	0.001	11.1
22	40.66		11.48	na				
21	40.66		12.25	na				
20	40.66		14.07	na				
19	40.66		19.43	na				
18	40.66		22.1	na				
17	40.66		24.31	na				
16	31.66		30.2	na				
15	31.66		32.35	na				
14	31.66		33.92	na				
13	22.66		38.66	na				
12	20.0		40.55	na				
11	20.0		41.67	na				
10	8.5		47.35	na				
9	8.5		50.44	na				
8	8.5		51.98	na				
7	0.0		56.21	na				
6	0.0		59.52	na				
5	8.5		56.39	na				
4	8.5		57.96	na				
3	2.5		61.11	na				
2	0.0		62.22	na				
1	0.0		62.22	na				
TEST	0.0		62.31	na	100.0			

The maximum velocity is 16.27 and it occurs in the pipe between nodes 20 and 19

Final Calculations - Hazen-Williams

FREEDOM FIRE PROTECTION INC.  
606 CONGRESS STREET HC1

Page 5  
Date 3/2/12

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	***** Notes *****
102 to 101	14.87	1.049 120	1E 2.0 0.0	8.660 2.000	12.534 0.0		K Factor = 4.20 Vel = 5.52
101 to 30	15.34	1.049 120	1E 2.0 1T 5.0	15.481 7.000	13.336 0.0		K Factor = 4.20 Vel = 11.21
30 to 17	30.21	0.2790	0.0	22.481	6.273		Vel = 11.21
30 to 17	0.0	1.049 120	1E 2.0 0.0	14.830 2.000	19.609 0.0		Vel = 11.21
	30.21	0.2791	0.0	16.830	4.697		Vel = 11.21
	0.0						
	30.21				24.306		K Factor = 6.13
103 to 18	19.43	1.049 120	1T 5.0 0.0	0.660 5.000	21.400 0.0		K Factor = 4.20 Vel = 7.21
	0.0	0.1233	0.0	5.660	0.698		Vel = 7.21
	19.43						
					22.098		K Factor = 4.13
104 to 19	18.22	1.049 120	1T 5.0 0.0	0.660 5.000	18.815 0.0		K Factor = 4.20 Vel = 6.76
	18.22	0.1095	0.0	5.660	0.620		Vel = 6.76
	0.0						
	18.22				19.435		K Factor = 4.13
105 to 20	15.49	1.049 120	1T 5.0 0.0	0.660 5.000	13.610 0.0		K Factor = 4.20 Vel = 5.75
	15.49	0.0813	0.0	5.660	0.460		Vel = 5.75
	0.0						
	15.49				14.070		K Factor = 4.13
106 to 21	14.34	1.049 120	1T 5.0 0.0	3.583 5.000	11.650 0.0		K Factor = 4.20 Vel = 5.32
	14.34	0.0703	0.0	8.583	0.603		Vel = 5.32
	0.0						
	14.34				12.253		K Factor = 4.10
107 to 22	13.99	1.049 120	1T 5.0 0.0	0.660 5.000	11.100 0.0		K Factor = 4.20 Vel = 5.19
	13.99	0.0671	0.0	5.660	0.380		Vel = 5.19
22 to 21	0.0	1.049 120	2E 4.0 0.0	7.500 4.000	11.480 0.0		Vel = 5.19
	13.99	0.0672	0.0	11.500	0.773		Vel = 5.19
21 to 20	14.34	1.049 120	0.0 0.0	7.330 0.0	12.253 0.0		Vel = 10.52
	28.33	0.2479	0.0	7.330	1.817		Vel = 10.52
20 to 19	15.49	1.049 120	0.0 0.0	9.660 0.0	14.070 0.0		Vel = 16.27
	43.82	0.5554	0.0	9.660	5.365		Vel = 16.27

Final Calculations - Standard

FREEDOM FIRE PROTECTION INC.  
606 CONGRESS STREET HC1

Page 6  
Date 3/2/12

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	***** Notes *****
19	18.22	1.38		9.583	19.435		
to		120		0.0	0.0		
18	62.04	0.2779		9.583	2.663		Vel = 13.31
18	19.43	1.61	1T	8.0	2.166	22.098	
to		120		0.0	8.000	0.0	
17	81.47	0.2172		10.166	2.208		Vel = 12.84
17	30.21	2.157	1T	12.307	9.000	24.306	
to		120		0.0	12.307	3.898	
16	111.68	0.0936		21.307	1.995		Vel = 9.81
16	0.0	2.157	1T	12.307	10.660	30.199	
to		120		0.0	12.307	0.0	
15	111.68	0.0937		22.967	2.151		Vel = 9.81
15	0.0	2.157	1E	6.153	10.583	32.350	
to		120		0.0	6.153	0.0	
14	111.68	0.0937		16.736	1.568		Vel = 9.81
14	0.0	2.157		9.000	33.918		
to		120		0.0	0.0	3.898	
13	111.68	0.0937		9.000	0.843		Vel = 9.81
13	0.0	2.157	1E	9.298	2.660	38.659	
to		150		0.0	9.298	1.152	
12	111.68	0.0620		11.958	0.741		Vel = 9.81
12	0.0	2.157	1E	6.153	5.830	40.552	
to		120		0.0	6.153	0.0	
11	111.68	0.0936		11.983	1.122		Vel = 9.81
11	0.0	2.635	1E	8.237	11.500	41.674	
to		120		0.0	8.237	4.981	
10	111.68	0.0353		19.737	0.697		Vel = 6.57
10	0.0	2.635	2E	16.474	54.330	47.352	
to		120	1T	16.474	32.948	0.0	
9	111.68	0.0353		87.278	3.084		Vel = 6.57
9	0.0	2.635	2E	16.474	10.660	50.436	
to		120	1T	16.474	32.948	0.0	
8	111.68	0.0353		43.608	1.541		Vel = 6.57
8	0.0	2.635	1E	8.237	7.500	51.977	
to		120		0.0	8.237	3.681	
7	111.68	0.0353		15.737	0.556		Vel = 6.57
7	0.0	2.635	1E	8.237	2.000	56.214	
to		120	1Zac	0.0	8.237	2.940	* Fixed loss = 2.94
6	111.68	0.0354		10.237	0.362		Vel = 6.57
6	0.0	2.635	1E	8.237	7.500	59.516	
to		120		0.0	8.237	-3.681	
5	111.68	0.0353		15.737	0.556		Vel = 6.57

Final Calculations - Standard

FREEDOM FIRE PROTECTION INC.  
606 CONGRESS STREET HC1

Page 7  
Date 3/2/12

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	***** Notes *****
5	0.0	2.635	3E 24.711	19.660	56.391		
to		120	0.0	24.711	0.0		
4	111.68	0.0353	0.0	44.371	1.567		Vel = 6.57
4	0.0	2.635	1B 9.61	6.000	57.958		
to		120	0.0	9.610	2.599		
3	111.68	0.0354	0.0	15.610	0.552		Vel = 6.57
3	0.0	6.16	1T 43.037	15.000	61.109		
to		140	1G 4.304	47.341	1.083		
2	111.68	0.0004	0.0	62.341	0.026		Vel = 1.20
2	0.0	16.41	1T 166.859	100.000	62.218		
to		140	2E 164.8	331.660	0.0		
1	111.68	0.0	0.0	431.660	0.001		Vel = 0.17
1	0.0	8.27	1T 55.354	750.000	62.219		
to		140	2E 56.936	112.290	0.0		
TEST	111.68	0.0001	0.0	862.290	0.088		Vel = 0.67
	100.00						Qa = 100.00
	211.68				62.307		K Factor = 26.82



... Fire Protection by Computer Design

FREEDOM FIRE PROTECTION INC.  
209 QUAKER RIDGE ROAD  
CASCO, MAINE 04015  
207-627-4109

Job Name : 606 CONGRESS STREET HC2  
Building : 606 CONGRESS STREET  
Location : PORTLAND, MAINE 04101  
System : #1 AREA #2  
Contract :  
Data File : 606 CONGRESS STREET HC2.WXF

Hydraulic Design Information Sheet

Name - 606 CONGRESS STREET Date - 1/2/12  
Location - PORTLAND, MAINE 04101  
Building - 606 CONGRESS STREET System No. - #1 AREA #2  
Contractor - Contract No. -  
Calculated By - MIKE NOBLIT Drawing No. - FP-2  
Construction: (X) Combustible ( ) Non-Combustible Ceiling Height - 11'-5"  
Occupancy - TAVERN

S (X) NFPA 13 ( ) Lt. Haz. Ord.Haz.Gp. ( ) 1 (X) 2 ( ) 3 ( ) Ex.Haz.  
Y ( ) NFPA 231 ( ) NFPA 231C ( ) Figure Curve

S Other

T Specific Ruling Made By Date

E  
M Area of Sprinkler Operation - ROOM System Type Sprinkler/Nozzle  
Density - 0.20 (X) Wet Make TYCO  
D Area Per Sprinkler - 130 ( ) Dry Model TY-FRB  
E Elevation at Highest Outlet - 22'-8" ( ) Deluge Size 1/2"  
S Hose Allowance - Inside - ( ) Preaction K-Factor 5.6  
I Rack Sprinkler Allowance - ( ) Other Temp.Rat.155  
G Hose Allowance - Outside - 250  
N

Note

Calculation Flow Required - 387.311 Press Required - 60.340 At Test  
Summary C-Factor Used: 120 Overhead 140 Underground

W Water Flow Test: Pump Data: Tank or Reservoir:  
A Date of Test - 5/8/2010 Cap. -  
T Time of Test - Rated Cap.- Elev.-  
E Static Press - 71 @ Press -  
R Residual Press - 62 Elev. - Well  
Flow - 992 Proof Flow  
S Elevation - 0

U Location -

P  
L Source of Information - PORTLAND WATER DISTRICT  
Y


# Water Supply Curve (C)

FREEDOM FIRE PROTECTION INC.  
606 CONGRESS STREET HC2

Page 2  
Date 1/2/12

City Water Supply:  
C1 - Static Pressure : 71  
C2 - Residual Pressure: 62  
C2 - Residual Flow : 992

Demand:  
D1 - Elevation : 9.814  
D2 - System Flow : 137.311  
D2 - System Pressure : 60.340  
Hose ( Adj City ) :  
Hose ( Demand ) : 250  
D3 - System Demand : 387.311  
Safety Margin : 9.080





# Fittings Used Summary

FREEDOM FIRE PROTECTION INC.  
606 CONGRESS STREET HC2

Page 3  
Date 1/2/12

Fitting Legend		1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
Abbrev.	Name																				
B	Generic Butterfly Valve	0	0	0	0	0	0	7	10	0	12	9	10	12	19	21	0	0	0	0	0
E	90' Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
G	Generic Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
T	90' Flow Thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Zac	Ames 2000SS	Fitting generates a Fixed Loss Based on Flow																			

Pressure / Flow Summary - STANDARD

FREEDOM FIRE PROTECTION INC.  
606 CONGRESS STREET HC2

Page 4  
Date 1/2/12

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
205	22.66	5.6	21.56	na	26.0	0.2	130	7.0
204	22.66	5.6	22.75	na	26.71	0.2	130	7.0
203	22.66	5.6	23.9	na	27.38	0.2	130	7.0
202	22.66	5.6	25.09	na	28.05	0.2	130	7.0
201	22.66	5.6	27.15	na	29.18	0.2	130	7.0
30	22.66		30.57	na				
13	22.66		31.74	na				
12	20.0		33.98	na				
11	20.0		35.63	na				
10	8.5		41.63	na				
9	8.5		46.15	na				
8	8.5		48.41	na				
7	0.0		52.9	na				
6	0.0		56.25	na				
5	8.5		53.38	na				
4	8.5		55.68	na				
3	2.5		59.09	na				
2	0.0		60.21	na				
1	0.0		60.21	na				
TEST	0.0		60.34	na	250.0			

The maximum velocity is 17.04 and it occurs in the pipe between nodes 202 and 201

Final Calculations - Hazen-Williams

FREEDOM FIRE PROTECTION INC.  
606 CONGRESS STREET HC2

Page 5  
Date 1/2/12

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftnng's Total	Pt Pe Pf	Pt Pv Pn	***** Notes *****
205 to 204	26.00 26.0	1.049 150 0.1400	0.0 0.0 0.0	8.500 0.0 8.500	21.556 0.0 1.190		K Factor = 5.60 Vel = 9.65
204 to 203	26.71 52.71	1.38 150 0.1360	0.0 0.0 0.0	8.500 0.0 8.500	22.746 0.0 1.156		K Factor = 5.60 Vel = 11.31
203 to 202	27.38 80.09	1.61 150 0.1392	0.0 0.0 0.0	8.500 0.0 8.500	23.902 0.0 1.183		K Factor = 5.60 Vel = 12.62
202 to 201	28.04 108.13	1.61 150 0.2427	0.0 0.0 0.0	8.500 0.0 8.500	25.085 0.0 2.063		K Factor = 5.60 Vel = 17.04
201 to 30	29.18 137.31	2.067 150 0.1118	1T 15.111 0.0 0.0	15.538 15.111 30.649	27.148 0.0 3.426		K Factor = 5.60 Vel = 13.13
30 to 13	0.0 137.31	2.067 150 0.1117	1E 7.555 0.0 0.0	2.916 7.555 10.471	30.574 0.0 1.170		Vel = 13.13
13 to 12	0.0 137.31	2.157 150 0.0909	1E 9.298 0.0 0.0	2.660 9.298 11.958	31.744 1.152 1.087		Vel = 12.06
12 to 11	0.0 137.31	2.157 120 0.1373	1E 6.153 0.0 0.0	5.830 6.153 11.983	33.983 0.0 1.645		Vel = 12.06
11 to 10	0.0 137.31	2.635 120 0.0517	1E 8.237 0.0 0.0	11.500 8.237 19.737	35.628 4.981 1.021		Vel = 8.08
10 to 9	0.0 137.31	2.635 120 0.0518	2E 16.474 1T 16.474 0.0	54.330 32.948 87.278	41.630 0.0 4.520		Vel = 8.08
9 to 8	0.0 137.31	2.635 120 0.0518	2E 16.474 1T 16.474 0.0	10.660 32.948 43.608	46.150 0.0 2.258		Vel = 8.08
8 to 7	0.0 137.31	2.635 120 0.0519	1E 8.237 0.0 0.0	7.500 8.237 15.737	48.408 3.681 0.816		Vel = 8.08
7 to 6	0.0 137.31	2.635 120 0.0518	1E 8.237 1Zac 0.0 0.0	2.000 8.237 10.237	52.905 2.815 0.530		* Fixed loss = 2.815 Vel = 8.08
6 to 5	0.0 137.31	2.635 120 0.0517	1E 8.237 0.0 0.0	7.500 8.237 15.737	56.250 -3.681 0.814		Vel = 8.08

Final Calculations - Standard

FREEDOM FIRE PROTECTION INC.  
606 CONGRESS STREET HC2

Page 6  
Date 1/2/12

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
5	0.0	2.635	3E 24.711	19.660	53.383				
to 4	137.31	120 0.0518	0.0	24.711	0.0				
4	0.0	2.635	1B 9.61	6.000	55.681				
to 3	137.31	120 0.0518	0.0	9.610	2.599		Vel = 8.08		
3	0.0	6.16	1T 43.037	15.000	59.088				
to 2	137.31	140 0.0006	1G 4.304	47.341	1.083		Vel = 1.48		
2	0.0	16.41	1T 166.859	100.000	60.210				
to 1	137.31	140 0.0	2E 164.8	331.660	0.0		Vel = 0.21		
1	0.0	8.27	1T 55.354	750.000	60.212				
to TEST	137.31	140 0.0001	2E 56.936	112.290	0.0		Vel = 0.82		
	250.00						Qa = 250.00		
	387.31				60.340		K Factor = 49.86		



# CITY OF PORTLAND, MAINE

Department of Building Inspections

## Original Receipt

Oct 25 2011

Received from F. J. ...

Location of Work 600 ...

Cost of Construction \$ \_\_\_\_\_ Building Fee: \_\_\_\_\_

Permit Fee \$ \_\_\_\_\_ Site Fee: \_\_\_\_\_

Certificate of Occupancy Fee: \_\_\_\_\_

Total: \_\_\_\_\_

Building (IL) \_\_\_ Plumbing (I5) \_\_\_ Electrical (I2) \_\_\_ Site Plan (U2) \_\_\_

Other F. J. ...

CBL: 029 A010

Check #: 75966 Total Collected \$ 910.00

**No work is to be started until permit issued.  
Please keep original receipt for your records.**

Taken by: [Signature]

WHITE - Applicant's Copy  
YELLOW - Office Copy  
PINK - Permit Copy