

ZONE	ADDRESS	DEVICE	FLOOR	DESCRIPTION	TEST RESULTS
1	1D001	HEAT DETECTOR	BASEMENT	APT. 129-2B BEDROOM	PASS
2	1D002	HEAT DETECTOR	BASEMENT	APT. 129-2B HALL	PASS
3	1D003	HEAT DETECTOR	BASEMENT	APT. 19-2B LIVING ROOM	PASS
4	1D004	HEAT DETECTOR	BASEMENT	APT. 129-2B KITCHEN	PASS
5	1D005	SMOKE DETECTOR	BASEMENT	131 HALL	PASS
7	1D007	HEAT DETECTOR	BASEMENT	APT. 131-2B BEDROOM	PASS
8	1D008	HEAT DETECTOR	BASEMENT	APT. 131-2B LIVING ROOM	PASS
9	1D009	SMOKE DETECTOR	1ST	129 HALL	PASS
10	1D010	HEAT DETECTOR	1ST	APT. 129-1 LIVING ROOM	PASS
11	1D011	HEAT DETECTOR	1ST	APT. 129-1 BEDROOM	PASS
12	1D012	HEAT DETECTOR	1ST	APT. 129-3 HALL	PASS
13	1D013	HEAT DETECTOR	1ST	APT. 129-3 KITCHEN	PASS
14	1D014	HEAT DETECTOR	1ST	APT. 129-3 BEDROOM	PASS
15	1D015	HEAT DETECTOR	1ST	APT. 131-3 BEDROOM	PASS
16	1D016	HEAT DETECTOR	1ST	APT. 131-3 HALL	PASS
17	1D017	HEAT DETECTOR	1ST	APT. 131-3 LIVING ROOM	PASS
18	1D018	HEAT DETECTOR	1ST	APT. 131-3 KITCHEN	PASS
19	1D019	HEAT DETECTOR	1ST	APT. 131-1 BEDROOM	PASS
20	1D020	HEAT DETECTOR	1ST	APT. 131-1 LIVING ROOM	PASS
21	1D021	SMOKE DETECTOR	1ST	131 HALL	PASS
22	1D022	HEAT DETECTOR	2ND	APT. 129-5 LIVING ROOM	PASS
23	1D023	HEAT DETECTOR	2ND	APT. 129-5 BEDROOM	PASS
24	1D024	HEAT DETECTOR	2ND	APT. 129-4 HALL	PASS
25	1D025	HEAT DETECTOR	2ND	APT. 129-4 BEDROOM	PASS
26	1D026	SMOKE DETECTOR	2ND	129 HALL	PASS
27	1D027	SMOKE DETECTOR	2ND	131 HALL	PASS
28	1D028	HEAT DETECTOR	2ND	APT. 131-4 KITCHEN	PASS
29	1D029	HEAT DETECTOR	2ND	APT. 131-4 LIVING ROOM	PASS
30	1D030	HEAT DETECTOR	2ND	APT. 131-4 BEDROOM	PASS
32	1D032	HEAT DETECTOR	2ND	APT. 131-5 BEDROOM	PASS
33	1D033	HEAT DETECTOR	2ND	APT. 131-5 HALL	PASS
34	1D034	HEAT DETECTOR	2ND	APT. 131-5 LIVING ROOM	PASS
35	1D035	HEAT DETECTOR	2ND	APT. 131-5 KITCHEN	PASS
36	1D036	HEAT DETECTOR	3RD	APT. 129-6 LIVING ROOM	PASS
37	1D037	HEAT DETECTOR	3RD	APT. 129-6 BEDROOM	PASS
38	1D038	HEAT DETECTOR	3RD	APT. 131-6 BEDROOM	PASS
39	1D039	HEAT DETECTOR	3RD	APT. 131-6 LIBING ROOM	PASS
160	1M001	TROUBLE	1ST	AES RADIO	PASS
161	1M002	PULL STATION	1ST	129 HALL	PASS
162	1M003	PULL STATION	2ND	129 HALL	PASS
163	1M004	PULL STATION	2ND	APT. 129-4 FIRE ESCAPE	PASS
164	1M005	PULL STATION	2ND	APT. 129-5 FIRE ESCAPE	PASS
165	1M006	PULL STATION	3RD	APT. 129-6 FIRE ESCAPE	PASS
166	1M007	PULL STATION	1ST	131 HALL	PASS

ZONE	ADDRESS	DEVICE	FLOOR	DESCRIPTION	TEST RESULTS
167	1M008	PULL STATION	2ND	131 HALL	PASS
168	1M009	PULL STATION	2ND	APT. 131-4 FIRE ESCAPE	PASS
169	1M010	PULL STATION	2ND	APT. 131-5 FIRE ESCAPE	PASS
170	1M011	PULL STATION	3RD	APT. 131-6 FIRE ESCAPE	PASS
171	1M012	CO DETECTOR	BASEMENT	BOILER AREA	PASS
172	1M013	HEAT DETECTOR	BASEMENT	BOILER AREA	PASS
173	1M014	HEAT DETECTOR	BASEMENT	ELECTRICAL AREA	PASS
174	1M015	PULL STATION	BASEMENT	ELECTRICAL AREA	PASS
175	1M016	W-GATE	1ST	129 HALL	PASS
176	1M017	PULL STATION	BASEMENT	APT. 129-2B KITCHEN	PASS

DEVICE	FLOOR	DESCRIPTION	TEST RESULTS
MINI SOUNDER	BASEMENT	APT. 129-2B	PASS
MINI SOUNDER	1ST	APT. 129-1	PASS
MINI SOUNDER	1ST	APT. 129-3	PASS
MINI SOUNDER	2ND	APT. 129-4	PASS
MINI SOUNDER	2ND	APT. 129-5	PASS
MINI SOUNDER	3RD	APT. 129-6	PASS
MINI SOUNDER	BASEMENT	APT. 131-2B	PASS
MINI SOUNDER	1ST	APT. 131-1	PASS
MINI SOUNDER	1ST	APT. 131-3	PASS
MINI SOUNDER	2ND	APT. 131-4	PASS
MINI SOUNDER	2ND	APT. 131-5	PASS
MINI SOUNDER	3RD	APT. 131-6	PASS
HORN/STROBE	1ST	129 HALL	PASS
HORN/STROBE	2ND	129 HALL	PASS
HORN/STROBE	1ST	131 HALL	PASS
HORN/STROBE	2ND	131 HALL	PASS
HORN/STROBE	BASEMENT	131 HALL	PASS
HORN/STROBE	BASEMENT	ELECTRICAL AREA	PASS