

Fire Suppression System Design Specifications

Notes

System Materials

| Item Number | Description | Quantity |
|---------------|---|----------|
| 87-120016-001 | ADP Nozzle | 3 |
| 87-120019-001 | R Nozzle | 4 |
| WK-282664-000 | ML-360 Link 360 F (182 C), ML, Unpaint | 2 |
| 87-120018-001 | GRW Nozzle | 1 |
| WK-282666-000 | ML-500 Link 500 F (260 C), ML, Orange | 1 |
| 60-120074-001 | 1 1/2" NPT Mechanical Gas Valve | 1 |
| 60-120006-001 | WHDR-400M Cylinder/Valve, 4 Gallon | 1 |
| 60-120099-001 | Universal Control Head Assembly | 1 |
| 60-120110-001 | Remote Manual Release, Combination | 1 |
| 60-120064-001 | Universal Link Detector Housing Kit (A+ | 3 |



Designed & Installed by:
Firesafe Equipment
PO Box 1355
Auburn, ME 04211
207-784-7525

For:
TAO