Structural Integrity
Consulting Engineers, Inc.

RESURGAM CITY OF PORTLAND, MAINE
Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 10/03/13

August 29st, 2013

Mr. Dan Soley

Reference:
106 High St.
Portland, ME

Structural Integrity Job Number: 13-0121

Dear Dan,

The opinions and comments contained herein are based on visual observations made during my visit to the site. Architectural, mechanical, electrical, and plumbing conditions are not included in this report. No warranty expressed or implied, as to the condition of the complete structure, is intended.

Based on my site visit, I have concluded that it is okay structurally to remove the attic framing as long as the two main timber beams that extend from gable end to gable end remain.

Please do not hesitate to call with any questions, or if I can be of further assistance.

Sincerely,

Aaron C. Jones, P.E., SECB, LEED AP
President

STATE OF MAINE
AARON C. JONES
No. 10968
LICENSED
PROFESSIONAL ENGINEER

8/29/13