


961239

FILL IN AND SIGN WITH INK



APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine,



To the INSPECTOR OF BUILDINGS, PORTLAND, ME. 19 December 1996

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 65 High St Use of Building Multi Fam No. Stories New Building Existing " "
 Name and address of owner of appliance Bill Simpson
 Installer's name and address Charles Burnham P.O. Box 382 Telephone 865-9010
Freeport, ME 04032

General Description of Work

To install Replace Steam Boiler

IF HEATER, OR POWER BOILER

Location of appliance Basement Any burnable material in floor surface or beneath? no
 If so, how protected? Kind of fuel? #2 Oil
 Minimum distance to burnable material, from top of appliance or casing top of furnace 18"
 From top of smoke pipe 18" From front of appliance 24" From sides or back of appliance 12"
 Size of chimney flue 8" Other connections to same flue yes - 2 water heaters
 If gas fired, how vented? Rated maximum demand per hour 250,000 BTU's
 Will sufficient fresh air be supplied to the appliance to insure proper and safe combustion? yes

IF OIL BURNER

Name and type of burner Beckett Labelled by underwriters' laboratories? yes
 Will operator be always in attendance? yes Does oil supply line feed from top or bottom of tank? bottom
 Type of floor beneath burner concrete Size of vent pipe 1 1/4 X 2
 Location of oil storage basement Number and capacity of tanks 2 - 275
 Low water shut off yes (2) Make 1-#67 1-450D OEM No.
 Will all tanks be more than five feet from any flame? yes How many tanks enclosed? none
 Total capacity of any existing storage tanks for furnace burners 2 - 275

IF COOKING APPLIANCE

Location of appliance Any burnable material in floor surface or beneath?
 If so, how protected? Height of Legs, if any
 Skirting at bottom of appliance? Distance to combustible material from top of appliance?
 From front of appliance From sides and back From top of smokepipe
 Size of chimney flue Other connections to same flue
 Is hood to be provided? If so, how vented? Forced or gravity?
 If gas fired, how vented? Rated maximum demand per hour

MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

Charlie Burnham Master Oil Burner #2670Replacement - Permit Fee 15.00Amount of fee enclosed?

APPROVED:

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed?

CS 300

Signature of Installer

INSPECTION FILE APPLICANT'S ASSESSOR'S COPY


961239

FILL IN AND SIGN WITH INK



APPLICATION FOR PERMIT FOR
HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine,



To the INSPECTOR OF BUILDINGS, PORTLAND, ME. 19 December 1996

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 65 High St Use of Building Multi Fam No. Stories New Building Existing "
Name and address of owner of appliance Bill Simpson
Installer's name and address Charles Burnham P.O. Box 382 Telephone 865-9010
Freeport, ME 04032

General Description of Work

To install Replace Steam Boiler

IF HEATER, OR POWER BOILER

Location of appliance Basement Any burnable material in floor surface or beneath? no
how protected? Kind of fuel? #2 Oil
Minimum distance to burnable material, from top of appliance or casing top of furnace 18"
From top of smoke pipe 18" From front of appliance 24" From sides or back of appliance 12"
Size of chimney flue 8" Other connections to same flue yes - 2 water heaters
If gas fired, how vented? Rated maximum demand per hour 250,000 BTU's
Will sufficient fresh air be supplied to the appliance to insure proper and safe combustion? yes

IF OIL BURNER

Name and type of burner Beckett Labelled by underwriters' laboratories? yes
Will operator be always in attendance? yes Does oil supply line feed from top or bottom of tank? bottom
Type of floor beneath burner concrete Size of vent pipe 1 1/4 X 2
Location of oil storage basement Number and capacity of tanks 2 - 275
Low water shut off yes (2) Make 1-#67 1-450D OEM No.
Will all tanks be more than five feet from any flame? yes How many tanks enclosed? none
Total capacity of any existing storage tanks for furnace burners 2 - 275

IF COOKING APPLIANCE

Location of appliance Any burnable material in floor surface or beneath?
If so, how protected? Height of Legs, if any
Skirting at bottom of appliance? Distance to combustible material from top of appliance?
From front of appliance From sides and back From top of smokepipe
Size of chimney flue Other connections to same flue
Is hood to be provided? If so, how vented? Forced or gravity?
If gas fired, how vented? Rated maximum demand per hour

MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

Charlie Burnham Master Oil Burner #2670

Replacement - Permit Fee 15.00

Amount of fee enclosed?

APPROVED:

[Signature]

Will there be in charge of the above work a person competent to see that the State and City requirements are being observed?
[Signature]

1. 1 1/2" FILL PIPE
2. 1 1/4" VENT PIPE
3. Kind of heat
4. Burner rigidity & support
5. Name & Label
6. Remote control
7. High limit control
8. Main cutoff switch
9. Low water cutoff
10. High limit control
11. Piping support & protection
12. Valves in supply line
13. Capacity of tanks
14. Tank rigidity & support
15. Oil gauge
16. Instruction card
17. Oil leaks
18. Adequate ventilation
19. Smokepipe to combustible
20. Thermal cutoff switch

Signature of Installer

INSPECTION FILE APPLICANT'S ASSESSOR'S COPY