



. . . Fire Protection by Computer Design

FREEDOM FIRE PROTECTION INC.
209 QUAKER RIDGE ROAD
CASCO, MAINE 04015
207-627-4109

Job Name : DANFORTH ON HIGH CONDOS HC1
Building : 81 DANFORTH STREET
Location : PORTLAND, MAINE 04101
System : #1 AREA #1
Contract :
Data File : DANFORTH ON HIGH CONDOS HC1.WXF

HYDRAULIC DESIGN INFORMATION SHEET

Name - DANFORTH ON HIGH CONDOS Date - 10/24/12
Location - PORTLAND, MAINE 04101
Building - 81 DANFORTH STREET System No. - #1 AREA #1
Contractor - Contract No. -
Calculated By - MIKE NOBLIT Drawing No. - FP-3
Construction: (X) Combustible () Non-Combustible Ceiling Height 9'-6"
OCCUPANCY - APARTMENTS

S Type of Calculation: (X)NFPA 13 Residential (X)NFPA 13R ()NFPA 13D
Y Number of Sprinklers Flowing: ()1 ()2 (X)4 ()
S ()Other
T ()Specific Ruling Made by Date
E
M Listed Flow at Start Point - 11.1 Gpm System Type
Listed Pres. at Start Point - 7 Psi (X) Wet () Dry
D MAXIMUM LISTED SPACING 12' x 12' () Deluge () PreAction
E Domestic Flow Added - Gpm Sprinkler or Nozzle
S Additional Flow Added - 100 Gpm Make TYCO Model CC2
I Elevation at Highest Outlet - Feet Size 1/2" K-Factor 4.2
G Note: Temperature Rating 175
N

Calculation Gpm Required 160.815 Psi Required 72.822 At Test
Summary C-Factor Used: Overhead 150 Underground 140

W Water Flow Test: Pump Data: Tank or Reservoir:
A Date of Test - 3/26/2008 Rated Cap. Cap.
T Time of Test - @ Psi Elev.
E Static (Psi) - 81 Elev.
R Residual (Psi) - 0 Other Well
Flow (Gpm) - 1644 Proof Flow Gpm
S Elevation - -2'-0"

P Location:
P
L Source of Information: PORTLAND WATER DISTRICT
Y


Water Supply Curve (C)

FREEDOM FIRE PROTECTION INC.
DANFORTH ON HIGH CONDOS HC1

Page 2
Date 10/24/12

City Water Supply:
C1 - Static Pressure : 81
C2 - Residual Pressure: 0
C2 - Residual Flow : 1644

Demand:
D1 - Elevation : 13.679
D2 - System Flow : 60.815
D2 - System Pressure : 72.822
Hose (Adj City) :
Hose (Demand) : 100
D3 - System Demand : 160.815
Safety Margin : 7.080



Fittings Used Summary

FREEDOM FIRE PROTECTION INC.
DANFORTH ON HIGH CONDOS HC1

Page 3
Date 10/24/12

Fitting Legend

Abbrev.	Name	½	¾	1	1¼	1½	2	2½	3	3½	4	5	6	8	10	12	14	16	18	20	24
B	Generic Butterfly Valve	0	0	0	0	0	0	7	10	0	12	9	10	12	19	21	0	0	0	0	0
E	90' Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
T	90' Flow Thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Zac	Ames 2000SS	Fitting generates a Fixed Loss Based on Flow																			

Pressure / Flow Summary - STANDARD

FREEDOM FIRE PROTECTION INC.
DANFORTH ON HIGH CONDOS HC1

Page 4
Date 10/24/12

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
101	31.583	4.2	15.5	na	16.53	0.1	144	7.0
102	31.583	4.2	13.21	na	15.26	0.1	144	7.0
103	31.583	4.2	12.11	na	14.62	0.1	144	7.0
104	31.583	4.2	11.76	na	14.4	0.1	144	7.0
19	31.583		12.18	na				
18	31.583		12.55	na				
17	31.583		13.68	na				
16	31.583		15.46	na				
15	31.583		16.94	na				
14	31.583		25.85	na				
13	31.583		34.4	na				
12	31.583		36.26	na				
11	31.583		37.41	na				
10	31.583		40.3	na				
9	31.583		44.09	na				
8	31.583		46.84	na				
7	31.583		53.48	na				
6	20.75		58.49	na				
5	12.25		62.62	na				
4	12.25		62.83	na				
3	9.33		64.37	na				
2	9.33		65.18	na				
1	5.42		66.91	na				
0	2.0		71.95	na				
TEST	0.0		72.82	na	100.0			

The maximum velocity is 20.49 and it occurs in the pipe between nodes 15 and 14

Final Calculations - Hazen-Williams

FREEDOM FIRE PROTECTION INC.
DANFORTH ON HIGH CONDOS HC1

Page 5
Date 10/24/12

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
101 to 15	16.53	1.101 150	1T	9.563 0.0	20.500 9.562	15.498 0.0		K Factor = 4.20	
	0.0	0.0478		0.0	30.062	1.438		Vel = 5.57	
	16.53					16.936		K Factor = 4.02	
102 to 17	15.26	1.101 150	1T	9.563 0.0	2.000 9.562	13.205 0.0		K Factor = 4.20	
	0.0	0.0413		0.0	11.562	0.477		Vel = 5.14	
	15.26					13.682		K Factor = 4.13	
103 to 18	14.62	1.101 150	1T	9.563 0.0	2.000 9.562	12.114 0.0		K Factor = 4.20	
	0.0	0.0381		0.0	11.562	0.440		Vel = 4.93	
	14.62					12.554		K Factor = 4.13	
104 to 19	14.40	1.101 150	1T	9.563 0.0	2.000 9.562	11.755 0.0		K Factor = 4.20	
	0.0	0.0371		0.0	11.562	0.429		Vel = 4.85	
19 to 18	0.0	1.101 150		0.0 0.0	10.000 0.0	12.184 0.0			
	14.4	0.0370		0.0	10.000	0.370		Vel = 4.85	
18 to 17	14.62	1.101 150		0.0 0.0	8.330 0.0	12.554 0.0			
	29.02	0.1354		0.0	8.330	1.128		Vel = 9.78	
17 to 16	15.26	1.101 150	1E	3.825 0.0	2.166 3.825	13.682 0.0			
	44.28	0.2961		0.0	5.991	1.774		Vel = 14.92	
16 to 15	0.0	1.101 150		0.0 0.0	5.000 0.0	15.456 0.0			
	44.28	0.2960		0.0	5.000	1.480		Vel = 14.92	
15 to 14	16.53	1.101 150	1E	3.825 0.0	12.916 3.825	16.936 0.0			
	60.81	0.5325		0.0	16.741	8.914		Vel = 20.49	
14 to 13	0.0	1.101 150	1T	9.563 0.0	6.500 9.562	25.850 0.0			
	60.81	0.5324		0.0	16.062	8.552		Vel = 20.49	
13 to 12	0.0	1.394 150		0.0 0.0	11.000 0.0	34.402 0.0			
	60.81	0.1687		0.0	11.000	1.856		Vel = 12.78	
12 to 11	0.0	1.394 150		0.0 0.0	6.830 0.0	36.258 0.0			
	60.81	0.1688		0.0	6.830	1.153		Vel = 12.78	

Final Calculations - Standard

FREEDOM FIRE PROTECTION INC.
DANFORTH ON HIGH CONDOS HC1

Page 6
Date 10/24/12

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
11	0.0	1.394	1T	9.523	7.583	37.411			
to		150		0.0	9.523	0.0			
10	60.81	0.1687		0.0	17.106	2.886		Vel = 12.78	
10	0.0	1.598	1E	5.828	37.830	40.297			
to		150		0.0	5.828	0.0			
9	60.81	0.0868		0.0	43.658	3.789		Vel = 9.73	
9	0.0	1.598	2E	11.656	20.083	44.086			
to		150		0.0	11.656	0.0			
8	60.81	0.0868		0.0	31.739	2.754		Vel = 9.73	
8	0.0	1.682	1E	7.48	16.750	46.840			
to		150		0.0	7.479	5.000		* Fixed loss = 5	
7	60.81	0.0676		0.0	24.229	1.638		Vel = 8.78	
7	0.0	2.157		0.0	10.583	53.478			
to		120		0.0	0.0	4.692			
6	60.81	0.0303		0.0	10.583	0.321		Vel = 5.34	
6	0.0	2.157	1E	6.153	8.500	58.491			
to		120		0.0	6.153	3.681			
5	60.81	0.0304		0.0	14.653	0.446		Vel = 5.34	
5	0.0	2.157	1E	6.153	0.830	62.618			
to		120		0.0	6.153	0.0			
4	60.81	0.0305		0.0	6.983	0.213		Vel = 5.34	
4	0.0	2.157	1E	6.153	2.916	62.831			
to		120		0.0	6.153	1.265			
3	60.81	0.0304		0.0	9.069	0.276		Vel = 5.34	
3	0.0	2.157	1E	6.153	20.330	64.372			
to		120		0.0	6.153	0.0			
2	60.81	0.0304		0.0	26.483	0.805		Vel = 5.34	
2	0.0	4.026	1E	10.0	3.166	65.177			
to		120	1B	12.0	22.000	1.693			
1	60.81	0.0015		0.0	25.166	0.037		Vel = 1.53	
1	0.0	4.026	1Zac	0.0	3.420	66.907			
to		140		0.0	0.0	5.041		* Fixed loss = 3.56	
0	60.81	0.0012		0.0	3.420	0.004		Vel = 1.53	
0	0.0	6.16		0.0	25.000	71.952			
to		140		0.0	0.0	0.866			
TEST	60.81	0.0002		0.0	25.000	0.004		Vel = 0.65	
	100.00							Qa = 100.00	
	160.81					72.822		K Factor = 18.84	