DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



## CITY OF PORTLAND BUILDING PERMIT



This is to certify that

DANFORTH ON HIGH LP /Simplex / Grinnell

Located at

81 DANFORTH ST

**PERMIT ID: 2013-00394** 

CBL: 040 A016001

has permission to install master box fire alarm system.

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

**Fire Prevention Officer** 

Code Enforcement Officer / Plan Reviewer

THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD

SCANNED

PERMIT ID: 2013-00394 Located at: 81 DANFORTH ST CBL: 040 A016001

## BUILDING PERMIT INSPECTION PROCEDURES Please call 874-8703 (ONLY)

or email: buildinginspections@portlandmaine.gov

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.
- Permits expire in 6 months. If the project is not started or ceases for 6 months.
- If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.

## **REQUIRED INSPECTIONS:**

Final - Fire

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

PERMIT ID: 2013-00394 Located at: 81 DANFORTH ST CBL: 040 A016001

City of Portland, Maine - Building or Use Permit				Permit No:	Date Applied For:	CRT:			
•		07) 874-8703, Fax: (20	7) 874-8716	2013-00394	02/27/2013	040	A016001		
Location of Construction: Owner Name:				Owner Address:			Phone:		
81 DANFORTH ST DANFO		DANFORTH ON HIGH LP 3		309 CUMBERLAN					
Business Name:		Contractor Name:		Contractor Address:	Phone				
		Simplex / Grinnell		20 Thomas Drive V	(207) 842-6440				
Lessee/Buyer's Name		Phone: P		Permit Type:					
				Fire Alarm System					
Proposed Use:			Propose	d Project Description:					
same - thirty units - elderly housing			install	install master box fire alarm system.					
			40						
Dept: Zoning	Status: Ap	proved w/Conditions	Reviewer:	Ann Machado	Approval D	ate:	02/28/2013	3	
Note:		•			-	Ok to I	ssue: 🗸		
	requires a sena	rate review and approval	thru Historic	Preservation This r	property is located w				
District.	requires a sepa	rate review and approvar	una mistorie	reservation. This p	roperty is rocated w		TIBLOTIC		
Dept: Fire	Status: Ap	proved w/Conditions	Reviewer:	Ben Wallace Jr	Approval D	ate:	04/03/2013	3	
Note:						Ok to I	ssue:		
	ACP annunciate	or(s), and pull stations sha	all be keved a	like.					
1) Records caomet, 1	ici, amaiciai	or(s), and pair stations site	an or noy ou u	*****					

- 2) In field installation shall be installed per code as conditions dictate.
- 3) The fire alarm system shall have a new fire alarm inspection sticker.
- 4) The installation shall comply with the following:
  - City of Portland Chapter 10, Fire Prevention and Protection;
  - NFPA 1, Fire Code (2009 edition), as amended by City Code;
  - NFPA 101, Life Safety Code (2009 edition), as amended by City Code;
  - City of Portland Fire Department Rules and Regulations;
  - NFPA 72, National Fire Alarm and Signaling Code (2010 edition), as amended by Fire Department Rules and Regulations; and NFPA 70, National Electrical Code (2011 edition) as amended by the State of Maine
- 5) All smoke detectors shall be photoelectric.
- 6) The fire alarm technician shall be present for the fire inspection. System acceptance and commissioning must be coordinated with alarm and suppression system contractors and the Fire Department. Call 874-8703 to schedule.
- 7) Fire protection systems shall be maintained. If system is to be off line over 4 hours a fire watch shall be in place. Dispatch notification required 874-8576.
- 8) A 4100 series Knox Box is required.
- 9) System CO detectors shall be located on the ceiling in the same room as permanently installed fuel-burning appliances and centrally located on every habitable level and in every HVAC zone of the building per NFPA 720:5.5.5.3.1. System CO detectors shall activate an audible alarm at the detector and FACP, and send an alarm signal the remote station. It shall not trip a/the master box.
- 10 Supervising Station monitoring for addressable fire alarm systems shall be by point.
- 11 \*\*The fire alarm annunciator and the two-way communications panel shall be located immediately adjacent to each other on the same wall in the lobby.\*\*
- 12 Notice: The first scheduled final inspection fee is at no charge. Additional inspections shall be billed at \$75 for each inspector.
- 13 Through-penetrations and membrane penetrations in fire walls, fire barrier walls, and fire resistance rated horizontal assemblies shall be protected by firestop systems or devices in conformance with NFPA 101:8.3.5 (ASTM E 814 or ANSI/UL 1479). Providing firestop labels at each firestop system or device and an onsite manual containing the detail for each firestop system or device used for the project will streamline final inspection approvals.

Location of Construction:	cation of Construction: Owner Name:		Phone:			
81 DANFORTH ST	DANFORTH ON HIGH LP	309 CUMBERLAND AVE STE 203				
Business Name:	Contractor Name:	Contractor Address:	Phone			
	Simplex / Grinnell	20 Thomas Drive Westbrook	(207) 842-6440			
Lessee/Buyer's Name	ssee/Buyer's Name Phone:		Permit Type:			
		Fire Alarm System				

- 14 All fire alarm records required by NFPA 72 should be stored in an approved cabinet located at the FACP labeled "FIRE ALARM RECORDS".
- 15 A master box connection and drill switch is required. AES Zones shall be:
  - 1. Water flow
  - 2.City Disconnect: Water flow
  - 3. Pull stations and detectors
  - 4. City Disconnect: Pull stations and detectors
  - 5.Not assigned
  - 6.Not assigned
  - 7.Not assigned
  - 8.AES tamper switc

E-Plan									
City of Portland, M	aine - Bui	lding or Use	Permit Applicat	ion [	Permit No:	Issue Date:		CBL:	
389 Congress Street, 0		_		1	2013-00394			040 A016001	
Location of Construction: Owner Name:			Owner Address:				Phone:		
81 DANFORTH ST		DANFORTH	DANFORTH ON HIGH LP		309 CUMBERLAND AVE STE 203				
				POR	TLAND, ME 04	1101			
Business Name:		Contractor Name:		Contractor Address:				Phone	
		Simplex / Grinnell		20 Thomas Drive Westbrook ME 04092			4092	(207) 842-6440	
Lessee/Buyer's Name		Phone:		Permit Type:				Zone:	
					Fire Alarm System			C49	
Past Use: Proj		Proposed Use:			Permit Fee: Cost of Work:		CEO District:		
thirty units - elderly hou	sing		same - thirty units - elderly		\$220.00 \$20,00				
(#2012-07-4399)		housing		V Approved		SPECTION: e Group: Type:			
				Denied Use			с споцр.	Group. Type.	
				4	/3/12 -	N/A			
Proposed Project Description	1:			1 7	9 0				
install fire alarm				Signature: BHANOVIC (58) Signat			gnature:	ature:	
				PEDESTRIAN ACTIVITIES DISTRICT (		P.A.D.)			
				Ac	tion: Approve	d Approve	ed w/Cond	ditions Denied	
				Sim	motores		Date		
Permit Taken By:	Date A	pplied For:					Dati	c.	
bjs		7/2013			Zoning	Approval			
1. This permit applica	tion does not	preclude the	Special Zone or Reviews Zoning Appeal		Historic Preservation				
Applicant(s) from meeting applicable State and Federal Rules.  2. Building permits do not include plumbing, septic or electrical work.  3. Building permits are void if work is not started within six (6) months of the date of issuance.			Wetland		Variance	Variance		Not in District or Landmark  Does Not Require Review	
					Miscellan				
					Condition	Conditional Use		Requires Review	
False information n permit and stop all	e a building	ng Subdivision		☐ Interpretation		Approved			
			Site Plan		_ Approved	I		Approved w/Conditions	
			Maj Minor N	мм 🗀	_ Denied			Denied	
			OK, w/ Grobe	5			1 1	hyexterior work	
			Date: 2 28 13 7	1801	Date:		Date:	Car, MI LEGIMA	
							~	My historic	
							· th	N historic	
			CDD MINIS	mro				P1 23014	
		C 1 C.1	CERTIFICA			. 4	4	6 1	
I hereby certify that I am that I have been authoriz									
this jurisdiction. In addit	tion, if a pern	nit for work desc	cribed in the applica	tion is i	ssued, I certify t	hat the code of	fficial's	authorized	
representative shall have		to enter all area	s covered by such p	ermit a	t any reasonable	hour to enforce	ce the p	rovision of the	
code(s) applicable to suc	n permit.								
SIGNATURE OF APPLICAN	SIGNATURE OF APPLICANT			ESS DATE PH			PHONE		

DATE

**PHONE** 

RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE



## Fire Alarm Permit

If you or the property owner owes real estate or property taxes or user charges on any property within the city, payment arrangements must be made before permits of any kind are accepted.

Installation address: 81 Danforth St, CBL:					
Exact location: (within structure) 1st floor electrical room 13	}				
Type of occupancy(s) (NFPA & ICC): 30 Unit Apartment Bldg.					
Building owner: Danforth on High LP					
Must be System Designer (point of contact); Steven Kalafarski Nicet level IV					
Designer phone: (978) 731-7243	B-moil: skalafarski@simplexgrinnell.coස				
Installing contractor: Wescott Electric/ Simplexgrinnell	Certificate of Pitness No: 1019				
Contractor phone: John Hale (207) 239-5100	E-mall: Johale@slmplexgrInnell.com				
This is a new application: YES  NO New AES Master Box: YES (Include Master Box approval form)					
Amendment to an existing permit: YES NO Perm	nit no:				
The following documents shall be provided with this application:					
Ploor plans Scope of Work	COST OF WORK! 20,000.00				
Wiring diagram 11 1/2 x 17s	PERMIT FEE: # 220,00				
Annunciator details pdf copy (may be e-mailed)	(\$10 PER \$1,000 + \$30 FOR THE FIRST \$1,000)				
Input/Output Mairix Designer qualifications	RECEIVED				
Equipment data sheets Battery/ voltage drop caics	FEB 2 7 2013				
1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1					
Master box approval only: YES NO (If yes check New AES Master Box above)	Dept. of Building Inspections City of Portland Maine				
The designer shall be the responsible party for this application. Download a new copy of this application at					
www.portlandmaine.gov/fire for every submitted. Submit all plans in electronic PDF in addition to readable 11 1/2 x 17s to					
the Building Inspections Department, 389 Congress Street, Room 315, Portland, Maine 04101.					
Prior to acceptance of any fire alarm system, a complete commissioning and acceptance test must be coordinated with all					
fire system contractors and the Fire Department, and proper document	• • • •				
All installation(s) must comply with the City of Portland Technical Standard for Signaling Systems for the Protection of					
Life and Property, available at www.portlandmaine.gov/fire.					
Applicant signatures Awin C. Kalafurii	Date: 2-4-13				