

ZONE	ADDRESS	DEVICE	FLOOR	DESCRIPTION	TEST RESULTS
1	1D001	SMOKE DETECTOR	BASEMENT	ELECTRICAL PANELS	PASS
2	1D002	HEAT DETECTOR	BASEMENT	BY REAR EXIT	PASS
3	1D003	HEAT DETECTOR	BASEMENT	STORAGE	PASS
4	1D004	HEAT DETECTOR	BASEMENT	BOILER AREA	PASS
5	1D005	HEAT DETECTOR	BASEMENT	STAIRS	PASS
6	1D006	HEAT DETECTOR	BASEMENT	APARTMENT 11 LIVING ROOM	PASS
7	1D007	HEAT DETECTOR	BASEMENT	APARTMENT 11 KITCHEN	PASS
8	1D008	SMOKE DETECTOR	1ST	REAR EXIT	PASS
9	1D009	HEAT DETECTOR	1ST	APARTMENT 3	PASS
10	1D010	HEAT DETECTOR	1ST	APARTMENT 4 LIVING ROOM	PASS
11	1D011	SMOKE DETECTOR	1ST	FRONT HALL	PASS
12	1D012	HEAT DETECTOR	1ST	APARTMENT 1	PASS
13	1D013	HEAT DETECTOR	1ST	APARTMENT 2 LIVING ROOM	PASS
14	1D014	HEAT DETECTOR	1ST	APARTMENT 2 BEDROOM	PASS
15	1D015	SMOKE DETECTOR	1ST	CENTER HALL	PASS
16	1D016	HEAT DETECTOR	2ND	APARTMENT 7 LIVING ROOM	PASS
17	1D017	HEAT DETECTOR	2ND	APARTMENT 6	PASS
18	1D018	HEAT DETECTOR	2ND	APARTMENT 5	PASS
19	1D019	HEAT DETECTOR	2ND	APARTMENT 6 LIVING ROOM	PASS
20	1D020	HEAT DETECTOR	2ND	APARTMENT 6 BEDROOM	PASS
21	1D021	SMOKE DETECTOR	2ND	FRONT HALL	PASS
22	1D022	SMOKE DETECTOR	2ND	REAR HALL	PASS
23	1D023	SMOKE DETECTOR	3RD	HALL	PASS
24	1D024	HEAT DETECTOR	3RD	APARTMENT 10 LIVING ROOM	PASS
25	1D025	HEAT DETECTOR	3RD	APARTMENT 10 KITCHEN	PASS
26	1D026	HEAT DETECTOR	3RD	APARTMENT 10 BEDROOM	PASS
27	1D027	HEAT DETECTOR	3RD	APARTMENT 9 LIVING ROOM	PASS
28	1D028	HEAT DETECTOR	3RD	APARTMENT 9 BEDROOM	PASS
29	1D029	HEAT DETECTOR	1ST	APARTMENT 2 KITCHEN	PASS
30	1D030	HEAT DETECTOR	1ST	APARTMENT 1 KITCHEN	PASS
31	1D031	HEAT DETECTOR	1ST	APARTMENT 4 KITCHEN	PASS
32	1D032	HEAT DETECTOR	2ND	APARTMENT 6 KITCHEN	PASS
33	1D033	SMOKE DETECTOR	1ST	BY STAIRS	PASS
34	1D034	HEAT DETECTOR	2ND	APARTMENT 7 KITCHEN	PASS
35	1D035	HEAT DETECTOR	3RD	APARTMENT 10 HALL	PASS
36	1D036	HEAT DETECTOR	BASEMENT	APARTMENT 11 BEDROOM	PASS
160	1M001	PULL STATION	BASEMENT	REAR EXIT	PASS
161	1M002	PULL STATION	BASEMENT	APARTMENT 11 EXIT	PASS
162	1M003	PULL STATION	1ST	MAIN ENTRANCE	PASS
163	1M004	PULL STATION	1ST	REAR EXIT	PASS
164	1M005	PULL STATION	2ND	HALL	PASS
165	1M006	PULL STATION	3RD	HALL	PASS
166	1M007	CO DETECTOR	BASEMENT	BOILER AREA	PASS
167	1M008	TROUBLE	BASEMENT	AES RADIO	PASS
168	1M009	PULL STATION	2ND	APARTMENT 7 EXIT	PASS
169	1M010	PULL STATION	3RD	APARTMENT 10 FIRE ESCAPE	PASS

ZONE	ADDRESS	DEVICE	FLOOR	DESCRIPTION	TEST RESULTS
170	1M011	PULL STATION	3RD	APARTMENT 11 FIRE ESCAPE	PASS
171	1M012	GATEWAY	1ST	W-GATE	PASS

DEVICE	FLOOR	DESCRIPTION	TEST RESULTS
HORN/STROBE	BASEMENT	REAR EXIT	PASS
HORN/STROBE	BASEMENT	STAIRS	PASS
HORN/STROBE	1ST	FRONT HALL	PASS
HORN/STROBE	1ST	CENTER HALL	PASS
HORN/STROBE	1ST	REAR HALL	PASS
HORN/STROBE	2ND	HALL	PASS
HORN/STROBE	3RD	HALL	PASS
MINI SOUNDER	1ST	APARTMENT 1	PASS
MINI SOUNDER	1ST	APARTMENT 2	PASS
MINI SOUNDER	1ST	APARTMENT 3	PASS
MINI SOUNDER	1ST	APARTMENT 4	PASS
MINI SOUNDER	2ND	APARTMENT 5	PASS
MINI SOUNDER	2ND	APARTMENT 6	PASS
MINI SOUNDER	2ND	APARTMENT 7	PASS
MINI SOUNDER	2ND	APARTMENT 8	PASS
MINI SOUNDER	3RD	APARTMENT 9	PASS
MINI SOUNDER	3RD	APARTMENT 10	PASS
MINI SOUNDER	BASEMENT	APARTMENT 11	PASS