

FIRE ALARM NOTES	FIRE ALARM LEGEND																																								
<p>1. THESE PLANS ARE PROVIDED AS A MEANS OF ESTABLISHING THE MINIMUM DESIGN CRITERIA FOR THE ELECTRICAL WORK. THE REFERENCED PLANS ARE SCHEMATIC IN NATURE AND ARE NOT TO BE RELIED UPON FOR CODE COMPLIANCE OR SUITABILITY OF PURPOSE. IT IS THE RESPONSIBILITY OF THE DESIGN-BUILD SUBCONTRACTOR, IN CONJUNCTION WITH THE DESIGN ENGINEER, TO ASSURE ALL WORK IS IN ACCORDANCE WITH APPLICABLE CODES, RULES, STATUTES, ORDINANCES AND GOOD ENGINEERING PRACTICES.</p> <p>2. SIGNIFICANT DESIGN ALTERATIONS, ADDITIONS, OR DISCREPANCIES SHALL BE BROUGHT TO THE ATTENTION OF THE DESIGN PROFESSIONAL BEFORE PROCEEDING.</p> <p>3. THE ELECTRICAL CONTRACTOR IS RESPONSIBLE FOR COORDINATING THE ELECTRICAL SYSTEM INSTALLATION WITH ALL TRADES INCLUDING MECHANICAL, ARCHITECTURAL, STRUCTURAL, AND PLUMBING.</p> <p>4. ELECTRICAL WORK SHALL CONFORM TO ALL LOCAL, STATE, AND FEDERAL STANDARDS, CODES, AND GUIDELINES.</p> <p>5. ALL FIRE ALARM DEVICES TO BE CAT. 30 KEYED.</p> <p>6. FIRE ALARM CONTRACTOR IS TO PROVIDE FIXTURE SUBMITTALS AND CIRCUITED DRAWINGS, INCLUDING PANEL DIAGRAMS FOR APPROVAL PRIOR TO INSTALLATION.</p> <p>7. FIRE ALARM SYSTEM TO BE INSTALLED AS REQUIRED BY CODE. IF ELEMENTS OF TRANSMITTING EQUIPMENT, INCLUDING ANTENNAS ARE PHYSICALLY SEPARATED, THE WIRING OR CABLING BETWEEN THEM SHALL BE PROTECTED BY CONDUIT.</p> <p>8. ALL EXPOSED WIRING SYSTEMS TO BE RUN IN E.M.T. OR RIGID CONDUITS AND RUN TIGHT TO ROOF OR FLOOR DECK OR CONTINUOUSLY ALONG STRUCTURAL COMPONENTS.</p> <p>10. ADDRESSABLE SMOKE DETECTORS MUST BE PROVIDED IN INTERIOR RESIDENTIAL UNITS, ELEVATOR LOBBIES, MECHANICAL AND ELECTRICAL ROOMS, COMPUTER/TELEPHONE/PBX ROOMS, AND STORAGE ROOMS.</p> <p>11. A SPEAKER/HORN MUST BE PROVIDED IN EACH RESIDENTIAL UNIT AND AREA USED FOR SLEEPING PURPOSE OR NOTIFICATION MAY BE VIA A INTERCONNECTED SYSTEM USING A SOUNDER BASE.</p> <p>12. WHERE SMOKE DETECTOR AND CARBON MONOXIDE DETECTORS ARE SHOWN TOGETHER A COMBINATION SMOKE/CARBON MONOXIDE DETECTOR IS ALLOWED.</p> <p>13. THE ELECTRICAL CONTRACTOR IS RESPONSIBLE FOR COORDINATING FIRE ALARM SYSTEM REQUIREMENTS IN CONJUNCTION WITH HVAC EQUIPMENT AS REQUIRED BY CODE.</p>	<table border="1"> <thead> <tr> <th>SYMBOL</th> <th>DESCRIPTION</th> </tr> </thead> <tbody> <tr> <td>AP</td> <td>ANNUNCIATION PANEL</td> </tr> <tr> <td>FACP</td> <td>FIRE ALARM CONTROL PANEL</td> </tr> <tr> <td>KB</td> <td>KNOX BOX</td> </tr> <tr> <td>FS</td> <td>FLOW SWITCH</td> </tr> <tr> <td>PS</td> <td>PRESSURE SWITCH</td> </tr> <tr> <td>TS</td> <td>TAMPER SWITCH</td> </tr> <tr> <td>HS</td> <td>HORN AND STROBE LIGHT</td> </tr> <tr> <td>H</td> <td>HORN UNIT</td> </tr> <tr> <td>S</td> <td>STROBE LIGHT</td> </tr> <tr> <td>F</td> <td>PULL STATION</td> </tr> <tr> <td>CO</td> <td>CARBON MONOXIDE DETECTOR</td> </tr> <tr> <td>COB</td> <td>CARBON MONOXIDE DETECTOR WITH SOUNDER BASE</td> </tr> <tr> <td>S</td> <td>SMOKE DETECTOR</td> </tr> <tr> <td>SB</td> <td>SMOKE DETECTOR WITH SOUNDER BASE</td> </tr> <tr> <td>SD</td> <td>DUCT SMOKE DETECTOR</td> </tr> <tr> <td>H</td> <td>HEAT DETECTOR</td> </tr> <tr> <td>HD</td> <td>DUCT HEAT DETECTOR</td> </tr> <tr> <td>TB</td> <td>FIRE ALARM BELL</td> </tr> <tr> <td>MHO</td> <td>MAGNETIC HOLD OPEN</td> </tr> </tbody> </table>	SYMBOL	DESCRIPTION	AP	ANNUNCIATION PANEL	FACP	FIRE ALARM CONTROL PANEL	KB	KNOX BOX	FS	FLOW SWITCH	PS	PRESSURE SWITCH	TS	TAMPER SWITCH	HS	HORN AND STROBE LIGHT	H	HORN UNIT	S	STROBE LIGHT	F	PULL STATION	CO	CARBON MONOXIDE DETECTOR	COB	CARBON MONOXIDE DETECTOR WITH SOUNDER BASE	S	SMOKE DETECTOR	SB	SMOKE DETECTOR WITH SOUNDER BASE	SD	DUCT SMOKE DETECTOR	H	HEAT DETECTOR	HD	DUCT HEAT DETECTOR	TB	FIRE ALARM BELL	MHO	MAGNETIC HOLD OPEN
SYMBOL	DESCRIPTION																																								
AP	ANNUNCIATION PANEL																																								
FACP	FIRE ALARM CONTROL PANEL																																								
KB	KNOX BOX																																								
FS	FLOW SWITCH																																								
PS	PRESSURE SWITCH																																								
TS	TAMPER SWITCH																																								
HS	HORN AND STROBE LIGHT																																								
H	HORN UNIT																																								
S	STROBE LIGHT																																								
F	PULL STATION																																								
CO	CARBON MONOXIDE DETECTOR																																								
COB	CARBON MONOXIDE DETECTOR WITH SOUNDER BASE																																								
S	SMOKE DETECTOR																																								
SB	SMOKE DETECTOR WITH SOUNDER BASE																																								
SD	DUCT SMOKE DETECTOR																																								
H	HEAT DETECTOR																																								
HD	DUCT HEAT DETECTOR																																								
TB	FIRE ALARM BELL																																								
MHO	MAGNETIC HOLD OPEN																																								

