

. . . Fire Protection by Computer Design

HAMPSHIRE FIRE PROTECTION
8 N. WENTWORTH AVE.
LONDONDERRY, NH 03053
603-432-8221

Job Name : YORK STREET, STANDPIPES
Building : STANDPIPES
Location : PORTLAND, ME
System : STP
Contract : 4833CME
Data File : YSSTP.wxf

HYDRAULIC DESIGN INFORMATION SHEET

Name - YORK STREET, STANDPIPES Date - 8-17-16
Location - PORTLAND, ME
Building - STANDPIPES System No. - STP
Contractor - OPECHEE Contract No. - 4833CME
Calculated By - BENOIT Drawing No. - 8
Occupancy - STANDPIPES

S (X)NFPA 14 Number of Standpipes ()1 (X)2 ()3 ()4 ()

Y ()Other

S ()Specific Ruling Made by Date

T

E Flow at Top Most Outlet - 250 Gpm System Type
M Pres. at Top Most Outlet - 100 Psi (X) Wet () Dry
Flow For Ea. Additional Standpipe - 250 Gpm
D Total Additional Flow - 500 Gpm
E Elevation at Highest Outlet - Feet
S Hose Valve Connection (X)1 1/2" (X)2 1/2"
I Class Service ()I (X)II ()III
G Note:165 PSI @ 750 GMP PUMPER REQUIRED AT FDC

N

Calculation Gpm Required 750 Psi Required 165 At FDC
Summary C-Factor Used: Overhead 120 Underground 120

W Water Flow Test: Pump Data: Tank or Reservoir:
A Date of Test - NA Cap.
T Time of Test - NA Rated Cap. Elev.
E Static (Psi) - 165 @ Psi
R Residual (Psi) - 165 Elev. Well
Flow (Gpm) - 750 Proof Flow Gpm
S Elevation - 0

U

P Location: FD PUMPER ASSIST AT FDC, WET MANUAL

P

L Source of Information: PORTLAND FIRE DEPT.

Y


Water Supply Curve C

HAMPSHIRE FIRE PROTECTION
YORK STREET, STANDPIPES

Page 2
Date 8-17-16

City Water Supply:
C1 - Static Pressure : 165
C2 - Residual Pressure: 165
C2 - Residual Flow : 750

Demand:
D1 - Elevation : 20.139
D2 - System Flow : _____
D2 - System Pressure : 163.098
Hose (Demand) : 750
D3 - System Demand : 750
Safety Margin : 1.902



Fittings Used Summary

HAMPSHIRE FIRE PROTECTION
YORK STREET, STANDPIPES

Page 3
Date 8-17-16

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	2.25	2	2.5	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
I	90' Grvd-Vic Elbow #10	0	0	2	3	4	3.5	6	5	8	7	8.5	10	13	17	20	23	25	33	36	40
J	90'Tee-Branch Grv Vic #20	0	0	4.5	6	8	8.5	10.8	13	17	16	21	25	33	41	50	65	78	88	98	120
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65					

Units Summary

Diameter Units Inches
Length Units Feet
Flow Units US Gallons per Minute
Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Pressure / Flow Summary - STANDARD

HAMPSHIRE FIRE PROTECTION
YORK STREET, STANDPIPES

Page 4
Date 8-17-16

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
S1	49.5		100.0	na	250.0			
S2	48.5		100.45	na	250.0			
SA	11.5		120.25	na				
S3	48.5		116.71	na	250.0			
SB	11.5		134.19	na				
SC	11.5		134.33	na				
SD	11.5		146.05	na				
FDC	3.0		163.1	na				

The maximum velocity is 16.88 and it occurs in the pipe between nodes SC and SD

Final Calculations - Hazen-Williams

HAMPSHIRE FIRE PROTECTION
YORK STREET, STANDPIPES

Page 5
Date 8-17-16

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
S1	250.00	4.26		1.000	100.000			Qa = 250	
to		120.0		0.0	0.433				
S2	250.0	0.0150		1.000	0.015			Vel = 5.63	
S2	250.00	4.26	I	9.217	39.000	100.448		Qa = 250	
to		120.0	J	21.067	30.284	16.025			
SA	500.0	0.0545		0.0	69.284	3.777		Vel = 11.25	
SA	0.0	4.26	2I	18.434	203.000	120.250			
to		120.0	J	21.067	55.301	0.0			
SC	500.0	0.0545	B	15.8	258.301	14.081		Vel = 11.25	
	0.0								
	500.00				134.331			K Factor = 43.14	
S3	250.00	4.26	2I	18.434	41.000	116.707		Qa = 250	
to		120.0	J	21.067	55.301	16.025			
SB	250.0	0.0151	B	15.8	96.301	1.456		Vel = 5.63	
SB	0.0	4.26		0.0	9.500	134.188			
to		120.0		0.0	0.0	0.0			
SC	250.0	0.0151		0.0	9.500	0.143		Vel = 5.63	
SC	500.00	4.26	2I	18.434	62.000	134.331			
to		120.0	J	21.067	39.501	0.0			
SD	750.0	0.1154		0.0	101.501	11.716		Vel = 16.88	
SD	0.0	4.26	4I	36.868	50.000	146.047			
to		120.0	S	28.968	65.836	3.681			
FDC	750.0	0.1154		0.0	115.836	13.370		Vel = 16.88	
	0.0								
	750.00				163.098			K Factor = 58.73	