



1 ELECTRICAL - Roof Fire Alarm Plan
 SCALE: 3/32"= 1'-0"

NOTES:

1. ALL CONDUIT ON ROOF SHALL BE GALVANIZED RIGID STEEL. THE LAST 18"-30" OF THE CONDUIT RUN TO EACH MOTOR SHALL BE LIQUID TIGHT FLEXIBLE METALLIC CONDUIT.
2. E.C. SHALL UTILIZE ROOF CURBS FOR ALL ROOF PENETRATIONS. ROOF IS NEW.
3. DUCT MOUNTED SMOKE DETECTORS SHALL BE PROVIDED BY E.C., INSTALLED BY M.C., WIRED BY E.C. ALL DUCT MOUNTED SMOKE DETECTORS SHALL HAVE REMOTE TEST STATION AND LED ON THE FLOOR BELOW, GROUP BY AREA AND INSTALL IN A CORRIDOR OR OTHER COMMON AREA. ALL TEST STATIONS SHALL BE PERMANENTLY LABELED WITH UNIT SERVED. "RTU-1 DUCT MOUNTED SMOKE DETECTOR". LABEL SHALL BE RED PLASTIC WITH 1/8" TALL (WHITE) LETTERS.

REVISION:

ISSUED:
11.23.16 - Issue for Permit

project architect: ---
drawn by: CMF

ELECTRICAL
ROOF
PLAN

sheet number:

E2.06

Mixed Use Development

York & High Street
Portland, Maine

BLW Engineers, Inc.
 311 Central Street, Suite 100, Box 151
 Lewiston, Maine 04240
 T: 978.486.4301 F: 978.428.0067
 www.blwengineers.com

HP/KC - ELECTRICAL - FIRE/SMOKE - FIRE PROTECTION