- DEVELOPMENT OF A CAREFUL CONSTRUCTION SEQUENCE.
- RAPID REVEGETATION OF DENUDED AREAS TO MINIMIZE THE PERIOD OF SOIL EXPOSURE.
- . RAPID STABILIZATION OF DRAINAGE PATHS TO AVOID RILL AND GULLY EROSION.
- THE USE OF ON-SITE MEASURES TO CAPTURE SEDIMENT (HAY BALES/ STONE CHECK DAMS/SILT FENCE, ETC.)

THE FOLLOWING TEMPORARY AND PERMANENT EROSION AND SEDIMENT CONTROL DEVICES WILL BE IMPLEMENTED AS PART OF THE SITE DEVELOPMENT. THESE DEVICES SHALL BE INSTALLED AS INDICATED ON THE PLANS OR AS DESCRIBED WITHIN THIS REPORT. FOR FURTHER REFERENCE, SEE THE LATEST EDITION OF THE MANIE EROSION AND SEDIMENT CONTROL BURNEY.

WATER FROM CONSTRUCTION TRENCH DEWATERING SHALL PASS FIRST THROUGH A FILTER BAG OR SECONDARY CONTAINMENT STRUCTURE (E.G. HAY BALE LINED POOL) PRIOR TO DISCHARGE. THE DISCHARGE SITE SHALL BE SELECTED TO AVOID FLOCOING, ICING, AND SEDIMENT DISCHARGES TO A PROTECTED RESOURCE. IN NO CASE SHALL THE FILTER BAG OR CONTAINMENT STRUCTURE BE LOCATED WITHIN 50 FEET OF A PROTECTED NATURAL RESOURCE.

### B. INSPECTION AND MONITORING

MAINTENANCE MEASURES SHALL BE APPLIED AS NEEDED DURING THE ENTIRE CONSTRUCTION SEASON. AFTER EACH RAINFALL, SNOW STORM OR PERIOD OF THAMING AND RUNDEF, THE SITE CONTRACTOR SHALL PERFORM A VISUAL INSPECTION OF ALL INSTALLE EROSION CONTROL MEASURES AND PERFORM REPAIRS AS NEEDED TO INSURE THEIR CONTINUOUS FUNCTION. FOLLOWING THE TEMPORARY AND/OR FINAL SEEDING AND MULCHING, THE CONTRACTOR SHALL IN THE SPRING INSPECT AND REPAIR ANY DAMAGES AND/OR UNESTABLISHED SPOTS. ESTABLISHED VEGETATIVE COVER MEANS A MINIMUM OF 902 OF AREAS VEGETATION WITH VIGOROUS GROWTH.

## C. TEMPORARY EROSION CONTROL MEASURES

THE FOLLOWING MEASURES ARE PLANNED AS TEMPORARY EROSION/SEDIMENTATION CONTROL MEASURES DURING CONSTRUCTION:

CRUSHED STONE-STABILIZED CONSTRUCTION ENTRANCE SHALL BE PLACED AT THE ENTRANCE ALONG YORK STREET.

2. SILTATION FENCE OR WOOD WASTE COMPOST BERMS SHALL BE INSTALLED DOWNSTREAM OF ANY DISTURBED AREAS TO TRAP RUNOFF-BORNE SEDIMENTS UNTIL GRASS AREAS ARE REVECETATED. THE SILT FENCE AND/OR WOOD WASTE COMPOST BERMS SHALL BE INSTALLED PER THE DETAILS PROVIDED IN THIS PACKAGE AND INSPECTED AT LEAST DONCE A WEEK AND BEFORE AND BEFORE AND MEDIATELY AFTER A STORM EVENT OF 0.5 INCHES OR GREATER, AND AT LEAST DAILY DURING PROLONGED RAINFALL. REPAIRS SHALL BE MADE IF THERE ARE ANY SIGNS OF EROSION OR SEDIMENTATION BELOW THE FENCE OR BERM LINE. IF THERE ARE SIGNS OF UNDERSOLVENITING AT THE COURSE COUNTY OF THE PROLONGED OF WATER BEHIND THE FENCE OR BERM LINE. IF THERE ARE SIGNS OF UNDERSOLVENITING AT THE COURSE OF WATER BEHIND THE FENCE OR BERM, INC. BET AND A STORE OF WATER BEHIND THE FENCE OR BERM, THE BARRIER SHALL BE REPLACED WITH A STONE CHECK DAM. WOOD WASTE COMPOST BERNS ARE NOT TO BE USED ADJACENT TO WELLAND AREAS THAT ARE NOT TO BE DISTURBED.

3. STRAW OR HAY MULCH INCLUDING HYDROSEDING IS INTENDED TO PROVIDE COVER FOR DENUDED OR SEEDED AREAS UNTIL REVEGETATION IS ESTABLISHED. MULCH PLACED DESTWEEN APRIL 15TH AND OCTOBER 15TH ON SLOPES OF LESS THEN 15 PERCENT SHALL BE ANCHORED BY APPLYING WATER; MULCH PLACED ON SLOPES OF EQUAL TO OR STEEPER THAN 15 PERCENT SHALL BE COVERED BY A FABRIC NETTING AND ANCHORED WITH STAPLES IN ACCORDANCE WITH MANUFACTURER'S RECOMMENDATION. FABRIC NETTING AND STAPLES SHALL BE USED ON DISTURBED AREAS WITHIN 50' OF LAKES, STREAMS, AND WETLANDS REGARDLESS OF THE UPSTREAM SLOPE. MULCH PLACED BETWEEN OCTOBER 15TH AND APRIL 15TH ON SLOPES EQUAL TO OR STEEPER THAN 8 PERCENT SHALL BE COVERED WITH A FABRIC METING AND ANCHORED WITH STAPLES IN ACCORDANCE WITH THE MANUFACTURER'S RECOMMENDATIONS SLOPES STEEPER THAN 3:1 AND EQUAL TO OR FLATTER THAN 2:1, WHICH ARE TO BE REVEGETATED, SHALL RECEIVE CURLEY BLANKETS BY AMERICAN EXCLISION OR EQUAL SLOPES STEEPER THAN 2:1 SHALL RECEIVE RIPRAP AS NOTED ON THE PLANS. THE MULCH APPLICATION ARTE FOR BOTH TEMPORARY AND PERMANENT SEEDING IS 75 LBS PER 1000 SF AS IDENTIFIED IN ATTACHMENT A OF THIS SECTION. MULCH SHALL NOT BE PLACED OVER SNOW.

- 4. TEMPORARY STOCKPILES OF STUMPS, GRUBBINGS, OR COMMON EXCAVATION WILL BE PROTECTED AS FOLLOWS:
- o) TEMPORARY STOCKPILES SHALL NOT BE LOCATED WITHIN 50 FEET OF ANY WETLANDS WHICH WILL NOT BE DISTURBED AND SHALL BE LOCATED AWAY FROM DRAINAGE SWALES.
- b) STOCKPILES SHALL BE STABILIZED WITHIN 7 DAYS BY EITHER TEMPORARILY SEEDING THE STOCKPILE BY A HYDROSEED METHOD CONTAINING AN EMULSIFIED MULCH TACKIFIER OR BY COVERING THE STOCKPILE WITH MULCH, SUCH AS HAY, STRAW, OR EROSION CONTROL MIX.
- c) STOCKPILES SHALL BE SURROUNDED BY SEDIMENTATION BARRIER AT THE TIME OF FORMATION.
- 5. ALL DENUDED AREAS THAT ARE WITHIN 50 FEET OF AN UNDISTURBED WETLAND, WHICH HAVE BEEN ROUGH GRADED AND ARE NOT LOCATED WITHIN A BUILDING PAD, PARKING AREA, OR ACCESS DRIVE SUBBASE AREA, SHALL RECEIVE MULCH OR EROSION CONTROL MESH FABRIC WITHIN 104 HOURS OF INITIAL DISTURBENCE OF SOLL. ALL AREAS WITHIN 105 DEET OF AN UNDISTURBED WAND SHALL BE MULCHED PRIOR TO ANY PREDICTED RAIN EVENT REGARDLESS OF THE 48 HOUR WINDOW. IN OTHER AREAS, THE TIME PERIOD MAY BE EXTENDED TO 7 DAYS.

6. FOR WORK, WHICH IS CONDUCTED BETWEEN OCTOBER 15TH AND APRIL 15TH OF ANY CALENDAR YEAR, ALL DENUDED AREAS, SHALL BE COVERED WITH HAY MULCH OR EROSION CONTROL MIX, APPLIED AT TWICE THE NORMAL APPLICATION RATE AND ANCHORED WITH A FABRIC NETHING. THE THIME PERIOD FOR APPLYING MULCH SHALL BE LIMITED TO 2 DAYS FOR ALL AREAS.

- 7. YORK STREET, HIGH STREET, AND DANFORTH STREET SHALL BE SWEPT TO CONTROL MUD AND DUST AS NECESSARY
- 8. DURING GRUBBING OPERATIONS STONE CHECK DAMS SHALL BE INSTALLED AT ANY EVIDENT CONCENTRATED FLOW DISCHARGE POINTS AND AS DIRECTED ON THE EROSION CONTROL PLANS.

9. SILT FENCING WITH A MINIMUM STAKE SPACING OF 6 FEET SHALL BE USED, UNLESS THE FENCE IS SUPPORTED BY WIRE FENCE REINFORCEMENT OF MINIMUM 14 GAUGE AND WITH A MAXIMUM MESH SPACING OF 6 INCHES, IN WHICH CASE STAKES MAY BE SPACED A MAXIMUM OF 10 FEET APART. THE BOTTOM OF THE FENCE SHALL BE ANCHORED.

- 10. WOOD WASTE COMPOST/BARK BERMS MAY BE USED IN LIEU OF SILTATION FENCING, BERMS SHALL BE REMOVED AND SPREAD IN A LAYER NOT TO EXCEED 3" THICK ONCE UPSTREAM AREAS ARE COMPLETED AND A 90% CATCH OF VEGETATION IS ATTAINED.
- 11. WATER AND/OR CALCIUM CHLORIDE SHALL BE FURNISHED AND APPLIED IN ACCORDANCE WITH MDOT SPECIFICATIONS SECTION 637 DUST CONTROL.

12. LOAM AND SEED IS INTENDED TO SERVE, AS THE PRIMARY PERMANENT REVEGETATIVE MEASURE FOR ALL DENUDED AREAS NOT PROVIDED WITH OTHER EROSION CONTROL MEASURES, SUCH AS RIPRAP. APPLICATION RATES ARE PROVIDED IN ATTACHMENT A OF THIS SECTION. SEEDING SHALL NOT OCCUR OVER SNOW.

THE FOLLOWING PERMANENT EROSION CONTROL MEASURES HAVE BEEN DESIGNED AS PART OF THE EROSION/SEDIMENTATION CONTROL PLAN:

1. ALL AREAS DISTURBED DURING CONSTRUCTION, BUT NOT SUBJECT TO OTHER RESTORATION (PAVING, RIPRAP, ETC.) WILL BE LOAMED, LIMED, FERRILIZED, MULCHED, AND SEEDED. FABRIC NETTING, ANCHORED WITH STAPLES, SHALL BE PLACED OVER THE MULCH IN AREAS AS NOTED IN TEMPORARY EROSION CONTROL MEASURES PARAGRAPH 3 OF THIS REPORT. ALL AREAS WITHIN 50 FEET OF AN UNDISTURBED WETLAND SHALL BE MULCHED PRIOR TO ANY PREDICTED RAIN EVENT REGARDLESS OF THE 48 HOUR WINDOW. NATIVE TOPSOIL SHALL BE STOCKPILED AND REUSED FOR INNIAL RESTORATION WHEN IT IS OF SUFFICIENT QUALITY.

# 1.4 IMPLEMENTATION SCHEDULE

THE FOLLOWING CONSTRUCTION SEQUENCE SHALL BE REQUIRED TO INSURE THE EFFECTIVENESS OF THE EROSION AND SEDIMENTATION CONTROL MEASURES ARE OPTIMIZED:

IT IS ANTICIPATED THAT CONSTRUCTION OF THE PROJECT WILL COMMENCE IN THE FALL OF 2015 AND BE COMPLETED BY FALL OF 2016.

NOTE: FOR ALL GRADING ACTIVITIES, THE CONTRACTOR SHALL EXERCISE EXTREME CAUTION NOT TO OVEREXPOSE THE SITE, THIS SHALL BE ACCOMPLISHED BY LIMITING THE DISTURBED AREA.

- 1. INSTALL STABILIZED CONSTRUCTION ENTRANCE AT THE INTERSECTION OF THE ACCESS DRIVE AND YORK STREET.
- 2. INSTALL PERIMETER SILT FENCE AND/OR WOOD WASTE BERMS PRIOR TO COMMENCEMENT OF DEMOLITION.
- 3. PERFORM DEMOLITION OF EXISTING SITE ELEMENTS.

4. FOUNDATION PREPARATION AREA SHALL BE EXCAVATED FOR INSTALLATION OF THE BUILDING FOUNDATION. BUILDING WORK WILL BE ON GOING THROUGH THE REMAINDER OF THE PROJECT.

- 5. COMMENCE INSTALLATION OF DRAINAGE APPURTENANCES
- 6. COMMENCE EARTHWORK AND GRADING TO SUBGRADE.
- 7. COMMENCE INSTALLATION OF WATER AND SEWER LINES.
- 8. CONTINUE EARTHWORK AND GRADING TO SUBGRADE AS NECESSARY FOR CONSTRUCTION
- 9. COMPLETE INSTALLATION OF UNDERGROUND UTILITIES TO WITHIN 5' OF THE BUILDINGS.
- 10. INSTALL LIGHT POLE FOUNDATIONS AND LIGHT POLES.
- 11. COMPLETE REMAINING EARTHWORK OPERATIONS.
- 12. COMPLETE INSTALLATION OF CATCH BASINS AND APPURTENANCES.
- 13. INSTALL SUB-BASE AND BASE GRAVEL WITHIN PARKING FIELDS, WALKWAYS, AND ALL DRIVEWAYS.
- 14. INSTALL CURBING IN PARKING FIELDS, DRIVEWAYS, AND ALONG THE STREETS AS NEEDED. 15. INSTALL BASE COURSE PAVING FOR ACCESS DRIVE AND PARKING AREA AS WELL AS CONCRETE SURFACES.
- 16. LOAM, LIME, FERTILIZE, SEED AND MULCH DISTURBED AREAS AND COMPLETE ALL LANDSCAPING.
- 17. INSTALL SURFACE COURSE PAVING FOR ACCESS DRIVE AND PARKING AREAS. STRIPE PER PLAN. 18. ONCE THE SITE IS STABILIZED AND A 90% CATCH OF VEGETATION HAS BEEN OBTAINED, REMOVE ALL TEMPORARY EROSION CONTROL MEASURES.
- 19. TOUCH UP LOAM AND SEED.

NOTE: ALL DENUDED AREAS NOT SUBJECT TO FINAL PAVING, RIPRAP, OR GRAVEL SHALL BE REVEGETATED.

PRIOR TO CONSTRUCTION OF THE PROJECT, THE CONTRACTOR SHALL SUBMIT TO THE OWNER A SCHEDULE FOR THE COMPLETION OF THE WORK, WHICH WILL SATISFY THE FOLLOWING CRITERIA:

- 1. THE ABOVE CONSTRUCTION SEQUENCE SHOULD GENERALLY BE COMPLETED IN THE SPECIFIED ORDER; HOWEVER, SEVERAL SEPARATE ITEMS MAY BE CONSTRUCTED SMULTANEOUSLY. WORK MUST ALSO BE SCHEDULED OR PHASED TO REDUCE THE EXTENT OF THE EXPOSED AREAS AS SPECIFIED BELOW. THE INTENT OF THIS SEQUENCE IS TO PROVIDE FOR REGISION CONTROL AND TO HAVE STRUCTURAL MEASURES SUCH AS SLT FENCE AND CONSTRUCTION ENTRANCES IN PLACE BEFORE LARGE AREAS OF LAND ARE DENUDED.

d) LIMIT THE AMOUNT OF EXPOSED AREA TO THOSE AREAS IN WHICH WORK IS EXPECTED TO BE UNDERTAKEN DURING THE PROCEEDING 30 DAYS.

b) REVEGETATE DISTURBED AREAS AS RAPIDLY AS POSSIBLE. ALL AREAS SHALL BE PERMANENTLY STABILIZED WITHIN 7 DAYS OF FINAL GRADING OR BEFORE A STORM EVENT: OR TEMPORARILY STABILIZED WITHIN 4B HOURS OF INITIAL DISTURBANCE OF SOIL FOR AREAS WITHIN 50 FEET OF AN UNDISTURBED WEILAND AND 7 DAYS FOR ALL OTHER AREAS. AREAS WITHIN 50 FEET OF AN UNDISTURBED WEILAND SHALL BE MULCHED PRIOR TO ANY PREDICTED RAIN EVENT RECARDLESS OF THE 48 HOUR WINDOW.

c) incorporate planned inlets and drainage system as early as possible into the construction phase. The ditches shall be immediately lined or revecetated as soon as their installation is complete.

### 1.5 EROSION, SEDIMENTATION AND STABILIZATION CONTROL PLAN

THE EROSION CONTROL INFORMATION IS INCLUDED IN THE PLAN SET.

THE EROSION CONTROL DETAILS AND SPECIFICATIONS ARE INCLUDED IN THE PLAN SET.

### 1.7 WINTER STABILIZATION PLAN

THE WINTER CONSTRUCTION PERIOD IS FROM NOVEMBER 1 THROUGH APRIL 15. IF THE CONSTRUCTION SITE IS NOT STABILIZED WITH PAVEMENT, A ROAD GRAVEL BASE, 75% MATURE VEGETATION COVER OR RIPRAP BY NOVEMBER 15 THEN THE SITE NEEDS TO BE PROTECTED WITH OVER-WINTER STABILIZATION. AM AREA CONSIDERED OPEN IS ANY AREA NOT STABILIZED WITH PAVEMENT; VEGETATION, MULCHING, EROSION CONTROL MATS, RIPRAP OR GRAVEL BASE ON A ROAD.

WINTER EXCAVATION AND EARTHWORK SHALL BE COMPLETED SUCH THAT ANY AREA LEFT EXPOSED CAN BE CONTROLLED BY THE CONTRACTOR. LIMIT THE EXPOSED AREA TO THOSE AREAS IN WHICH WORK IS EXPECTED TO BE UNDER TAKEN DURING THE PROCEEDING 15 DAYS AND THAT CAN BE MULCHED IN ONE DAY PRIOR TO ANY SNOW EVENT.

ALL AREAS SHALL BE CONSIDERED TO BE DENUDED UNTIL THE SUBBASE GRAVEL IS INSTALLED IN ROADWAY/PARKING AREAS OR THE AREAS OF FUTURE LOAM AND SEED HAVE BEEN LOAMED, SEEDED AND MULCHED. HAY AND STRAW MULCH RATE SHALL BE A MINIMUM OF 150 LBS./1,000 S.F. (3 TONS/ACRE) AND SHALL BE PROPERTY ANHORED.

THE CONTRACTOR SHALL INSTALL ANY ADDED MEASURES WHICH MAY BE NECESSARY TO CONTROL EROSION/SEDIMENTATION FROM THE SITE DEPENDENT UPON THE ACTUAL SITE AND WEATHER CONDITIONS. CONTINUATION OF EARTHWORK OPERATIONS ON ADDITIONAL AREAS SHALL NOT BEGIN UNTIL THE EXPOSED SOIL SURFACE ON THE AREA BEING WORKED HAS BEEN STABILIZED, IN ORDER TO MINIMIZE AREAS WITHOUT EROSION CONTROL PROTECTION.

I. SOIL STOCKPILES OF SOIL OR SUBSOIL SHALL BE MULCHED FOR OVER WINTER PROTECTION WITH HAY OR STRAW AT TWICE THE NORMAL RATE OR AT 150 LBS/1,000 S.F. (3 TONS PER ACRE) OR WITH A FOUR-INCH LAYER OF WOODWASTE EROSION CONTROL MIX. THIS SHALL BE DONE WITHIN 24 HOURS OF STOCKING AND RE-ESTABLISHED PRIOR TO ANY RAINFALL OR SNOWFALL. ANY SOIL STOCKPILE SHALL NOT BE PLACED (EVEN COVERED WITH HAY OR STRAW) WITHIN 50 FEET FROM ANY NATURAL RESOURCES.

# 2. NATURAL RESOURCE PROTECTION

2. NATURAL RESOURCE PROTECTION
ANY AREAS WITHIN 50 FEET FROM ANY NATURAL RESOURCES, IF NOT STABILIZED WITH A MINIMUM OF 75% MATURE VEGETATION CATCH, SHALL BE MULCHED BY DECEMBER 1 AND ANCHORED WITH PLASTIC NETTING OR PROTECTED WITH EROSION CONTROL MAIS. DURING WINTER CONSTRUCTION, A DOUBLE LINE OF SEDIMENT BARRIERS (IZ. SILT FENCE BACKED WITH HAY BALES OR BROSON CONTROL MAY) SHALL BE PLACED BETWEEN ANY NATURAL. RESOURCE AND THE DISTURBED AREA. PROJECTS CROSSING THE NATURAL RESOURCE SHALL BE PROTECTED A MINIMUM DISTANCE OF 50 FEET ON EITHER SIDE FROM THE RESOURCE. EXISTING PROJECTS NOT STABILIZED BY DECEMBER 1 SHALL BE PROTECTED WITH THE SECOND LINE OF SEDIMENT BARRIER TO ENSURE TUNCTIONALITY DURING THE SPRING THAW AND RANS.

DURING FROZEN CONDITIONS, SEDIMENT BARRIERS SHALL CONSIST OF WOODWASTE FILTER BERMS AS FROZEN SOIL PREVENTS THE PROPER INSTALLATION OF HAY BALES AND SEDIMENT SILT FENCES.

4. MULCHING
AN AREA SHALL BE CONSIDERED DENUDED UNTIL AREAS OF FUTURE LOAM AND SEED HAVE BEEN LOAMED, SEEDED AND MULCHED. HAY AND STRAW
MULCH SHALL BE APPLIED AT A RATE OF 150 LB. PER 1,000 SQUARE FEET OR 3 TONS/ACRE (TWICE THE NORMAL ACCEPTED RATE OF 75-LBS,7,000
S.F. CR 1,5 TONS/ACRE) AND SHALL BE PROPERLY ANACHORED. MULCH SHALL NOT BE SPREAD ON 100 PC SNOW. THE SNOW SHALL BE REMOVED
DOWN TO A ONE-INCH DEPTH OR LESS PRICE TO APPLICATION. AFTER EACH DAY OF FINAL GRADING, THE AREA SHALL BE PROPERLY STRAILIZED
WITH ANACHORED HAY OR STRAW OR ERGOSON CONTROL MATTING, AN AREA SHALL BE CONSIDERED IN HAVE BEEN STRAWLUSED
SURFACES HAVE BEEN EITHER MULCHED WITH STRAW OR PROSON CONTROL WATTING, AN AREA SHALL BE CONSIDERED IN HAVE BEEN STRAWLUSED
SURFACES HAVE BEEN EITHER MULCHED WITH STRAW OR PROVIDE THE MULCH.

BETWEEN THE DATES OF NOVEMBER 1 AND APRIL 15, ALL MULCH SHALL BE ANCHORED BY PEG LINE, MULCH NETTING, ASPHALT EMULSION CHEMICAL, OR WODD CELLULOSE FIBER, WHEN GROUND SURFACE IS NOT VISIBLE THROUGH THE MULCH THEN COVER IS SUFFICIENT. AFTER NOVEMBER 1ST, MULCH AND ANCHORING OF ALL BARE SOIL SHALL OCCUR AT THE END OF EACH FINAL GRADING WORKDAY.

# 5. MULCHING ON SLOPES AND DITCHES

SLOPES SHALL NOT BE LEFT EXPOSED FOR ANY EXTENDED TIME OF WORK SUSPENSION UNLESS FULLY MULCHED AND ANCHORED WITH PEG AND
NETTING OR WITH EROSION CONTROL BLANKETS. MULCHING SHALL BE APPLIED AT A RATE OF 230 LBS/1,000 S.F. ON ALL SLOPES GREATER THAN 8%.

MULCH NETTING SHALL BE USED TO ANCHOR MULCH IN ALL DRAINAGE WAYS WITH A SLOPE GREATER THAN 3% FOR SLOPES EXPOSED TO DIRECT WINDS AND FOR ALL OTHER SLOPES GREATER THAT 8%. EROSION CONTROL BLANKETS SHALL BE USED IN LIEU OF MULCH IN ALL DRAINAGE WAYS WITH SLOPES GREATER THAN 8%. EROSION CONTROL MIX CAN BE USED TO SUBSTITUTE EROSION CONTROL BLANKETS ON ALL SLOPES EXCEPT

6. SEEDING
BETWEEN THE DATES OF OCTOBER 15 AND APRIL 1ST, LOAM OR SEED WILL NOT BE REQUIRED. DURING PERIODS OF ABOVE FREEZING TEMPERATURES FINISHED AREAS SHALL BE FINIS GRADED AND EITHER PROTECTED WITH MULCH OR TEMPORARILY SEEDED AND MULCHED UNTIL SUCH TIME AS THE FINAL TREATMENT CAN BE APPLIED. IF THE DATE IS A FIRE THE EMPOSED AND AND SEED AND THEN DIVISION SURFACE, THEN THE AREA MAY BE DORNANT SEEDED AT A RATE OF 3 TIMES HIGHER HAN SEPCIFIED FOR PERMANENT SEED AND THEN UNIFORM SURFACE, THEN THE AREA MAY BE DORNANT SEEDED AT A RATE OF 3 TIMES HIGHER HAN SEPCIFIED FOR PERMANENT SEED AND THEN THE OFFICE AND THEN THE AREA MAY BE DORNANT SEED AND THEN THE OFFICE AND THEN SEPCIFIED FOR THE AREA MAY BE DORNANT SEED AND THEN THE OFFICE AND THE OFFICE

# STANDARDS FOR TIMELY STABILIZATION OF CONSTRUCTION SITES DURING WINTER

1. STANDARD FOR THE TIMELY STABILIZATION OF DITCHES AND CHANNELS — THE APPLICANT SHALL CONSTRUCT AND STABILIZE ALL STONE—LINED DITCHES AND CHANNELS ON THE SITE BY NOVEMBER 15. THE APPLICANT SHALL CONSTRUCT AND STABILIZE ALL GRASS—LINED DITCHES AND CHANNELS ON THE SITE BY SEPTEMBER 1.

STANDARD FOR THE TIMELY STABILIZATION OF DISTURBED SLOPES — THE APPLICANT SHALL CONSTRUCT AND STABILIZE STONE—COVERED SLOPES INDIVEMBER 15. THE APPLICANT SHALL SEED AND MULCH ALL SLOPES TO BE VEGETATED BY SEPTEMBER 1. THE DEPARTMENT SHALL CONSIDER BY AREA HAVING A GRADE GREATER THAN 15% TO BE A SLOPE.

3. STANDARD FOR THE TIMELY STABILIZATION OF DISTURBED SOILS -- BY SEPTEMBER 15 THE APPLICANT SHALL SEED AND MULCH ALL DISTURBED SOILS ON AREAS HAWING A SLOPE LESS THAN 15%. IF THE APPLICANT FAILS TO STABILIZE THESE SOILS BY THIS DATE, THEN THE APPLICANT SHALL TAKE ONE OF THE FOLLOWING ACTIONS TO STABILIZE THE SOIL FOR LATE FALL AND WINTER.

# 1.8 MAINTENANCE OF FACILITIES

THE STORMWATER FACILITIES WILL BE MAINTAINED BY THE APPLICANT, 101 YORK STREET, LLC OR THEIR ASSIGNED HEIRS. THE CONTRACT DOCUMENTS WILL REQUIRE THE CONTRACTOR TO DESIGNATE A PERSON RESPONSIBLE FOR MAINTENANCE OF THE SEDIMENTATION CONTROL FEATURES DURING CONSTRUCTION AS REQUIRED BY THE EROSION CONTROL REPORT. LONG—TERM OPERATION/MAINTENANCE RECOMMENDED FOR THE STORMWATER FACILITIES IS PRESENTED BELOW.

THE RESPONSIBLE PARTY MAY CONTRACT WITH SUCH PROFESSIONALS, AS MAY BE NECESSARY IN ORDER TO COMPLY WITH THIS PROVISION AND MAY RELY ON THE ADVICE OF SUCH PROFESSIONALS IN CARRYING OUT ITS DUTY HEREUNDER, PROVIDED, THAT THE FOLLOWING OPERATION AND MAINTENANCE PROCEDURES ARE HEREBY ESTABLISHED AS A MINIMUM FOR COMPLIANCE WITH THIS SECTION. A MAINTENANCE LOG OF THE INSPECTIONS SHALL BE KEPT BY THE RESPONSIBLE PARTY.

INSPECTION AND MAINTENANCE FREQUENCY AND CORRECTIVE MEASURES:
THE FOLLOWING AREAS, FACILITIES, AND MEASURES WILL BE INSPECTED AND THE IDENTIFIED DEFICIENCIES WILL BE CORRECTED. CLEAN—OUT MUST INCLUDE THE REMOVAL AND LECAL DISPOSAL OF ANY ACCUMULATED SEDIMENTS AND DEBRIS.

CATCH BASINS:

INSPECT CATCH BASINS 2 TIMES PER YEAR (PREFERABLY IN SPRING AND FALL) TO ENSURE THAT THE CATCH BASINS ARE WORKING IN THEIR INTENDED FASHION AND THAT THEY ARE FREE OF DEBRIS. CLEAN STRUCTURES WHEN SEDIMENT DEPTHS REACH 12" FROM INVERT OF OUTLET. IF THE BASIN OUTLET IS DESIGNED WITH A HOOD TO TRAP FLOATABLE MATERIALS (I.E. SOULT), CHECK TO ENSURE WATERTICHT SEAL IS WORKING. AT A MINIMUM, REMOVE FLOATING DEBRIS AND HYDROCARBONS AT THE TIME OF THE INSPECTION. HYDROCARBON SOCKS INSTALLED WITHIN CATCH BASINS SHALL BE PROPERLY DISPOSED OF BY AN APPROVED CONTRACTOR WITHIN 14 DAYS AFTER THE FIRST 1" RAINFALL EVENT AFTER THAT PLAY AFTER THE THAT HAVE AFTER THE THAT HAVE AND ADDISPOSED OF DAY A PAPROVED CONTRACTOR WITHIN 14 DAYS AFTER THE FIRST 1" RAINFALL EVENT AFTER THAT BY A PROPERLY DISPOSED OF ONE YEAR AFTER THE INSTALL BE MAINTAINED WITHIN ALL CATCH BASINS DURING THE FIRST YEAR OF OPERATION. ALL SOCKS SHALL BE REMOVED AND DISPOSED OF ONE YEAR AFTER THE INITIAL REPLACEMENT. NEW HYDROCARBON SOCKS SHALL BE INSTALLED WITHIN AREAS THAT RECEIVE NEW PAYMEMENT IN THE FUTURE.

## VEGETATED AREAS:

INSPECT SLOPES AND EMBANKMENTS EARLY IN THE GROWING SEASON TO IDENTIFY ACTIVE OR POTENTIAL EROSION PROBLEMS. REPLANT BARE AREAS OR AREAS WITH 5PARSE GROWITH. WHERE RILL EROSION IS EVIDENT, ARMOR THE AREA WITH AN APPROPRIATE LINING OR DIVERT THE EROSIVE FLOWS TO ON—SITE AREAS ABILE TO WITHSTAND THE CONCENTRATED FLOWS. THE FACILITIES WILL BE INSPECTED AFTER MAJOR STORMS AND ANY IDENTIFIED

ROADWAYS AND PARKING SURFACES: CLEAR ACCUMULATIONS OF WINTER SAND IN PARKING LOTS AND ALONG ROADWAYS AT LEAST ONCE A YEAR, PREFERABLY IN THE SPRING. ACCUMULATIONS ON PAYEMENT MAY BE REMOVED BY PAYEMENT SWEEPING, ACCUMULATIONS OF SAND ALONG ROAD SHOULDERS MAY BE REMOVED BY GRADING EXCESS SAND ID THE PAYEMENT EDGE AND REMOVING IT MANUALLY OR BY A FRONT-END LOADER. REPAIR POTHCLES AND OTHER ROADWAY OBSTRUCTIONS AND HAZARDS. PLOWING AND SANDING OF PAVED AREAS SHALL BE PERFORMED AS NECESSARY TO MAINTAIN VEHICLULAR TRAFFIC SAFETY.

### STORMWATER PLANTERS:

MAINTENANCE SHALL BE PERFORMED AT LEAST 2 TIMES PER YEAR (PREFERABLY IN SPRING AND FALL). AT A MINIMUM, THE MAINTENANCE SHALL CONSIST OF THE FOLLOWING:

- STORMWATER PLANTER UNIT INSPECTION FOREIGN DEBRIS, SILT, MULCH &TRASH REMOVAL
- FILTER MEDIA EVALUATION AND RECHARGE AS NECESSARY PLANT HEALTH EVALUATION AND PRUNING OR REPLACEMENT AS NECESSARY
- REPLACEMENT OF MULCH
  DISPOSAL OF ALL MAINTENANCE REFUSE ITEMS

THE FOLLOWING PROCEDURES ARE HEREBY ESTABLISHED AS A MINIMUM FOR COMPLIANCE WITH THIS SECTION. FOR FURTHER INFORMATION ON THE PROCEDURES LISTED BELOW, REFER TO MOEP CHAPTER 500 RULES — APPENDIX C.

### SPILL PREVENTION:

APPROPRIATE SPILL PREVENTION, CONTAINMENT, AND RESPONSE PLANNING/IMPLEMENTATION SHALL BE USED TO PREVENT POLLUTANTS FROM BEING DISCHARGED FROM MATERIALS ON SITE. GROUNDWATER PROTECTION:
DURING CONSTRUCTION, HAZARDOUS MATERIALS WITH THE POTENTIAL TO CONTAMINATE GROUNDWATER SHALL NOT BE STORED OR HANDLED IN AREAS
OF THE SITE WHICH DRAIN TO AN INFILITRATION AREA.

FUGITIVE SEDIMENT AND DUST: APPROPRIATE MEASURES SHALL BE TAKEN TO ENSURE THAT ACTIVITIES DO NOT RESULT IN NOTICEABLE EROSION OF THE SOILS AND WATER AND/OR CALCIUM CHLORIDE SHALL BE USED TO ENSURE THAT ACTIVITIES DO NOT RESULT IN FUGITIVE DUST EMISSIONS DURING OR AFTER CONSTRUCTION.

DEBRIS AND OTHER MATERIALS:
LITTER, CONSTRUCTION DEBRIS, AND CHEMICALS EXPOSED TO STORMWATER MUST BE PREVENTED FROM BECOMING A POLLUTANT SOURCE.

WATER COLLECTED THROUGH THE PROCESS OF TRENCHING AND/OR DE-WATERING MUST BE REMOVED FROM THE PONDED AREA, AND MUST BE SPEED THROUGH NATURAL WOODED BUFFERS OR OTHER AREAS THAT ARE SPECIFICALLY DESIGNED TO COLLECT THE MAXIMUM AMOUNT OF SEDIMENT POSSIBLE.

NON-STORMWATER DISCHARGES: IDENTIFY AND PREVENT CONTAMINATION BY NON-STORMWATER DISCHARGES.

YORK STREET MIXED USE DEVELOPMENT PROJECT: SITE LOCATION; PORTLAND, ME

X PERMANENT SEEDING TEMPORARY SEEDING

1. INSTRUCTION ON PREPARATION OF SOIL: PREPARE A GOOD SEED BED FOR PLANTING METHOD USED. 2.APPLY LIME AS FOLLOWS: \_# / ACRES, OR 138 # /M SQ. FT.

3.FERTILIZE WITH \_\_\_\_ POUNDS OF \_\_\_\_ N-P-K/AC. OR 18.4 POUNDS OF 10-20-20 N-P-K/M SQ. FT. 4.METHOD OF APPLYING LIME AND FERTILIZER: SPREAD AND WORK INTO THE SOIL BEFORE SEEDING. 5.SEED WITH THE FOLLOWING MIXTURE:

40% CREEPING RED FESCUE 20% KENBLUE KENTUCKY BLUEGRASS

10% TIFFANY CHEWINGS FESCUE 6.MULCHING INSTRUCTIONS: APPLY AT THE RATE OF \_\_\_\_PER ACRE, OR 75\_POUNDS PER M. SQ. FT.

		AMOUNT	UNIT # TONS, ET
7.	TOTAL LIME	138	#/1000 SQ. FT.
8.	TOTAL FERTILIZER	18.4	#/1000 SQ. FT.
9.	TOTAL SEED	1.03	#/1000 SQ. FT.
10.	TOTAL MULCH	75	#/1000 SQ. FT.
11.	TOTAL OTHER MATERIALS,	SEEDS, ETC.	

SPRING SEEDING IS RECOMMENDED. HOWEVER, LATE SUMMER (PRIOR TO SEPTEMBER 1) SEEDING CAN BE MADE. PERMANEN SEEDING SHOULD BE MADE PRIOR TO AUGUST 5 OR AS A DORMANT SEEDING AFTER THE FIRST KILLING FROST AND BEFORE THE FIRST SNOWBALL. IF SEEDING CANNOT BE DONE WITHIN THESE SEEDING DATES, TEMPORARY SEEDING AND MULCHING shall be used to protect the site. Permanent seeding shall be ded dedured until the next recommended section controlled.

PROJECT: YORK STREET MIXED USE DEVELOPMENT

SITE LOCATION: PORTLAND, ME

PERMANENT SEEDING X TEMPORARY SEEDING

1. INSTRUCTION ON PREPARATION OF SOIL: PREPARE A GOOD SEED BED FOR PLANTING METHOD USED.

2.APPLY LIME AS FOLLOWS: \_# / ACRES, OR 138 # /M SQ. FT.

3.FERTILIZE WITH \_\_\_\_ POUNDS OF \_\_\_\_ N-P-K/AC. OR 13.8 POUNDS OF 10-10-10 N-P-K/M SQ. FT. 4.METHOD OF APPLYING LIME AND FERTILIZER: SPREAD AND WORK INTO THE SOIL BEFORE SEEDING. 5.SEED WITH THE FOLLOWING MIXTURE:

50% WINTER RYE

6.MULCHING INSTRUCTIONS: APPLY AT THE RATE OF \_\_\_\_PER ACRE, OR 75\_POUNDS PER M. SQ. FT.

		AMOUNT	UNIT # TONS, ETC
7.	TOTAL LIME	138	#/1000 SQ. FT.
8.	TOTAL FERTILIZER	13.8	#/1000 SQ. FT.
9.	TOTAL SEED	1.03	#/1000 SQ. FT.
10.	TOTAL MULCH	75	#/1000 SQ. FT.
11.	TOTAL OTHER MATERIALS,	SEEDS, ETC.	

SPRING SEEDING IS RECOMMENDED; HOWEVER, LATE SUMMER (PRIOR TO SEPTEMBER 1) SEEDING CAN BE MADE. PERMANENT SEEDING SHOULD BE MADE PRIOR TO AUGUST 5 OR AS A DORMANT SEEDING AFTER THE FIRST KILLING FROST AND BEFORE THE FIRST SNOWFALL IF SEEDING CANNOT BE DONE WITHIN THESE SEEDING DATE. TEMPORARY SEEDING AND MULCHING SHALL BE USED TO PROTECT THE SITE. PERMANENT SEEDING SHALL BE DELAYED UNITL THE NEXT RECOMMENDED SEEDING PERIOR.

NOTE: THIS PLAN SET IS ISSUED FOR PERMITTING PURPOSES AND SHALL NOT BE USED FOR CONSTRUCTION.

**Erosion Control Notes** York Street - Mixed Use Development roject: Portland, Maine York Street, LLC

36 Danforth Street, Portland, MF 04101

Drawina No. C6.01

Alz Cala

OF MAN

ALTON M. PALMER III No. 6281

(100 mg/

Date Revision

TE PLAN REVIEW ssued For Date Ву

Checked: AMP Scale: AS SHOWN Job No.: 3018 File Name: 3018-DETAILS.dwa This plan shall not be modified naineers, Inc.(GPCFI). Any alterations.



Relationships. Responsiveness. Results. www.gorrillpalmer.com 207.657.6910