

**Dana Fisher, LLC**  
P.O. Box 169 \* Portland, Maine 04112  
Email: [asiawest@aol.com](mailto:asiawest@aol.com)

July 26, 2011

Jeanie Bourke  
Code Enforcement Officer / Plan Review  
City Of Portland  
389 Congress Street  
Portland, Maine 04101

Re: 85 York Street - Restaurant


Dear Jeanie,

Here is a plot plan with the revised ramp direction. Also included is an email from JB Brown consenting to the change. As indicated on the building permit application, I will put handrails on both sides at 36".

Thanks for your help this morning!

Let me know if I can provide anything further.

Regards,



Tod Dana

671-5566

RECEIVED  
JUL 27 2011  
Dept. of Building Inspections  
City of Portland, Maine

**From:** Vincent Veroneau <veroneau@jbbrown.com>  
**To:** ASIATEST@aol.com  
**Subject:** 85 York Street Ramp  
**Date:** Tue, Jul 26, 2011 12:05 pm

Tod,

As owners of both 101 York Street and 85 York Street, this letter acknowledges and approves of the ramp design change as shown on your revised site plan. Please let me know if you have additional questions or need anything further.

Regards,

Vin

---


Vincent P. Veroneau  
President  
J.B. Brown & Sons  
36 Danforth Street  
Portland, Maine 04101

(207) 774-5908 Ext. 11  
[Veroneau@jbbrown.com](mailto:Veroneau@jbbrown.com)  
[www.jbbrown.com](http://www.jbbrown.com)

RECEIVED  
JUL 26 2011  
12:05 PM  
ASIATEST@aol.com

EL RAYO PARKING LOT

Min 36" Ramp 1:12 max



RECEIVED  
 JUN 27 1987  
 Dept. of Building Inspections  
 City of New York

YORK STREET