



Portland Fire Department

CERTIFIED MAIL

RE:

51-53 York Street Page 1 of 2

**NOTICE OF VIOLATION
AND ORDER TO CORRECT**

To Whom it May Concern,

The City of Portland inspected the above-referenced property on 11/5/2018 and found violations of the City of Portland Code of Ordinances, which are listed on the attached page(s). You are hereby ordered to correct these violations by the dates given on the attached.

A reinspection of your property will take place on 12/11/2018 10:00:00AM .

Please contact the Fire Prevention Bureau at 874-8400 if you have any question about your reinspection. If the violations are not corrected at the time of reinspection, you will be charged a \$150 failed reinspection fee.

If you do not correct the attached violations, then this matter may be referred to the City of Portland Corporation Counsel for legal action, including civil penalties and other legal remedies.

Thank you for keeping the City of Portland safe.

Sincerely,

Captain John Brennan
Fire Prevention Bureau
City of Portland

NON-COMPLIANCE VIOLATION LIST

NAME	CODE DESCRIPTION	COMMENTS	Deadline
PFD Rules, 5.10.2	All signal systems must have a current inspection sticker issued by a Master Fire Alarm Company.	Expired Sticker	11/19/2018
NFPA 10- 7.2.4.4	Where manual inspections are conducted, records for manual inspections shall be kept on a tag or label attached to the fire extinguisher, on an inspection checklist maintained on file, or by an electronic method.	Building wide	11/19/2018
NFPA 101-4.5.8, 7.9.3	Emergency lights must be kept in good working order.	Numerous E-Lights were found to be not functioning building wide.	12/5/2018