

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



# CITY OF PORTLAND BUILDING PERMIT



This is to certify that  
BROWN J B & SONS

Located at  
20 DANFORTH ST

PERMIT ID: 2017-01415      ISSUE DATE: 11/02/2017      CBL: 040 D001001

has permission to **Reconfigure internal entrance door, move cubicle wall, new cubicle fit out - construct 4 new cubicles.**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 hour notice is required.

A final inspection must be completed before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

*/s/ Jason Grant*

*/s/ Brian Stephens*

**Fire Official**

**Building Official**

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY  
THERE IS A PENALTY FOR REMOVING THIS CARD**

*Approved Property Use - Zoning*  
offices

*Building Inspections*

**Use Group:** B

**Type:** Existing  
Unknow  
n

*Fire Department*

Business (Professional Offices)  
Sprinkled  
1st Floor  
MUBEC/IBC-2009

BUILDING PERMIT INSPECTION PROCEDURES  
Please call 874-8703  
or email: [buildinginspections@portlandmaine.gov](mailto:buildinginspections@portlandmaine.gov)

**Check the Status of Permit or Schedule an Inspection at  
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the City of Portland Inspections Division for the inspections listed below. Appointments must be requested 48 to 72 hours in advance. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that are attached to this permit.**
- **Permits expire in 6 months if the project is not started or ceases for 6 months.**
- **If the inspection requirements below are not followed, then additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC), one set of printed approved stamped construction documents will be kept at the site of work and open to inspection by building officials.**

### **REQUIRED INSPECTIONS:**

Above Ceiling Inspection  
Close-in Plumbing/Framing w/Fire & Draft Stopping  
Electrical Close-in w/Fire & Draftstopping  
Final - Electric  
Final - Fire  
Final Inspection

The project cannot move to the next phase prior to the required inspection and approval to continue.

If the permit requires a certificate of occupancy, it must be paid and issued to the owner or designee before the space may be occupied.

<b>City of Portland, Maine - Building or Use Permit</b>		<b>Permit No:</b> 2017-01415	<b>Date Applied For:</b> 09/07/2017	<b>CBL:</b> 040 D001001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
<b>Proposed Use:</b> Same: offices		<b>Proposed Project Description:</b> Reconfigure internal entrance door, move cubicle wall, new cubicle fit out - construct 4 new cubicles.		
<b>Dept:</b> Historic		<b>Status:</b> Approved w/Conditions	<b>Reviewer:</b> Robert Wiener	<b>Approval Date:</b> 09/21/2017
<b>Note:</b>		<b>Ok to Issue:</b> <input checked="" type="checkbox"/>		
<b>Conditions:</b>		1) No exterior alterations are approved with this permit, including but not limited to venting, mechanicals, lighting, signage, doors, windows, masonry, trim, etc.		
<b>Dept:</b> Zoning		<b>Status:</b> Approved w/Conditions	<b>Reviewer:</b> Christina Stacey	<b>Approval Date:</b> 09/12/2017
<b>Note:</b>		<b>Ok to Issue:</b> <input checked="" type="checkbox"/>		
<b>Conditions:</b>		1) The use of the unit shall remain offices. Any change of use shall require a separate permit application for review and approval. 2) ANY exterior work requires a separate review and approval thru Historic Preservation. This property is located within an Historic District. 3) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.		
<b>Dept:</b> Building Inspecti		<b>Status:</b> Approved w/Conditions	<b>Reviewer:</b> Brian Stephens	<b>Approval Date:</b> 10/13/2017
<b>Note:</b>		<b>Ok to Issue:</b> <input checked="" type="checkbox"/>		
<b>Conditions:</b>		1) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems, fire suppression and fuel tanks. Separate plans may need to be submitted for approval as a part of this process. 2) All penetrations shall maintain the fire resistance rating of walls and ceilings with approved firestop materials, including electrical fixtures and exhaust vents per IBC Sec. 713 and IRC Sec. R302.4 3) All existing fire separation partitions, barriers and horizontal assemblies at adjacent occupancies or dwelling units shall be maintain for rating and continuity. Additional materials may need to be added for compliance. 4) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.		
<b>Dept:</b> Engineering DPS		<b>Status:</b> Not Applicable	<b>Reviewer:</b> Rachel Smith	<b>Approval Date:</b> 09/11/2017
<b>Note:</b>		<b>Ok to Issue:</b> <input checked="" type="checkbox"/>		
<b>Conditions:</b>		1) This approval is non-applicable to Engineering DPW as it relates to approval for Grease Control Equipment for the Fats, Oil, and Grease Program. If approval is needed for this project by the Engineering Department of Public Works for any other reason than FOG, please contact 207-874-8801.		
<b>Dept:</b> Fire		<b>Status:</b> Approved w/Conditions	<b>Reviewer:</b> Jason Grant	<b>Approval Date:</b> 11/02/2017
<b>Note:</b>		<b>Ok to Issue:</b> <input checked="" type="checkbox"/>		
<b>Conditions:</b>				

PERMIT ID: 2017-01415

Located at: 20 DANFORTH ST

CBL: 040 D001001

1) All construction shall comply with City Code, Chapter 10.  
All construction shall comply with 2009 NFPA 101 Life Safety Code, Chapter # 43 and other applicable chapters  
All construction shall comply with 2009 NFPA 1, Fire Code.  
This review and approval by the AHJ shall not relieve the applicant of the responsibility of compliance with this Code. NFPA 1 (section 1.14.4).  
All means of egress to remain accessible at all times.  
If applicable, all outstanding code violations shall be corrected prior to final inspection