Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 07/12/13

NOTE:
ALL RECEPTACLES SHALL BE 18" A.F.F UNLESS NOTED OTHERWISE

8 A8.6 TYPICAL ELECTRICAL OUTLET HEIGHTS
1" = 1'-0"

CRITERIA NOTES

1. PROVIDE SIGNAGE THAT IS HIGH CONTRAST, NON-GLARE, TACTILE (RAISED CHARACTERS AND BRAILLE) CUSTOM SIGNAGE ON THE WALL AT THE STRIKE SIDE OF THE DOOR (RIGHT SIDE OF DOUBLE DOORS). MOUNT SIGN SO THAT TACTILE CHARACTERS ARE LOCATED 48" MIN. MEASURED FROM THE BASELINE OF THE LOWEST TACTILE CHARACTER AND 60" MAX. FROM THE BASELINE OF THE HIGHEST TACTILE CHARACTER.
2. COORDINATE STUD FRAMING WITH SHOWER PAN DIMENSIONS. REFER TO PLUMBING FIXTURE MATRIX FOR CUT SHEETS AND SHOWER PAN DIMENSIONS.

4 A8.6 ACCESSIBLE SHOWER
NOT TO SCALE

7 A8.6 DOOR SIGNAGE
3/4" = 1'-0"

3 A8.6 ACCESSIBLE TUB
NOT TO SCALE

6 A8.6 GRAB BAR BLOCKING
3/4" = 1'-0"

2 A8.6 ACCESSIBLE SHOWER-BASE SECTION
1 1/2" = 1'-0"

5 A8.6 ACCESSIBLE TUB/SHOWER SEAT BLOCKING
3/4" = 1'-0"

1 A8.6 PLAN-ACCESSIBLE ROLL-IN SHOWER
3/4" = 1'-0"

LOCATE DOORBELL DISABLE SWITCH NEXT TO WELCOME LIGHT SWITCH - DO NOT GANG BOX. PROVIDE SEPARATE LABELED COVERPLATE (TYPICAL)

9 A8.6 HEARING DEVICE TYPICAL LAYOUT
1/4" = 1'-0"

NOTES: 1. ELECTRICAL OUTLET BOXES AND SIMILAR BOXES FOR T.V., PHONE, ETC. IN PARTY WALLS MUST BE STEEL AND NOT OVER 16" SQUARE. SUCH BOXES ARE TO BE SEALED WITH 3M MPP-45 FIRE BARRIER PUDDY PAD OR EQUAL. STACK MULTIPLE BOXES VERTICALLY WHEN ON SAME SIDE OF WALL.

10 A8.6 J-BOX OFFSETS AT ADJOINING ROOMS
1 1/2" = 1'-0"

DEVICES FOR THE HEARING IMPAIRED

SYMBOL	DEVICE	NOTES
J PB	BUTTON FOR DOOR SIGNAL	OUTSIDE DOOR ON STRIKE SIDE, +48" AFF FACTORY LABEL ON COVER PLATE
J T	2-GANG BOX WITH TRANSFORMER FOR DOOR BELL	MOUNT IN SOFFIT OR CABINET – PROVIDE ACCESS
DDS	DOORBELL DISABLE SWITCH	WALL BEHIND ENTRY DOOR, GANG W/ LIGHT SWITCH "DOORBELL DISABLE SWITCH" PLAQUE
G	POINT ADDRESSIBLE SMOKE DETECTOR W/ SOUNDER BASE	MOUNT 4" – 12" BELOW CEILING "FIRE" LABEL INTEGRAL TO DEVICE.
A A H	HORN STROBE FOR DOOR SIGNAL	MOUNT 80" AFF
▽	REMOTE STROBE FIRE/DOOR SIG	MOUNT 80" AFF

NOTES:
PROVIDE ASSISTIVE LISTENING DEVICES IN THE REQUIRED NUMBER OF ROOMS PER BUILDING CODES AND ADAAG 2004.

1. DISTRIBUTE HEARING IMPAIRED ROOMS AMONGST ALL CLASSES OF ROOMS INCLUDING SUITES.
2. PLAQUES (EXCEPT AS NOTED): PROVIDE AS INDICATED. PLAQUES SHALL BE BLACK PHENOLIC WITH 1/4" WHITE ENGRAVED LETTERS.

REVISION SCHEDULE

DATE	REVISION DESCRIPTION	BY

CONSTRUCTION CORPORATION
11 CORPORATE DRIVE, BELMONT NH 03220
PHONE (603) 527-9090 FAX (603) 527-9191

GUESTROOM DETAILS

PROJECT:
COMMERCIAL & MAPLE STREET
MIXED USE DEVELOPMENT
PORTLAND, ME

DATE: 06-20-13
SCALE: SEE PLAN
DRAWN BY: KPH
SHEET: A8.6

© COPYRIGHT 2012 BY O.C.C.