Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 07/12/13

LOUVER DETAIL WITH DUCT FROM BELOW

NTS

NOTE IF DIMENSION "A" IS LESS THAN 1 INCH SEE MODIFIED LOUVER DETAIL THIS SHEET.

LOUVER DETAIL WITH DUCT FROM ABOVE

NTS

NOTE IF DIMENSION "A" IS LESS THAN 1 INCH SEE MODIFIED LOUVER DETAIL THIS SHEET.

LOUVER DETAIL WITH HORIZONTAL DUCT

NTS

NOTE IF DIMENSION "A" IS LESS THAN 1 INCH SEE MODIFIED LOUVER DETAIL THIS SHEET.

LOUVER CONNECTION DETAIL

NTS

NOTE TYPICAL FOR LOUVERS AND BLOCK VENTS. IF DIMENSION "A" IS LESS THAN 1 INCH SEE MODIFIED LOUVER DETAIL AT RIGHT (LOUVERS ONLY).

MODIFIED LOUVER DETAIL

NTS

ROUND/FLAT OVAL FIRE DAMPER INSTALLATION DETAIL

NTS

ROUND/FLAT OVAL FIRE DAMPER INSTALLATION DETAIL WHERE A 12x12 ACCESS DOOR IS NOT POSSIBLE

NTS

RECTANGULAR FIRE DAMPER INSTALLATION DETAIL WHERE 12X12 ACCESS DOOR IS NOT POSSIBLE

NTS

RECTANGULAR FIRE DAMPER INSTALLATION DETAIL

NTS

HEX-2 PIPING SCHEMATIC

NTS

NOTES -
1. INSTALL CP-POOL, CP-SPA BELOW POOL WATER PIPE ELEVATION.
2. PUMPS CP-S & CP-POOL, CP-SPA SHALL ENERGIZE ON A CALL FOR HEAT FROM THE POOL / SPA WATER SYSTEMS.
3. HEX-2 SHOWN, HEX-3 FOR THE SPA IS SIMILAR.

BENNETT ENGINEERING
MECHANICAL • ELECTRICAL
(207) 865-9475

REVISION SCHEDULE		
DATE	REVISION DESCRIPTION	BY

COPYRIGHT 2012 BY O.C.C.

CONSTRUCTION CORPORATION
11 CORPORATE DRIVE, BELMONT NH 03220
PHONE (603) 527-9090 FAX (603) 527-9191

MECHANICAL DETAILS

PROJECT: COMMERCIAL & MAPLE STREET MIXED USE DEVELOPMENT PORTLAND ME.

DATE: 06-06-2013
SCALE: 1/8" = 1'-0"
DRAWN BY:

SHEET: M10